# **Panasonic**

Ultra High-Speed, High-Accuracy Laser Displacement Sensor

# HL-C2 Series User's Manual

# **Preface**

Thank you for purchasing Ultra High-Speed, High-Accuracy Laser Displacement Sensor "HL-C2 Series".

To fully use this product safely and properly, please read this manual carefully. Please check our website (https://panasonic.net/id/pidsx/global) about new info of the product and new version of the user's manual.

#### ■ Note

- Please notice that illustrations in this USER'S MANUAL might be little different from the actual product.
- 2. Contents of this USER'S MANUAL will be changed without notice due to improvements.
- This USER'S MANUAL and software must not be partially or totally copied or reprinted.
- 4. If there are any questions, mistakes, paging disorder, or missing pages in this USER'S MANUAL, please contact our sales office nearest you.
- 5. We have no responsibility of any results of operations regardless of the above.

# ■ Symbol Indications

This USER'S MANUAL uses symbols to indicate safety precautions, instructions, and reference.

Before reading this USER'S MANUAL, fully understand the meanings of these indications.

⚠WARNING	"WARNING" indicates the possibility that death or serious injury could result if a handling error occurs.
<b>△</b> CAUTION	"CAUTION" indicates the possibility that the user could be injured or property could be damaged if a handling error occurs.

<b>O</b> CHECK	"CHECK" indicates any instructions or precautions for
GOILOK	using the system.
@ REFERENCE	"REFERENCE" indicates any hints for operation, detail
SKEFEKENCE.	explanations, or references.
TECHNIQUE	"TECHNIQUE" indicates useful conditions or techniques
DIEGNINIQUE	(know-how) for operation of the system.

# Whole USER'S MANUAL Construction

The HL-C2 Series is prepared for the following user's manuals. Read them as necessary.

#### HL-C2 Series USER'S MANUAL (PDF)



#### This manual

This manual describes cautions for using HL-C2 Series, and installation method, operation method, function details, specifications, maintenance and inspection method of system components (controller, sensor head).

#### HL-C2 Series USER'S MANUAL: RS-232C Communication Control (PDF)



The manual describes various commands for controlling the system by PLC or PC using RS-232C communication. Please read this manual before an evaluation test for system configuration or programming. Please read "HL-C2 Series USER'S MANUAL" for functional details of the system.

# HL-C2 Series USER'S MANUAL: USB Communication Control (PDF)



The manual describes API for controlling the system by PLC or PC using USB communication.

Please read this manual before an evaluation test for system configuration or programming. Please read "HL-C2 Series USER'S MANUAL" for functional details of the system.

# HL-C2 Series USER'S MANUAL: Ethernet Communication Control (PDF)



This manual explains various settings to acquire measurement information of the HL-C2 system by PLC using Ethernet communication.

For detailed explanation concerning the system's functions, precautions for use, etc., refer to the separate "HL-C2 Series USER'S MANUAL".

# ■ USER'S MANUAL for Intelligent Monitor AiM

The Intelligent Monitor AiM, which contains various useful functions in addition to the compact programmable display, is available when developing PC-based system.

#### HL-C2 Series USER'S MANUAL: Intelligent Monitor AiM (PDF)



This manual is included as a PDF file in the Intelligent Monitor AiM, which can be downloaded on our Internet website.

This manual describes installation method, operation method, functional details and error messages of the software.

It also describes an evaluation analysis of HL-C2 Series or use of buffering function and received light intensity waveform display function, which are useful for optimum system setting.

# **Manual Construction**

Specification

Appendix Appendix

	Preface	This chapter provides cautions for safe and correct operation of the product. Be sure to read this chapter.
1	Prior to Use	This chapter explains the configuration, installation, and connection of the system (Controller, Sensor head, and Intelligent monitor AiM).
2	I/O Terminal	This chapter explains I/O terminal blocks on the controller.
	•	
3	Programmable Display Operation	This chapter describes the operation method of compact programmable display.
4	Explanation of Functions	This chapter describes various functions of the system.
	•	
5	Communication Control	This chapter explains control method of system by RS-232C/USB/Ethernet communication.
6	Maintenance and Service	This chapter explains the maintenance and service of the system.
7	Troubleshooting	This chapter explains corrective actions against abnormal state.

4

Арх

3

manual.

Read this chapter if failures are suspected.

components (controller, and sensor head).

This chapter describes the specifications of system

This chapter provides index and revision history of this

# Contents

Whole USER'S MANUAL Construction 1 ■ USER'S MANUAL for Intelligent
Monitor AiM2
Manual Construction3
Contents4
Safety Precautions7
O LIL III
Correct Handling8
Installation Environment8
Use Environment8
■ Ambient Temperature, Humidity and
Illuminance8
■ Power Supply Voltage·····9
■ Environment9
Protective Structure9
Warming Up Time10
Measures to Noise10
Insulation Resistance and Voltage
Resistance10
Power Supply11
Power Supply11
■ Power Supply Sequence for Controller11
Controller 11
Instantaneous Power Failure11
Grounding12
Ground the device when noise
influence is large12
■ Use an exclusive ground ······12
■ Precautions for positive ground
environment13
Installation14
■ Controller14
■ Wire Connections and Connectors ······· 14
■ Cable Extension14
Cautions on Handling Laser Light15
JIS/IEC/GB/KS15
■ Semiconductor laser is used as the
light source of sensor15
■ Cautions 15
■ Warning Label ·······16
CE22
■ CE Compliant Condition22
FDA······23
■ Export to US23
■ Export to US23 ■ FDA-compliant Product23
■ FDA-compliant Product23 ■ Classification23
■ Classification ——23 ■ Labeling ——23
■ Labeling23 ■ Beam Attenuator25
■ Beam Attenuator 25 ■ FDA Standard 26
Remote Interlock27
Kemote Interlock27

Export Regulations by Japanese Government28
■ Compliance with Export Regulations by Japanese Government28 ■ Specification of Export Uncontrolled
Product
1 Prior to Use 1-1
1-1 System Configuration       1-2         1-1-1 System Configuration       1-2         1-1-2 System Components & Accessories         List       1-3
Controller Accessories
Extension Cable for Sensor Head (Optional)
■ Connection cable for compact programmable display (3m) (Optional)·······1-6 ■ Intelligent Monitor AiM ·········1-6 ■ Ethernet Communication Setting Tool ····1-6
<b>1-2</b> Part Names and Functions 1-7 <b>1-2-1</b> Controller1-7 <b>1-2-2</b> Sensor Head1-9
1-3 Installation Method
Mounting ND Filter 1–14  1-4 Connection ————————————————————————————————————
Supply 1–15  1-4-2 Connection Method of Terminal  Block 1–15
Model Number of Terminal Blocks······1-15 Wiring Method········1-15  1-4-3 Connection of Intelligent Monitor
AiM (PC) 1–17  Connection 1–17

	Refractive Index	4-29
		· 4-3
	Timing	· 4-3
		4-34
		· 4-3
		4-36
	Filter Operation	4-3
	Operation Coefficient	
	Offset	
	Upper/Lower Limit Value of Judgmen	it
	•	
	Upper/Lower Hysteresis of Judgmen Output	IT . 1–11
		. 4-4.
	Analog Scaling  Analog Output at Alarm	. 4-4
	Analog Output at Data Unfixed······	
-	Digital Output at Alarm	· 4-50
ī	Alarm Output Delay·····	. 4-5
	Digit Number of Measurement Value	
	-3 Common Setting	
	Sampling Period	
	Terminal Input Control	
	Chattering Prevention of Terminal Input	
	Judgment Output Off Delay	
	Interference Prevention	4-58
4-3	-4 System Setting	4-59
	Display Update Cycle of Measuremer	nt
	Value	4-59
	Change Indication Unit	4-6
	Output Setting Copy	4-62
	Priority Setting of Memory Change	4-6
	Memory Change ·····	4-64
	Memory Copy	· 4-6
	Initialization	4-66
	Save	
-	Communication: COM Port·····	4-69
•	RS-232C Output	· 4-70
	-5 Buffering Setting	
	Data Buffering Operation  Buffering Operation	4-76
•	Self-stop	4-7
	Buffering Mode	4-7
-	Buffering Type ······	. 4-7
-	Buffering Rate	. 4-7
-	Accumulation Amount	- 7 · . - 4 – 7
ī		. 4–80
	Trigger Delay·······	· 4–8
	Trigger Point	· 4-8
	Sample Trigger Accumulation Amount	
	Status Readout ······	4-82
	Final Data Point ······	4-82
	Trigger Counter Readout ·····	4-82
	Data Read·····	· 4–8

4-4 Supplemental Explanation
5 External Communication Control ·5-1
5-1 Communication Control by RS-232C · 5-2 5-1-1 Specifications
5-2 USB Communication Control ··· 5-24  Operating Environment ····································
6 Maintenance and Inspection···6−1
6-1 Maintenance
<b>7</b> Troubleshooting7-1
7-1 Corrective Actions 7-2 7-2 Lock 7-7 7-3 Initialization 7-7

8 Specifications 8	-1
8-1 Controller Specifications 8-2 Sensor Head Specifications 8-3-2 Sensor Head Model 8-3-2 Sensor Head Model 8-3-3-4 Cutside Dimension 8-3-2 Sensor Head Model 9-3-3-4 Outside Dimension 8-3-3-4 Outside Dimension 8-3-4 Sensor Head Specification 8-3-4 Sensor Head Model 9-3-4 Sensor Head Model 9-3	3-8 8-8 8-9 8-9 -36
■ Controller	-39 -48 - <b>49</b> -49 -53
Appendix ······	1
I Index Revision history	

# Safety Precautions

This product is intended to detect the objects and does not have the control function to ensure safety such as accident prevention.

Do not use the product as a sensing device to protect human body.

Please use the products that comply with local laws and standards for human body protection specified by e.g., OSHA, ANSI and IEC.

Please read this manual carefully before using the product and use it correctly.

# **↑** WARN I NG

- Install a fail-safe device when the product is used for the purpose that has a possibility of physical injury or serious extended damage.
- Do not use the product in the atmosphere of flammable gas, to prevent explosion.
- The product was developed and manufactured for industrial use.

# **⚠**CAUTION

- Use the product within specifications.
   Abnormal heat or smoke generation may occur.
- Do not disassemble or remodel the product. Electrical shock or smoke generation may occur.
- Connect the electric wire securely with the terminal screws.

  Imperfect connection may cause abnormal heat or smoke generation.
- Do not touch the terminal during energization of the product, to prevent electrical shock.

# **Correct Handling**

Note the following points when installing and using HL-C2 Series.

# Installation Environment

# ■ Do not install the product in the following conditions.

- Where the ambient temperature, ambient humidity or ambient illuminance of beam receiving surface is beyond the range of specifications
- (→ Refer to "Use Environment".)
- Where dew condensation occurs due to rapid temperature change
- In an atmosphere of corrosive gas or flammable gas
- · Where covered or filled with dust, iron powder and salt
- In an atmosphere which is likely to be exposed to organic solvent such as benzene, thinner or alcohol, or to strong alkaline materials such as ammonia or sodium hydroxide
- · Where heavy vibration or impact is applied
- · Where direct sunlight is received
- · Where water, oil or chemicals splashes
- · Where load is applied to the product

# Use Environment

# ■ Ambient Temperature, Humidity and Illuminance

# Ambient temperature

Use the product with the temperature specification ranges (→ Chapter 8 "Specifications").

Sensor head : 0 to 45°C Controller : 0 to 50°C

Compact programmable display : 0 to 50°C

Store the product with the following specification ranges.

Sensor head : -20 to 70°C Controller : -20 to 70°C

Compact programmable display : -20 to 60°C

- The life of the semiconductor laser depends on the ambient temperature during use. When using the product near a heat source, take measures to keep the ambient temperature of the sensor head as lower as possible. Mount the sensor on a device having good heat radiation because the sensor itself also generates heat.
  - \* As for HL-C211 \( \subseteq (-\subseteq \subseteq)\), when installing two sensor heads in parallel with a distance of 20mm or less, each sensor head should be mounted on aluminum or iron which surface area is 200cm<sup>2</sup> or more.

#### Ambient humidity

Use the sensor within a range of 35 to 85% RH.

Avoid using it in places that may be exposed to dew condensation due to rapid temperature change.

#### Ambient illuminance of light receiving surface

Use the sensor in locations where illuminance from incandescent lamps is 3,000 lx or less.

# ■ Power Supply Voltage

The power supply voltage should be within the rated voltage range of 21.6 to 26.4V DC.

#### Environment

- The internal circuit may be broken when the external surge voltage exceeds 500V [± (1.2×50) μs unipolar full wave voltage]. If there is danger of external surge voltages exceeding 500V, install a surge absorber between the power supply and input terminal.
- Keep the emitter surface and the receiver surface clean, not to attach light refractors such as water, oil and fingerprints, or light blockers such as dust and dirt. When cleaning these parts, wipe them off using a soft lint-free cloth or lens cleaning paper.
- Install the sensor head at where extraneous light (such as sunlight or light
  which has the same wavelength as laser beam) do not enter the receiver. If
  high accuracy is required, install a light shield plate or the like on the sensor
  head.
- Do not use the product in dusty places or that exposed to flammable or corrosive gases, droplet, direct sunlight, severe vibration or impact.

# **Protective Structure**

 The sensor head has protection against immersion, while the controller and connectors are not structurally dustproof, waterproof, or corrosion-resistant.
 Do not use the product underwater or in the rain.

# Warming Up Time

Allow at least 30 minutes of warming up after turning on the power to ensure the performance of the product.

# Measures to Noise

- Install the product as far away as possible from noise source such as high-voltage lines, high-voltage device, power lines, power device, machines which generate a large starting and stopping surge, welding machines and inverter motor.
- Install the product as far away as possible from wireless device that has a transmitter such as amateur radio device.
- The LCD display breaks if excessive static electricity is applied on the panel surface of compact programmable display.
- Do not roll up the sensor cable (bundle in parallel) with other wirings. Keep
  it at least 100mm away from other wires. Cables should be separated from
  high voltage and power circuit lines. If it is unavoidable, shield it by
  running through a conductive material such as grounded electrical conduit.
- For input signal lines and output signal lines, run them separately, not rolled up with the power line and power supply line. Keep them at least 100 mm apart. All signal lines should be connected as short as possible.
- Analog output is affected if a large amount of electrical noise arises in the power supply. In this case, use a noise filter or a noise dampened transformer.
- For signal lines for RS-232C or for I/O terminals, use shielded cables and connect the shielding wire to the frame ground (F.G.) to reduce electric noise.
- Analog outputs is likely to be influenced by noise, especially by external noise. Use shielded wires and wire them as short as possible.
- Use an exclusive class D frame ground and avoid sharing the ground with other devices. This may produce an opposite effect.

# Insulation Resistance and Voltage Resistance

Do not conduct insulation resistance tests and voltage resistance tests among the power supply, I/O signals, metal parts of the controller and sensor head.

# Power Supply

# ■ Power Supply

- Select a power supply with a ripple 0.5V or less (P-P) and a current capacity 2A or more.
- When using a commercial switching regulator, be sure to ground the frame ground (F.G.) terminal to avoid the influence of high frequency noise.
- When using a transformer in the power supply, be sure to use an insulated transformer. The product or the power supply may be damaged if an auto transformer is used.
- Use an insulated power supply that incorporates a protective circuit to protect against abnormal voltages from the power line.
- When using a power supply that does not incorporate a protective circuit, be sure to supply power through a protective element such as a fuse.

# ■ Power Supply Sequence for Controller

- Arrange the power supply sequence so the controller turns off prior to the I/O power.
- If the I/O power turns off prior to the controller, the controller detects the change in level of input signals and this may cause wrong operation.
- Leave an interval for at least 10 seconds between turning off the controller and turning on the power again.
- It takes about 40 to 50 seconds from power-on to operating state (start up completed), depending on the settings saved. No outputs are determined during startup. Do not output anything during the period.
- During startup, -10.8V of analog voltage and -5mA of analog current are output.
- Do not turn off the power while saving the settings. In the worst case, the system of controller is destroyed and may fail to restart.

# Instantaneous Power Failure

If an instantaneous power failure occurs, the system operates continuously, or goes to the same state as power-on state, depending on the duration of power failure. Do not use the system in the environment where an instantaneous power failure occurs.


# Grounding

# ■ Ground the device when noise influence is large

• Under normal use, the product has sufficient noise resistance. In an environment with particularly high noise levels, however, ground it securely.


# ■ Use an exclusive ground

- Use wires of 1.5 mm<sup>2</sup> or more and establish a class D ground with a ground resistance of  $100\Omega$  or less.
- Make the grounding point as close to the controller as possible, keeping the ground wire distance short.
- Use an exclusive ground. Sharing the ground with other devices may produce an opposite effect.
- The connector housing for the sensor head case and sensor cable is connected electrically to the frame ground (F.G.) terminal of the controller terminal through the sensor cable.



# Precautions for positive ground environment

The GND terminals of 24VDC (-) and USB port, SG of RS-232C, and COMMON terminal (-) of the input / output circuit are connected inside the HL-C2. The FG terminal, USB port connector shell, RS-232C connector shell and Ethernet connector shell are also connected inside the HL-C2. Make sure that there is no potential difference from externally connected devices such as a PC and PLC.



If the HL-C2 is used in a positive-grounding environment, power supply (24VDC) can become short-circuited via the GND terminal of PC or USB, thus resulting in a malfunction.

- •Do not ground the positive (+) terminal of the HL-C2.
- •When grounding the positive side of the power supply (24V DC) to the equipment, use a separate power supply (24V DC) for the HL-C2 and insulate the HL-C2.

# Installation

#### Controller


- Install the controller unit according to "1-3 Installation Method", assuring plenty of space around it. If it is installed in a manner other than specified, failures may occur due to temperature rise.
- If the controller is mounted internally on the place where air circulation is blocked such as in a control board, the ambient temperature will rise due to heat generated by the controller. In such case, forced cooling is required.
- Vent holes for heat radiation are provided at the top and bottom of controller unit. Provide adequate space for heat radiation, not to block the holes.

#### Wire Connections and Connectors

- Connect all wirings securely according to the explanations for I/O circuit and description on the unit.
- Turn off the power of controller before connecting or disconnecting the connectors.
- When connecting or disconnecting the connectors, be sure to hold the connector area not to apply extra force to the cable.
- Be careful not to touch terminals or to let foreign objects get in the connector after disconnecting connectors.
- Be careful not to apply force to around the connector of sensor head cable and extension cable. Do not bend the cables near connectors, which causes disconnection of the cable.
- When moving the sensor head during operation, install not to bend the cable during movement. Use replaceable extensions cable where the cable needs to be bent.

#### Cable Extension

- Do not pull the cable with a force more than 29.4N when wiring the cable when the sensor head and the controller are fixed. At least 20 mm is required from the cable connection to the bend. The bending radius must be 30 mm or more.
- Use only one extension cable for connection between one sensor head and a controller.



# Cautions on Handling Laser Light

# JIS/IEC/GB/KS

# Semiconductor laser is used as the light source of sensor

The laser is classified based on JIS (JIS C 6802:2014) and IEC (IEC 60825-1:2014), GB (GB 7247.1:2012), KS (KS C IEC 60825-1:2013) standards.

Class	Max. output	Wavelength	Model No.
1	0.1mW (*1)	658nm	HL-C201A□(-□)
2	1mW		HL-C203B□(·MK), HL-C205B□(·MK), HL-C208B□(·MK), HL-C211B□(·MK), HL-C235BE(·MK)
3R	5mW		HL-C205C□(-MK), HL-C208C□(-MK), HL-C211C□(-MK), HL-C235CE(-MK), HL-C235CE-W(MK)

(\*1) HL-C201A□-SP3□: 0.3mW

#### Cautions

- Be careful not to directly watch the laser beam or its reflected light from a mirror surface.
- 2) Install the sensor so the laser beam comes higher or lower than eye level in order not to watch the beam directly during operation.
  - Laser safety distance (Nominal Ocular Hazard Distance: NOHD) is approx. 0.4m for HL-C203B  $\square$  (-MK) and HL-C205  $\square$  (-MK), is approx. 0.5m for HL-C208  $\square$  (-MK) and HL-C211  $\square$  (-MK), is approx. 1.4m for HL-C235BE(-MK) / HL-C235CE(-MK), HL-C235CE-W(MK). The laser beam must be terminated at the end of its path by a diffuse reflector or an absorber.
- Laser beam emission can be stopped by using the laser control input terminal. (→ "2-1 Functions and Arrangement of I/O Terminal Block")
  - \* Use the interlock control input terminal when using as an emergency stop circuit for safety. Release the short circuit by short bar to stop laser emission.
- 4) Please contact Panasonic Industrial Devices SUNX if the system breaks down. Laser radiation is not automatically stopped during disassembling the sensor head. The users therefore may be exposed to laser beam in disassembling the sensor head.
- Do not use the system in the manner other than specified in this USER'S MANUAL.

	You may be exposed to hazardous laser radiation if the device
▲ CAUTION	is controlled or adjusted in procedures not specified in this
	manual.


6) Read the descriptions of the warning label carefully before use. The warning label is affixed to the side of the sensor head. The Japanese and English warning labels are packed with the sensor. Use them as needed.

# ■ Warning Label

• 10mm type (HL-C201A)




• 30mm type (HL-C203B)



# In Chinese (E type only)







# • 5mm type (HL-C205B)

#### In Japanese / English / Korean

$\Delta$	レーザ放射 ビームをのぞき 込まないこと	LASER RADIATION DO NOT STARE INTO BEAM	레이저 병사 민을 무지하지 미지오
<u>/</u> *\	(表大山力) inW	IMANIMUM OUTPUT) TAW	(하대 중요) 1mW
	(パルス幅) 最大10ms	PULSE SUPATION I MINI NAX	(대시수개간 시(len-
	(課長) 4等ほレーザ	IMEDIAN SELEMBLES ARE	(대권) 번도체레이지
	(議長) 855mm	(WAVELENGTH) OSTIM	(하장) 658ma
_	クラス2レーザ製品	CLASS2 LASER PRODUCT	2 등급 레이지 기본
	UB 0 8862 2016)	(ECOM25-1 2014)	968 O I #Cessez #+ 2016)
V L	ザ放射の出口	LASER APERTURE	전이게 계구


	4-14	급 레이지 당착 좋은 주시의	Wall worth and
	Q 27/2.	김 레르스 경기 육산가스의	
	レーザ放射	LASER RADIATION	레이지 방사
lΛ	ピームをのぞき 込まないこと	DO NOT STARE INTO BEAM	변을 주시하지 비사오.
<u>/</u> **\	(最大公力) leW (y (s 大橋) 北大10ms (建費) 半等体レーザ (連長) が8mm	WAXINU. OUTPUT) Town PULSE DURATION TOWN MAKE MENUN SHICKOUCON DER WAVELENGTHI 1998 M	(영스계속 위원 경역:0ess
	カラス2レーザ製点 (対5 G ette 2014)	CLASSOLASER PRODUCT	2등급 대학치 제품 89 G ECROSS-1 2019

#### In Chinese (E type only)





#### <Label position>







#### • 50mm type (HL-C205C)

# In Japanese / English / Korean




ı	THE COCHTON	March Carried P 45	Billian C Swort C	1
l	CAUTION - CL-589R LA	SER HALIATON WHEN CHEN, AVOI	DURECTEVE EXPOSURE	
Į	주의 - 개방시 32	등을 데이지 방신 책접 눈의	노출은 피려시오.	
ĺ	레이지 방사	LASER RADIATION	レーザ放射	ľ
l	개설 등 노출을 피하시오.	AVOID DIRECT EYE EXPOSURE	日への直接数様(を 避けること	Λ
	(최기 중위) StoW (선시회수시간 최기(ma (대통) 도구(회에리기 (대통) Görnn	QUAXINOUN COMPUT) Servi PULSE DURATION; 16 es max. (MECHUN) SEMPONOUTO LUSCE (MANUELENSTI); 850 cm	(婦大社力) SerW (パルス値) 最大10ms (雑物) 半導体レーザ (雑多) 658mm	<u>/</u> *\
l	3R주변 기에게 제공 MS C FCeesaS I nelso	CLASSER LASER PRODUCT (EC60925-1 2014)	クラスSRLーザ製品 (MS C 6980 2014)	_
ı	편이가 개구	LASER APERTURE	レーザ放射の出	

#### In Chinese (E type only)











# • 85mm type (HL-C208B)

#### In Japanese / English / Korean

^	レーザ放射 ビームをのぞき 込まないこと	LASER RADIATION DO NOT STARE INTO BEAM	레이지 명사 원을 주시하지 마시오.
<b>/</b> *\	(最大山力) :mW	AMAZIMI, MI DUTPUT) 1 INV	(취연 총의) (mW
	(パリス株) 最大報酬	PULSE DURATION) 16 No INIX	IRA (육계간 후기lozo
	(課責) 主導体レーザ	JUENUW) 654 (010), C101 1455.	(괴진) 전도체레이지
	(議員) 888mm	(WAVELENGTH) 658 IN	(취상) 658ma
_	クラス2レーザ製品	GLASSE LASER PRODUCT	2 등급 위에서 제품
	(JIS C text2 2014)	(ECROSES 2014)	pc3 015Causza-c 2013)
V	ザ放射の出口	LASER APERTURE	전이저 계구


CAUTION - CLASSICLAS	SER RADIATION WHEN OPEN JOIN	DT STARE INTO BEAM	
주의 - 개방시 2등	납 레이지 당부 좋은 주시회	ব হসতে	
	LASER RADIATION DO NOT STARE INTO BEAM (MAXIMUM OUTPUT) 1 MW (PULSE DIRATION) 1 MW (PULSE DIRATION) 1 MW (MAXIMUM SHIDONACTOR LIBER (MX VELENSTH) 658000 CLASSE LASER PRODUCT	レーザ放射 ビームをのぞき 込まないこと (国大なか left/ グリス(最) まだけのs (変数) キザタルーザ (決義) osten フラスとレーザ製品	<u>*</u>

#### In Chinese (E type only)





#### <Label position>



#### • 85mm type (HL-C208C)

#### In Japanese / English / Korean






#### In Chinese (E type only)







# • 110mm type (HL-C211B)

#### In Japanese / English / Korean

		レーザ放射 ビームをのぞき 込まないこと (3人はか): new (7人に関: は大10ms (7月) + 年日レーザ (本兵) 955ms クラス2レーザ製品 (18 C 9882 2018)	LASER RADIATION  DO NOT STARE INTO BEAM  MADIAN OUTBUT, INW PULSE DURATION; SHIP RICK WINDLENGTH, SHIP WINDLENGTH; SHIP WINDLENGTH; SHIP GLASSE LASER PRODUCT INCOME.	페이지 병사 민준 무스하지 마시오. (여도 후하 1mm (소시속 제한 소(1com (대한) 연도제에이지 (여항) 655ms 2종급 편이기 제품 88 (15002351 2019
--	--	---	---	---


	うス2のレーザ放射が出る ビーム		
	SEH RACUATION WHEN OPEN JON THE 레인지 당착 좋은 주시회		
레이지 방사	LASER RADIATION	レーザ放射	
원을 주시하지 비사오.	DO NOT STARE INTO BEAM	ピームをのそか 込まないこと	Λ
(독대 출제) 1mW 경소계속시한 최명(den) (예상) 만조제(하여지 (학생) 558(co)	WAXIMUM CUTPUT) 1649 (PULSE DURATION) 1649 MAX. (MECHUN) SEMICONOLIDA 128FR (WAVELENSTH) 05816	(原大日力) feW () (に大幅) 北大10ms (課費) 中等体レーザ (演長) 958mm	<u>/*\</u>
2등급 데이지 제품 (3 0 HC80828-1 2018)	CLASS2 LASER PRODUCT (ECKRIST-1 2014)	クラス2レーザ製式 (#3 G sesse 25/4)	_
편이자 계구	LASER APERTURE	レーザを飲む出	- V

#### In Chinese (E type only)





#### <Label position>







#### • 110mm type (HL-C211C)

# In Japanese / English / Korean


	レーザ放射	LASER RADIATION	레이지 방사
Λ	日への直接技ぜくを	AVOID DIRECT EYE	리를 눈 노출을
	述けること	EXPOSURE	리하시오.
<u>/</u> **\	(成文表の) Smir	MAXIMUM GUTPUT) SERV	6위의 중앙 51,000
	((か久間) 最大10ms	(PULSE GURATION) TOTAL	(6소지수(전) 531555
	(協力) 単環線レーザ	(MEDIUM: SOMEXICUTTRUSCO	(여명) 1만5 위(이곳
	(対質) 658mm	(WAVELENSTIT: 658mm)	(여명) 65848
_	クラス3RLーザ製品	CLASSOR LASER PRODUCT	32분명 이이의 제품
	(JB C 6509 2014)	(E00005-1 0014)	#8 C FCaters 1 2015
V□	一ザ放射の出口	LASER APERTURE	<b>《이지 가구</b>

住業一ここを買くとクラ	<b>スポのレーザ放射が到る 日への直</b>	接待はくを辿っること	)
CAUTION - CL-559H LA	SER HALIATON WHEN CHEN, AVO	DILBRECT EYE EXPOSITE	
주의 - 개방시 32	등을 레이지 방사 작품 눈의	노출은 피리시오.	
레이지 방사	LASER RADIATION	レーザ放射	)
의접 등 노슬은 위하시오.	AVOID DIRECT EYE EXPOSURE	月への直播数様くを 避けること	Λ
(최기 중위) SuW 영선 제속기원 최기(ma (대공) 도구제(하위기 (대공) Sitem	QUANTIALIN SUTPUT) STAN PULSE DURATION) 16 MINING ARCAIN) SCHOOL COLUMN (WAVELENGTH) 850 MINING	(超大性力) Ser(W (パリンス質) 最大10mo (経費) 半導体レーザ (油素) がitem	<u>/</u> *\
3R ≨ tr d o d n ₹ pre C Fotoses I serie	ALKOCOB LACED GENOLIST	クラスSRLーザ製品 (JB C 680C 2014)	_
의시기 제.3	LASED ADERTURE	1. 409/8+000	

# In Chinese (E type only)











#### • 350mm type (HL-C235BE)

#### In Japanese / English / Korean

	INUM OUTPUT) THW	(最末年力) ToW	/u/
(제공) 단도되셔야의 (제품)	SE DUMATION) TRACTAGE MAIG SEMECHBUCTOR MER VELLINGTHI) GGRESS	5 (p.ス度) 最大itera (特別) 平等体レーザ (表長) (Seinn	<u> /**\</u>
S등군 네이저 제중 CLA KS C (Ectolgs-1 2013)	ASS2 LASER PRODUCT	クラス2レーザ装具 (AS G GHZ 2014)	_



#### In Chinese

洋賞	激光辐射	
打开对有2类效光辐射	勿直视光束	\Lambda \lambd
勿直配光束	最大输出: 1mW 脉宽:最大10ms 媒体:半导体激光 波长:658nm	<b>/</b> 秦\
	2类激光产品 GB7247.1 2012	_
	激光窗口	<b>□ V</b> .



#### <Label position>







# • 350mm type (HL-C235CE)

#### In Japanese / English / Korean

레이지 방사 독립 등 도움을 계획시으	AVOID DIRECT EYE EXPOSURE	レーザ放射 Eへの直接組よくを 通けること	$  \wedge  $
(村町 泰軍) 6mW	(MADIMUM OUTPUT) SHAW	(京文出方) Selfi	<u>/</u> **\
(現在文章人)第 用電 fire	(PULSE DURATION) TORRITOR,	(パルス度) 法大10ms	
(司達) (整統利用司等	(MEDIUM) STAKONOLICTORIJSER	(京江) 年等日レーザ	
(神後) 655ms	(WAYELENGTH) ESTINE	(汉長) Videns	
2분등급 레이크 기준	CLASSIR LASER PRODUCT	クラス3Rレーザ製品	_
(KS C ((GRORES-1 2013)	[ECRESS-1 8014]	(JS C 6852 2016)	
레이커 계곡	LASER APERTURE	レーザ放射の出	- V



#### In Chinese











#### • 350mm type (HL-C235CE-W)

# In Japanese / English / Korean

의 이 제 병사 지정한 노선을 제한 시간. (하다 항상) GraW (환수 선수시의 카디(Sra (기선) 한도카리이처 (환선) 선(Stan (환선) 선(Stan (환선) 선(Stan)	LASER RADIATION  AVOID D RECT EYE EXPOSURE  (MAXIMAN OUTPUT) SHIW PULSE DURETTING "CHINE YOU, METHING 3 SHIPOUTCY SHIPS  WAS ELASED PRODUCT (ECONOCI 1261-16)	レーザ放射 Eへの音楽域はくを 適けること (お大血力) SetV (バスス版) は大いか (成現) 平時はレーザ (成現) 956m クラスSRレーザ報告 (JFC 950cm	*
레이저 계근	LASER APERTURE	レーザ放射の出口	7 VI


	注葉一ここを飼くとクラス20のレーデ放射が出る Bへの管控機はくを続けること				
	CAUTION - CLASSIR LASER PAULATION WHEN OPEN LAVOUD HECT ETE EXPOSURE				
	주의 - 개당기 3만	등급 케이커 방사 책임 높의	· 출은 폐하시오.		
^	レーザ放射 日への直接値(を 難けること	LASER RADIATION AVOID DIRECT EYE EXPOSURE	케이지 방사 지정 등 도로운 계환기도		
<u>/</u> **\	(副大島力) SerW (デルス質) 副大10ms (課費) 平等終レーデ (連長) 668mm	(WAXIWUM OUTPUT) SINW PULSE DURATION) 10ms NO. SHEDIAN) SEMOSIDUCTORUSER (WAVELENGTH) 660mm	(미리 중에) 558W (비스 사람시한 위에 3ms (비슨) 만드레이어가 (바람) 55Accs		
_	クラス3R L 一州製品 (JS G 6R02 2514)	GLASSSR LASER PRODUCT (EC60825-1 2016)	(83년)급 레이지 지준 (63년) ECROSOS : 2019)		
V [	一ザ汝射の出口	LASER APERTURE	데이저게든		

#### In Chinese

注意 为开制有3B炎治丸辐射 超免增精度均直线换射	激光辐射 避免以隔受到直接照射 最大输出: 5mW 脉变:最大10ns 媒体: 半导体激光: 波长: 658nm 3R类激光产品 GB7247.1 2012	*
l	激光窗口	_ ▼



# <Label position>







#### • 8mm type (HL-C201A□-SP2□)

In Japanese / English / Korean





• 15mm type (HL-C201A□-SP3□)


#### In Japanese / English / Korean






<Label position>


HL-C201A□-SP2□






# CE

Make sure to use CE compliant sensor head and programmable display for making this product CE compliant.



# ■ CE Compliant Condition

To meet the CE compliant condition, attach ferrite cores (SEIWA ELECTRIC MFG. Co., Ltd. E04SR200935A) to the power supply cable and the head cable shown as below.



[Contact for CE]

Panasonic Marketing Europe GmbH Panasonic Testing Center Winsbergring 15, 22525 Hamburg, Germany

# **FDA**

# ■ Export to US

When the laser product mounted on equipment is exported to the United States, they are subjected to the regulation of the Food and Drug Administration. In order to prevent the injury on users due to laser products from happening, FDA has established PART 1040 (Performance Standards for Light-Emitting Products). FDA classifies laser products according to the degree of risk and provides the safety measures for respective classes ( Refer to the "FDA Standard" table). Use the FDA-compliant products as shown below.

# ■ FDA-compliant Product

HL-C201F (E)/HL-C201F (E) -MK HL-C203F (E)/HL-C203F (E) -MK HL-C205B (E)/HL-C205B (E) -MK/HL-C205C (E)/HL-C205C (E) -MK HL-C208B (E)/HL-C208B (E) -MK/HL-C208C (E)/HL-C208C (E) -MK HL-C211F (E)/HL-C211F (E) -MK HL-C211F5 (E)/HL-C211F5 (E) -MK

HL-C235CE-W/HL-C235CE-WMK

# Classification

FDA-compliant products are classified as listed below.

Model	Class
HL-C201F(E)/HL-C201F(E)-MK	I **1
HL-C203F(E)/HL-C203F(E)-MK	
HL-C205B (E)/HL-C205B (E)-MK	II
HL-C208B (E)/HL-C208B (E)-MK	
HL-C211F(E)/HL-C211F(E)-MK	П
HL-C205C (E)/HL-C205C (E)-MK	
HL-C208C (E)/HL-C208C (E)-MK	Ша
HL-C211F5(E)/HL-C211F5(E)-MK	Ша
HL-C235CE-W/HL-C235CE-WMK	

<sup>\*1 10</sup>mm type is classified as Laser Class I, Laser Notice No.50.

# ■ Labeling

The product uses the following labels in accordance with FDA standards.

• Aperture/Warning label, Protective housing label






#### Certification/Identification label

Panasonic Indus	trial Devices SUN	X Co., Ltd	
2431-1,Ushiyama-cho	,Kasugai,Aichi,486-090	1,Japan	
Complies with 21 Cl	FR 1040.10 and 1040	.11	KDCL
MANUFACTURED			
	SERIAL NO.		

#### <Label position>








# **O**CHECK


The figures above show the examples of major model (for L-C203F(E)/HL-C203F(E)-MK). As for label positions of other models, refer to the Instruction Manual for sensor head included in each product.

# ■ Beam Attenuator

Use the attached beam attenuator if there is a danger of getting laser beam into your eyes during operation.



Fix the beam attenuator with the attached screws to cover the light emitting surface.



When the beam attenuator is not used, fix it to either side surface of sensor head with the attached screws.

# ■ FDA Standard

Paguiramento	Class*1					
Requirements	I	IIa	II	IIIa	IIIb	IV
Performance (all laser products)						
Protective housing [1040.10(f)(1)]	$R^{*2}$	$R^{*2}$	$R^{*2}$	$R^{*2}$	$R^{*2}$	$R^{*2}$
Safety interlock [1040.10(f)(2)]	R*3,4	$R^{*3,4}$	R*3,4	$R^{*3,4}$	R*3,4	R*3,4
Location of controls [1040.10(f)(7)]	N/A	R	R	R	R	R
Viewing optics [1040.10(f)(8)]	R	R	R	R	R	R
Scanning safeguard [1040.10(f)(9)]	R	R	R	R	R	R
Performance (laser system)						
Remote interlock connector	N/A	N/A	N/A	N/A	R	R
[1040.10(f)(3)]						
Key control [1040.10(f)(4)]	N/A	N/A	N/A	N/A	R	R
Emission indicator [1040.10(f)(5)]	N/A	N/A	R	R	$R^{*10}$	$R^{*10}$
Beam attenuator [1040.10(f)(6)]	N/A	N/A	R	R	R	R
Manual reset mechanism	N/A	N/A	N/A	N/A	N/A	$R^{*13}$
[1040.10(f)(10)]						
Performance (specific-purpose products)						
Medical [1040.11(a)]	S	S	S	$S^{*8}$	S*8	S*8
Surveying, leveling, alignment	S	S	S	S	NP	NP
[1040.11(b)]						
Demonstration [1040.11(c)]	S	S	S	S	S*11	S*11
Labeling (all laser products)						
Certification/identification [1010.2,3]	R	R	R	R	R	R
Protective housings	D	R*5	R*5	R*5	R*5	R*5
[1040.10(g)(6),(7)]						
Aperture [1040.10(g)(5)]	N/A	N/A	R	R	R	R
Class warning [1040.10(g)(1),(2),(3)]	N/A	R*6	R*7	R*9	R*12	R*12
Information (all laser products)						
User information [1040.10(h)(1)]	R	R	R	R	R	R
Product literature [1040.10(h)(2)(i)]	N/A	R	R	R	R	R
Service information [1040.10(h)(2)(ii)]	R	R	R	R	R	R

R : Required N/A : Not applicable

S : Requirements : Same as for other products of that Class.

NP : Not permitted

D : Depends on level of inner radiation

- \*1 Class is based on the maximum level of laser exposure during operation.
- \*2 Required wherever and whenever such human access to laser radiation levels that exceed the limits of Class I is not necessary for the product to perform its intended function.
- \*3 Required at the protective housing which is designed to be removed or displaced during operation or maintenance, if removal or displacement of the protective housing could permit human access to laser or collateral radiation.
- \*4 The requirements for interlock differ depending on the class of inner radiation.
- \*5 The contents of label differ depending on the level and wavelength of laser radiation inside the protective housing.
- \*6 Warning statement label
- \*7 CAUTION logotype
- \*8 The method to measure the level of laser radiation to human body is required.
- \*9 CAUTION if 2.5mWcm<sup>-2</sup> or less, DANGER if greater than 2.5mWcm<sup>-2</sup>.
- \*10 Time difference is needed between instruction and emission.
- \*11 Exception should be provided for demonstration of laser products or light shows using laser of Class IIIb or IV.
- \*12 DANGER logotype
- \*13 Required after August 20, 1986.


# Remote Interlock

Interlock control input terminal can be used as the emergency stop circuit for safety purposes.

- For NPN type, laser beam emission can be stopped by opening the IL terminal and (-) terminal.
- For PNP type, laser beam emission can be stopped by opening the IL (+) terminal and IL (-) terminal.

At factory shipment, the short bar for short circuit is attached to the remote interlock terminal.

Remove the bar and connect the cable when using the interlock control function.



# **Export Regulations by Japanese Government**

# ■ Compliance with Export Regulations by Japanese Government

Some models are subject to export control, which is defined by "Foreign Exchange and Foreign Trade Act".

#### · Export controlled products

Below products fall under the export control, which is defined by "Foreign Exchange and Foreign Trade Act". When exporting or transferring these products outside of Japan, the license from the Japanese government is required.

Also, these products fall under the international export control regime, such as NSG (Nuclear Suppliers Group) guidelines 1.B.3.b.1 and WA (Wassenaar Arrangement) 2.B.6.b.1.a, and are objects of the regulation. Please comply with the export control in each country.

```
HL-C2C(-\square), HL-C21C(-\square): Controller is the export controlled item HL-C2\square\square\square(-\square\square) : Sensor head is the export controlled item
```

#### Export uncontrolled products

Below products do not fall under the export control, which is defined by "Foreign Exchange and Foreign Trade Act".

```
HL-C2CE(-\(\pi\)), HL-C21CE(-\(\pi\)) : Controller that does not fall under the control (E type controller)

HL-C2\(\pi\)\(\pi\) : Sensor head that does not fall under the control (E type sensor head)
```

- \* Use the standard cable and programmable display.
- \* To identify E type, see the type identification plate affixed on the sensor, the programmable display or intelligent monitor AiM.

# **O**CHECK

Select the combination of E type controller and E type sensor head mentioned above, not to be subject to export control regulation. If either the controller or the sensor head is export controlled product, the product is subject to export control regulation.

# ■ Specification of Export Uncontrolled Product

The specification of display resolution and measurement resolution for the export uncontrolled products are shown below. Other specifications not mentioned here are the same as export controlled products.

0.25µm

- \* The programmable display and Intelligent Monitor AiM displays the measured value in increments of 0.25μm.
- \* Numerical input, e.g. setting of upper limit for comparison judgment output, can be set in increments of 0.001μm. The internal processing, however, is done in increments of 0.25μm. In this case positive values are omitted and negative values are rounded up.
- \* Settings by USB and RS232 are also possible in increments of 0.001μm. The data of measurement value responded is incremented by 0.25μm.
- \* If you change the default value of operation coefficient setting, the displayed measurement value will not be incremented by 0.25μm.

# ■ Functional Restriction

- •When the export controlled sensor head is connected to the E type controller, lasers on both Head A and Head B turn off. The output of measurement value for OUT1 and OUT2 become zero. In such a state the alarm output is always ON and the system is unusable.
- •In case the E type head is connected to the export controlled controller,

Type and operation of sensor head connected to E type controller

Connect	Onamation	
Head A	Head B	Operation
E type	E type	0
E type	=	0
E type	Controlled	×
Controlled	E type	×
Controlled	Controlled	×
Controlled	-	×

- the product can be used without restrictions in functions or specifications. This combination of controller and sensor head, however, is subject to export control regulations.
- \* The Code 6 is returned when alarm output is read using the external communication function while the export controlled head is connected to the E type controller. 

  "Chapter 5 External Communication Control"

# МЕМО



# Prior to Use


This chapter explains the configuration, installation method, and connection method of the system (Controller, Sensor Head, Compact Programmable Display, and Intelligent Monitor AiM).

1-1	System Configuration
1-2	Part Names and Functions       1-7         1-2-1 Controller       1-7         1-2-2 Sensor Head       1-9
1-3	Installation Method       1-10         1-3-1 Controller       1-10         1-3-2 Sensor Head       1-11
1-4	Connection
	(PC) ·····1-17

# 1-1 System Configuration

# 1-1-1 System Configuration

The system configuration and the cables for connecting the devices are shown as below.



If the sensor head is connected to the sensor head B connection (HEAD B) side, the measurement cannot be


performed.

Refer to **→** "1-4 Connection" for proper connection of each device.

# 1-1-2 System Components & Accessories List

#### ■ Controller Accessories

The accessories of the controller are as shown below.



I/O terminal block NPN type PNP type

Analog output/laser control terminal block



NPN type

Ferrite core

SEIWA ELECTRIC MFG. Co., Ltd. E04SR200935A × 3

TDK ZCAT3035-1330 × 1



RS-232C protection cap



\*1: HL-C2C is attached.

The short bar is already installed with the remote interlock terminal as default.

USB cable (2m)




#### **HL-C2 Series Instruction Manuals**



# ■ Sensor Head Accessories

The accessories of the sensor head are as shown below.



## Warning label








# ■ ND Filter Unit (Optional)

ND Filter Unit (Type: HL-C2F01)



## ■ Extension Cable for Sensor Head (Optional)




## ■ Compact programmable display (Optional)


Refer to the "HL-C2 Series User's Manual: Programmable Display" for handling regarding installation and connection.

Refer to "Chapter 3 Programmable Display Operation" for the operation method.

Main unit of compact programmable display



Compact programmable display brackets & Screws



Product name	Screen	Backlight	Body color	Product no.
	4.6-inch STN 320 x 120 dots	Green /Orange /Red	Pure black	AIG12GQ02D
GT12G				AIG12GQ12D
G112G			Hairline silver	AIG12GQ03D
				AIG12GQ13D
GT12M		White /Pink/ Red	Pure black	AIG12MQ02D
				AIG12MQ12D
			Hairline silver	AIG12MQ03D
				AIG12MQ13D

Terminal block for compact programmable display



■ Connection cable for compact programmable display (3m) (Optional)



## ■ Intelligent Monitor AiM


Intelligent Monitor AiM and "HL-C2 Series USER'S MANUAL: Intelligent Monitor AiM" can be downloaded on our website (https://panasonic.net/id/pidsx/global).

## ■ Ethernet Communication Setting Tool

Ethernet Tool Configurator WD (compatible to Ver.1.62 and later) can be downloaded on our website (https://panasonic.net/id/pidsx/global).

# 1-2 Part Names and Functions

## 1-2-1 Controller



#### 1. POWER Indicator

Lights up in green when electricity is provided to the controller.

#### 2. ALM1 (Alarm) Indicator

Abnormal condition indicator for OUT1.

Lights up in red during dark status (poor light intensity) of OUT1 or the sensor head is unconnected status.

#### 3. ALM2 (Alarm) Indicator

Abnormal condition indicator for OUT2.

Lights up in red during dark status (poor light intensity) of OUT2 or the sensor head is unconnected status.

#### 4. LASER A Indicator

Lights up in green during the laser radiation of Head A.

#### 5. LASER B Indicator

Lights up in green during the laser radiation of Head B.

### 6. Analog Output Terminal

Terminal for analog data output.

#### 7. Laser Control Terminal

Stops laser emission in case of short-circuiting.

#### 8. Remote Interlock Terminal

Stops laser emission when its opened.

#### 9. USB Connector

Used for communication with PC using USB.

#### 10. Programmable Display Connection Connector

Used for connecting the compact programmable display.

#### 11. RS-232C Connector (\* Only HL-C2C is equipped.)

Used for communication with the control devices using RS-232C.

#### 12. I/O Terminal

Terminal for various I/O (Zero Set Input, Timing Input, Reset Input, Alarm Output, Strobe Output, and Judgment Output) and memory change.

Refer to → "2-1 Functions and Arrangements of I/O Terminal Block".

#### 13. Power Terminal

Terminal for power supply to the controller.

Refer to • "1-4 Connection" - "Power Connection".

#### 14. Sensor Head A Connection Connector

Controller recognizes a sensor head which is connected to this connector as "Sensor Head A" and starts operation.

#### 15. Sensor Head B Connection Connector

Controller recognizes a sensor head which is connected to this connector as "Sensor Head B" and starts operation.

#### 16. DIN Rail Mounting Hook

Used for hooking/removing the sensor heads to/from the 35mm width DIN rail with one-touch simple operation.

#### 17. Ethernet Connector (\* Only HL-C21C□ is equipped.)


Used for communication with the control devices using Ethernet.

## **OCHECK**

In case of connecting one sensor head to the controller, be sure to connect the sensor head to (14) the sensor head A connection (HEAD A) side.

If the sensor head is connected to (15) the sensor head B connection (HEAD B) side, the measurement cannot be performed.

## 1-2-2 Sensor Head



## (1) Laser Emission Indicator (LASER ON)

Lights up in green during laser emission.

#### (2) Measurement Range Indicator (RANGE)

Lights up in yellow when the target reaches at approximately center of the measurement.

Blinks in yellow when the target enters within the measurement range.

Turns off the light when the target goes out of the measurement range.

Refer to • "8-6 Characteristics" - "Output Characteristics and Measurement Range Indicator".

## (3) Light Emitter

Emits the laser light.

#### (4) Light Receiver

Receives the laser specular light from a measurement target.

### (5) Warning Label

Shows the laser emission position.

Please read carefully before use.

# 1-3 Installation Method

Before installing each device, read carefully the explanation of the setting environment, concerning about noise or radiation, and the power supply. Refer to \*Correct Handling".

## 1-3-1 Controller

The controller can be installed by using DIN rail or using screws.

## ■ Installation by Using DIN Rail


The controller can be easily installed/uninstalled by using 35mm width DIN rail (DIN EN50022) with one-touch operation.

#### Installation

- 1 Hook the upper tab on the DIN rail.
- **2** Push the bottom of the controller until it clicks. The installation of the controller is completed.

#### Removal

- 1 Insert the flathead screwdriver in the mounting lever.
- 2 Pull down the mounting lever.
- **3** Raise the controller and remove it.




## ■ Installation by Using Screws

Using two M4 screws, fix the controller securely. The tightening torque should be 0.7N·m or less.

→ Refer to "8-5 Outside Dimension".

## 1-3-2 Sensor Head

Securely fix the sensor head in two screw holes using M5 screws.




## **OCHECK**

- •The tightening torque should be 1.2N·m or less.
- •The depth of both screw holes is 10mm, not through-holes. Be careful to choose screws with considering its length.

### Installation Direction of Sensor Head


To obtain the greatest precision and the best stability, the sensor head should be oriented facing the direction of the measurement targets as shown in the figure below.

- Installation direction for the moving target
- Measurement of extremely different adjacent colors or materials
   When measuring a moving target that is extremely different adjacent colors or materials, the direction of the sensor head should be as shown below to minimize the measurement error.




#### · Measurement of a rotating target

When measuring a rotating target, the direction of the sensor head should be as shown below to minimize the effect of vertical oscillation or displacement.




### · Measurement of step detection

When measuring a moving target that has difference grooves, the direction of the sensor head should be as shown below to minimize interference caused by target edges.




#### Measurement of a target in narrow space or slot


When measuring a target in narrow space or slot, the direction of the sensor head should be as shown below so that the emitted and received light are not blocked.




#### • Measurement of a black target or low-light intensity


When measuring a low-reflectance black target, light intensity reflected from the target decreases and the signal from the linear image sensor is also getting smaller. As a result, it decreases the resolution. So mount the sensor head as shown below to increase the light received intensity.








[Shorten the distance]




Black target

## When mounting the sensor head to a wall surface

The direction of the sensor head should be as shown so that the receiver does not receive the multiplex reflected beam from the wall. If the wall reflectance is high, painting the surface matte-black is effective.






#### • Angle between the measurement center and the sensor head

#### Diffuse reflection surface

Mount the sensor head as shown at the right, so the emitter surface and receiver surface of sensor head is parallel to a measuring target. For the measurement center distance and measurement range, refer to → "8-2 Sensor Head Specifications".



90 degrees

#### Specular reflection surface

Mount the sensor head as shown at the right, so the angle between the emitting and receiving laser light is symmetry to a measuring target. Make sure that the specular reflection line (tilt of the head) is perpendicular to a measuring target as shown in the right.

For the measurement center distance and measurement range, refer to  $\Rightarrow$  "8-2 Sensor Head Specifications".


# Mounting ND Filter

Mount the ND filter (option) in case the amount of reflected beam is too large on specular reflection installation.


Securely tighten the two attached M2.6 bind screws (4mm length) to two screw holes on the sensor head. The tightening torque should be  $0.3N\cdot m$  or less.

## **O**CHECK

Carefully mount ND filter not to get fingerprints or damage on the glass. If you do get fingerprints or other stain on the lens, wipe it off with an optical cloth.



HL-C203, HL-C211




HL-C235

# 1-4 Connection

# 1-4-1 Connection Method of Power Supply


- Connect 24VDC power supply wiring with "24V" and "0V" terminals of the terminal 3.
- •Use twisted wires to minimize the effect of noise.

Rated Voltage	24VDC
Tolerance Voltage Variation Range	21.6 to 26.4VDC
	One sensor head: approx. 0.45A Two sensor heads: approx. 0.6A
Incoming Current	8A or less



# 1-4-2 Connection Method of Terminal Block

The controller has three terminal blocks.



## ■ Model Number of Terminal Blocks

The terminal blocks are detachable from the controller and fixed with screws. Use the tools and electric wire in the below list.


Terminal Block	Manufacturer	Туре
Socket	PHOENIX CONTACT Ltd	MC1.5/16-ST-3.5(Color:Black) MC1.5/11-ST-3.5(Color:Black)
Tightening Tool	Flathead Screwdriver	Tightening Torque
rightening roof	Blade Width: 0.4 X 2.5	0.22 to 0.25N·m
Adaptable	Size	Cross-section Area
Electric Wire (Stranded Wire)	AWG#24 to 15	0.5 to 1.5mm <sup>2</sup>

# ■ Wiring Method


1 Strip insulation from the end of the wire.



2 Insert the wire in the terminal block until it contacts the back, then, secure it by tightening the screw.



**3** If two or more terminals are connected, twist wires before inserting them.



## **O**CHECK

- Be sure to turn off the power supply before wiring or detaching the terminal blocks.
- Never use wires tinned with solder. They may break by vibration.
- The length of the wire should be 30m or less.

# 1-4-3 Connection of Intelligent Monitor AiM (PC)

A USB driver must be installed to a PC before connecting a controller and PC installed Intelligent Monitor AiM.


For installation of the USB driver, refer to the "HL-C2 Series Intelligent Monitor AiM USER'S MANUAL".

The below operating environment is required for operating the intelligent monitor AiM.

Operating environment		
os	Microsoft Windows® 7 Professional 32bit/64bit Microsoft Windows® 8.1 Pro 32bit/64bit Microsoft Windows® 10 Professional 32bit/64bit (Japanese, English, Chinese, Korean)	
CPU	1GHz or more processor*1	
Hard Disc	50MB or more of available memory	
Memory	2GB or more*1	
Display	SXGA (1280 × 1024 full color) or more	
USB Port	USB 2.0 Full Speed (USB 1.1 compatible) compliant	
Serial Port	RS-232C-compliant, Communication speed: 115.2kbps	

<sup>\*1</sup> It depends on the operation environment of OS.

#### Connection



<sup>\*</sup>Windows is a registered trademark of Microsoft Corporation in the United States and other countries.

## МЕМО




This chapter explains I/O terminal blocks on the controller.

2-1	Functions and Arrangements of I/O	
	Terminal Block······	2-2
2-2	I/O Circuit······	2-4
2-3	Interlock Circuit······	2-6
2-4	Analog Output Circuit · · · · · · · · · · · · · · · · · · ·	2-7
2-5	Timing Chart ······	2-8


# **2-1** Functions and Arrangements of I/O Terminal Block

### Analog output terminal block/Laser control terminal block



Term	ninal	Function	
NPN	PNP	Function	
(V	)1	Analog voltage output (for OUT1)	
AG	ND	Analog ground	
(1)	)1	Analog current output (for OUT1)	
(V	)2	Analog voltage output (for OUT2)	
AG	ND	Analog ground	
(1)	)2	Analog current output (for OUT2)	
LS	RA	Laser control input (for Head A) Laser stop during short circuit	
LS	RB	Laser control input (for Head B) Laser stop during short circuit	
(-	-)	Common (-)	
IL	IL-	Remote interlock Laser stop when opened.	
(-)	IL+	Remote interlock common	

#### I/O terminal block



Term	ninal	Function	
NPN	PNP	runction	
ZS	31	Zero set input (for OUT1) ON during short circuit*	
ΤN	<i>l</i> 11	Timing input (for OUT1) ON during short circuit	
RS	31	Reset input (for OUT1) ON during short circuit	
		Reserved terminal	
		Reserved terminal	
(-	·)	Common (-)	
AL	_1	Alarm output (for OUT1)	
S1	Γ1	Strobe output (for OUT1)	
HI1		Judgment HI output (for OUT1)	
·		Judgment GO output (for OUT1)	
LO1		Judgment LO output (for OUT1)	
		Reserved terminal	
(-)	(+)	Common (-)/Common (+)	
24	١V	24VDC input for power supply	
0V Power supply ground 0V		Power supply ground 0V	
F	G	Frame ground	


<sup>\*</sup> Turn off the terminal in case short circuit lasts for more than one second.

Refer to • "1-4 Connection" for the connection method of terminal block.

## **O**CHECK

Do not connect anything to the reserved terminals; they are connected to the internal circuit.

### I/O terminal block



Terminal		Function	
NPN	PNP	Function	
ZS	32	Zero set input (for OUT2) ON during short circuit*	
TN	<i>1</i> 2	Timing input (for OUT2) ON during short circuit	
RS	S2	Reset input (for OUT2) ON during short circuit	
(-	-)	Common (-)	
Al	_2	Alarm output (for OUT2)	
S	Γ2	Strobe output (for OUT2)	
Н	12	Judgment HI output (for OUT2)	
G	D2	Judgment GO output (for OUT2)	
LC	)2	Judgment LO output (for OUT2)	
		Reserved	
(-)	(+)	Common (-)/Common (+)	
M	10	Memory change (16 ways)	
M	11		
M2		wemory change (10 ways)	
М3			
(-)		Common (-)	

<sup>\*</sup> Turn off the terminal in case short circuit lasts for more than one second.


Refer to • "1-4 Connection" for the connection method of terminal block.

## **O**CHECK

Do not connect anything to the reserved terminals; they are connected to the internal circuit.

# 2-2 I/O Circuit


# ■ NPN Type



# **O**CHECK

The common (-) and the power supply (0V) for main unit are internally connected. Be sure not to cause the potential difference at operation.

## ■ PNP Type




## **O**CHECK

The common (-) and the power supply (0V) for main unit are internally connected. Be sure not to cause the potential difference at operation.

# 2-3 Interlock Circuit


## ■ NPN Type

Connect IL and Common (-) in case of NPN output type.



## ■ PNP Type


Connect IL+ and IL- in case of PNP output type.



## OCHECK

IL+ is connected to the 24V power supply at the internal circuit. Do not connect the voltage input or PNP transistor open collector output to it.

# 2-4 Analog Output Circuit




\*: Either "1" or "2" is entered.

## **OCHECK**


- · Do not short-circuit analog output terminals or apply voltage to them.
- · Use shielded wires for analog outputs.

# 2-5 Timing Chart


#### Normal measurement




#### Peak/bottom measurement



The above chart uses peak measurement for explanation.





- Zero set by timing input during HOLD status is valid.
- Reset input by timing input during HOLD status causes data unfixed status. The system holds this status until the timing input is cancelled.
- Zero set input during data unfixed status is invalid.
- The system holds reset input during data unfixed status until the timing input is cancelled.
- Judgment output is determined by the measurement value, judgment output upper limit, and judgment output lower limit. It is turned to OFF during data unfixed status.
- At any data unfixed status other than that caused by reset input, the programmable display displayed value, analog output, and judgment output do the same performances as the reset input operation.
- Analog output during data unfixed status is indicated by the setting of initial value.
- When "Offset" is set, the offset value is added at execution of zero set.
- If zero set is executed during peak to peak measurement, the measurement value at that time becomes the zero (reference value of measurement). Therefore, inputting reset during executing zero set makes the reference value of measurement a negative (-) value.
- When digital output at alarm is fixed, judgment output is conjunction with the fixed value.


### Processing of zero set/timing/reset input

	On timing input	Reset input (during data unfixed)
Zero set input (ON/OFF)	The input is reflected at the moment of zero set (programmable display displayed value and analog output).	Invalid
Timing input		Hold data unfixed status.
Reset input	The data unfixed status occurs at the moment of reset input (HOLD status while timing input is ON).	


## Function of timing input (level)

Analysis mode	Function
Normal measurement	This mode holds the measurement value when timing input turns to ON. The HOLD status is cancelled when it turns to OFF.
Peak/bottom measurement	This mode starts the HOLD status when input signal turns to ON. The HOLD status is cancelled when it turns to OFF. The peak (bottom) value is reset when the HOLD status is cancelled.
Peak to peak measurement	This mode starts the HOLD status when input signal turns to ON. The HOLD status is cancelled when it turns to OFF. The data is set to zero when the HOLD status is cancelled.


#### Laser control



#### Interlock control



- \*1 Sampling period (Ts) × average number of times Laser stability time is also required.
- \*2 For laser stop input, remote interlock input and memory change input, the setting should be ON2 (continuous input for more than 100ms), regardless of the setting in Chattering Prevention for Terminal Input Refer to → "4-3-3 Common Setting" "Chattering Prevention for Terminal Input".



# **Programmable Display Operation**

3-1 Operation Screens ······ 3-2
3-2 Basic Operation 3-6
3-2-1 First Measurement ······3-6
3-3 Screen Transition Diagram ····· 3-10
3-3-1 Display Waveform of Received Light
Intensity ····· 3-14
3-3-2 Received Light Intensity at Peak

The screen data and "HL-C2 Series User's Manual: Programmable Display" can be downloaded from our website (https://panasonic.net/id/pidsx/global).

# 3-1 Operation Screens


#### Screens


• Top menu and Setting menu



The left figure shows the Top screen.

All kinds of screens displayed on the programmable display can be changed through any of the keys on the Top menu.





Touching respective keys moves the screen to corresponding menu.

Head A	Touch the key to move to Head A Menu screen.
Head B ·······	Touch the key to move to Head B Menu screen.
OUT1	Touch the key to move to OUT1 Menu screen.
OUT2	Touch the key to move to OUT2 Menu screen.
Common	Touch the key to move to Common Menu screen.
System	Touch the key to move to System Menu screen.

Operation of basic keys


Top Touch the key to return to Top screen.
Meas Touch the key to move to Measurement Value screen.
Wave Touch the key to move to Received Light Intensity Waveform screen.
Menu Touch the key to return to respective Menu screens.

## ■ Shift Screen Levels

The operation screen consists of hierarchical tree structure.

Touch the **♣** keys to move to the desired screen and set the required items.

Touch the keys to shift the screen among the same hierarchical level.



Shift to lower tier by one level

····· Shift to upper tier by one level

Advance to another item on the same level


Return to another item on the same level

Change between Head A/B or OUT1/2, or change of Menu


## ■ Select Variables from among Alternatives

This section explains how to select the variables from among alternatives.


### [Case 1: small number of alternatives]



#### [Case 2: large number of alternatives]



The variable changes every time the  $\boxed{\blacktriangledown}$  key is pressed.



Touch the key to change the variable in reverse order.


Touching the setting value displayed between the ▼ and ▲ keys returns the setting to the initial value.

## ■ Enter Value


This section explains how to enter the numerical value for upper/lower limit value or offset. A numerical keypad is displayed on the screen for numerical input.


- Touch the frame above the setting value.
   The cursor blinks and numerical value can be entered.
- 2 Enter the integral value using the keypad.
- **3** Touch the . (decimal point) key. Enter the decimal fractions.


- 4 Touch the (enter) key.
  This determines the value.
  - \* Touch the [ES] key to cancel and quit the entry.
  - \* Touch the RL key to clear the entry and reenter the value.
  - \* Touch the Bs key to delete the previous numerical value.












MEMO

# 3-2 Basic Operation

## 3-2-1 First Measurement

This section explains the basic operating procedures of measurement with HL-C2 Series product.

# STEP1 Initial power-on



Connect the controller, sensor head and compact programmable display.

→ "1-1 System Configuration"

Make sure that the +24VDC power supply is connected correctly.

→ "1-4-1 Connection Method of Power Supply" Check the wiring of interlock.

Laser emission starts after the system is turned on and starts up correctly.


Check if the interlock terminal short circuits and laser control terminal is opened if laser does not light.

→ "2-1 Functions and Arrangements of I/O Terminal Block" Check the power supply connection if the POWER indicator does not light.

Approximately 25 to 30 seconds are required from power-on to laser emission.

After the programmable display starts up correctly, the measurement value display screen appears. This completes start-up procedures.

# STEP2 Basic setting



Select diffuse reflection mode or specular reflection mode depending on the measurement object.

→ "4-3-1 Head Setting" – "Installation Mode"

Select Diffuse [Standard] to set the diffuse reflection mode. Select Specular [Standard] to set specular reflection mode.


→ "4-3-1 Head Setting" – "Measurement Mode"

The initial values for other settings can be used to measure the distance to the surface of measurement object.


More detailed settings enable various kinds of measurement.

→ "Chapter 4 Explanation of Functions"


# STEP3 Position adjustment of sensor head



# STEP4 Initialization





# STEP5 Save settings



# STEP6 Thickness measurement

This step explains the basic setting procedures of thickness measurement. The example below shows the procedures for thickness measurement using two sensor heads.







## TECHNIQUE

- The difference in the measurement value between sensor head A and B, because an object is extremely different adjacent colors or materials, can be adjusted by setting Calibration function to each sensor head.
- → "4-3-1 Head Setting" "Calibration"
- · Use Zero Set function to measure the amount of displacement from the reference thickness.
  - → "4-3-2 OUT Setting" "Zero Set"
- $\cdot$  Select the measurement mode according to the material used for stable measurement.
  - → "4-3-1 Head Setting" "Measurement Mode"
- Change the sampling cycle and moving average depending on the amount of displacement and moving speed of measurement object for stable measurement.
- → "4-3-3 Common Setting" "Sampling Cycle" and "4-3-2 OUT Setting" "Filter Operation"
- When using a reference measurement object, measure the object while Output Selection is set to -(A+B) and then execute Zero Set. The thickness of the object is set to Offset. This makes the measurement easier.

# STEP7 Thickness measurement: glass material





Set Output Selection to Transparent Object A when measuring glass thickness.

→ "4-3-2 OUT Setting" – "Output Selection"

Select the measurement surface based on the glass layers to be measured. In this example, 1st Surface – 2nd Surface is set.

→ "4-3-2 OUT Setting" – "Transparent Object"

An optional ND filter may be needed when measuring an object with high reflectance. Make sure that the received light intensity is not saturated.

→ "3-3-1 Display Waveform of Received Light Intensity"

The thickness of multiple surfaces or clearance can be measured.

→ "4-3-2 OUT Setting"- "Transparent Object"

Measurements that reflect refractive index can be done. (the

Measurements that reflect refractive index can be done. (the refractive index of glass is generally around 1.55).

→ "4-3-2 OUT Setting"- "Refractive Index" and "Refractive Index Calculation"

## JTECHNIQUE

**Output Selection** 

Set

Transparent Object


Fix ND filter


Advanced settings


- The difference in the measurement value due to the surface state of measurement object can be adjusted by setting Calibration function.
- → "4-3-1 Head Setting" "Calibration"
- Measurement of thin objects or that with thin clearance is available when "Glass" is selected in the Measurement Mode.
  - → "4-3-1 Head Setting" "Measurement Mode"


# 3-3 Screen Transition Diagram

### Screen Flow










# 3-3-1 Display Waveform of Received Light Intensity

The compact programmable display can display the signal of received light intensity at Sensor Head A and B.

When the measurement object is transparent, adjust the position while viewing the waveform to make the measurement easier. In correct and accurate measurement, two peak waveforms for each surface appear in case of one panel of glass. In case of two panels of glass, four peak waveforms appear.

As shown below, the programmable display can display "whole waveform" and "enlarged waveform" screens.




# 3-3-2 Received Light Intensity at Peak

The screen displays the peak intensity of received light at measurement point.

If the waveform has more than one peak, the largest value of intensity is displayed. The screen also displays the state of received light intensity if an alarm occurs in the measurement range.

Recd Light Int	ensity at Peak	Тор
Head A	500	
Head B	500	




# **Explanation of Functions**

This chapter describes various functions of the system.

4-1	Data Flow 4-2
4-2	Classification of Function · · · · 4-3
4-3	Function List & Initial Values · · · · · 4-3
	4-3-1 Head Setting 4-7
	4-3-2 OUT Setting 4-23
	4-3-3 Common Setting 4-53
	4-3-4 System Setting 4-59
	4-3-5 Buffering Setting · · · · 4-75
4-4	Supplemental Explanation · · · · · 4-84
	4-4-1 Alarm Setting and Outputs 4-84
	4-4-2 Conditions When Output Data
	become Unfixed ······ 4-85
	4-4-3 Memory Save and Terminal
	Setting 4-88

## 4-1 Data Flow

Up to two sensor heads can be connected to the controller. Individual measurement by each of sensor head and calculation of measurement values for two sensor heads can be performed. Operation flow of each function is shown as below.



# 4-2 Classification of Function

In this system, all functions are classified into four categories for fixing stable measurement and various outputs.

Classification	Details
	Function setting for stable measurement by improving accuracy of laser emission intensity
OUT Setting	Function setting related to output data processing
Common Setting	Function setting for common setting of "Head setting" and "OUT Setting".
System Setting	System setting such as "Initialization", "Save", and the communication settings.

# 4-3 Function List & Initial Values

Class	Functi	on	Details	Initial value	Memory change*1	
	Installation N	/lode	Selects the measurement type from diffuse reflection or specular reflection for the target object.	Diffuse*2	0	4-7
	Measuremer	it Mode	Selects the most suitable digital operation type for the target object.	Diffuse [Standard]*2	0	4-8
	Emission Ad	justment	Sets the optimum emitted light intensity for the measurement area.	AUTO	0	4-10
	Emission Area-a Adjustment Area-b		This function specifies an emission auto	1	0	4-11
Setting			adjustment area.	512	O	4-11
Head Se	Emitted Ligh Intensity Sea		Searches the received light intensity of all measurement surfaces and sets the optimum intensity automatically.	AUTO	Х	4-13
	Alarm Delay Times		Holds the previous normal value up to the set number of times during alarm operation.	8	0	4-14
	Measurement Surface Reference		Selects the counting method of the surface which is set at "Output Selection".	Near	0	4-15
	Measuring	Point a	A given range can be specified for	3	0	4-16
	Range	Point b	measurement.	510	J	. 10
	Laser Contro	ol	Switches emission/stop of laser.	Emission	0	4-18

<sup>\*1</sup> Memory Change O: Maximum 16 settings can be saved by performing memory change.

X: Settings can not be changed by performing memory change.

<sup>\*2</sup> When the initialization is performed with 10mm type (HL-C201A) connected, the default of the installation mode is specular reflection, the default of the measurement mode is specular reflection [standard].

Class		Fund	tion	Details	Initial value	Memory change*1	Ref. page
Head Setting	Calib	ration	value a value to the measurement object's color, material, surface condition.		Upper measurement limit (positive number) Upper measurement limit (positive number) Lower measurement limit (negative number) Lower measurement limit	0	4-19
Head		Recog	value b gnition	Sets the peak of the received light waveform and the recognition level.	(negative number)	0	4-21
	Medi	an Filte	er	Cut off sudden changes in measurement values in order to prevent variation in measurement.	OFF	0	4-22
	Outp	ut Sele	ection	Selects whether measurement is individually performed by each sensor head or performed by two sensor heads with various calculation.	OUT1:A OUT2:B	0	4-23
	Т	ranspa	rent Object	Selects the measurement surface from several surfaces existed in the transparent object.	1 <sup>st</sup> surface	0	4-25
		Refra Index calcu		Reflects the refractive index, which is set at "Refractive Index", to the measurement result.	OFF	0	4-27
		Refractive Index		Sets the refractive index for measuring transparent object.	1.000000	0	4-29
	Zero Set			Forcibly sets the measurement value to "0".	OFF	0	4-31
	Timing			Holds the measurement value display of compact programmable display and analog output.	OFF	Х	4-33
	Rese	ŧ		Resets the measurement value.	OFF	Χ	4-34
Setting	Hold			Stops updating the measurement value display.	OFF	Х	4-35
etti	Anal	ysis Mo	s Mode Sets the analysis mode. Normal		0	4-36	
OUTS	Filte	Opera	ition	Selects the moving average, low-pass, or high-pass.	Moving average	0	
0	А	verage	Times	Sets the average number of times of moving average.	512 times	0	4-37
	С	utoff fr	equency	Sets the cutoff frequency of the low-pass/high-pass filter.	100Hz	0	
	Oper	ation C	Coefficient	Sets the operation coefficient for the measurement value.	1.000000	0	4-39
	Offse	et		Adds/subtracts the offset value to/from the measurement value.	0.0000mm	0	4-40
			r Limit value	Sets upper/lower limit value for judging the measurement	Upper measurement limit (positive value)	0	4-41
	Judg ent	Lowe	r Limit Value		Lower measurement limit (negative value)		4-41
	Outp	Uppe	er Limit Hys.		0.1% of the meas. range	0	4-43
			er Limit Hys.	output for chattering.	0.1% of the meas. range Upper meas. limit		_
	امدا		eas. Val A	Performs scaling the analog	(positive val.) +5[V]	0	4-45
	Anal Scali	na –	eas. Val B	voltage output to any desired value.	Lower meas. limit		
				uconeu value.	(positive val.)		
*17		V	oltage b	16 " 1 11 6 1	-5[V]		

<sup>\*1</sup> Memory Change O: Maximum 16 settings can be saved by performing memory change.

X: Settings can not be changed by performing memory change.

Class	Function	Details	Initial value	Memory change*1	Ref. Page		
	Analog Output at Alarm	Sets the analog output status at alarm operation.	Hold previous value	0	4-48		
	Fixed Value	Fixes the analog output status at alarm operation.	+10.800[V]	0	4-40		
ng	Analog Output at Data Unfixed	Sets the analog output status at data unfixed.	-10.800[V]	0	4-49		
Setting	Digital Output at Alarm	Sets the digital output status at alarm operation.	Hold previous value	0	4-50		
OUT	Alarm Output Delay	Retards output from the alarm terminal.	ON	0	4-51		
	Digit Number of Measurement Value	Sets the display digits number of measurement value on compact programmable display.	5 digits	0	4-52		
	Analog Output at Data Unfixed	Sets the analog output status at data unfixed.	-10.800[V]	0	4-49		
Э	Sampling Cycle	Sets the sampling cycle for measurement.	40µs	0	4-53		
Setting	Terminal Input Control	Independent	0	4-55			
non S	Chattering Prevention for Terminal Input	Prevents chattering of terminal input.	ON1	0	4-56		
Common	Judgment Output Off Delay	Delays the timing of switching ON to OFF of the judgment output.	OFF	0	4-57		
)	Interference Prevention	Prevents interference between 2 sensor heads.	OFF	0	4-58		
	Display Update Cycle of Measurement Value	Sets the update cycle of measurement value display.	Standard	☆	4-59		
	Change Indication Unit	Changes the indication unit of the measurement value on compact programmable display.	mm unit	☆	4-61		
	Copy Output Setting	Copies the setting contents of between memories.	"OUT Setting"	Х	4-62		
Setting	Priority Setting of Memory Change	Sets the terminals and command	ls.	☆	4-63		
set	Memory Change	Changes memory for saving the s	etting contents.	☆	4-64		
System 5	Memory Copy	a memory to	Х	4-65			
sys	Initialization	Х	4-66				
U)	Initialize All Memory	itialize All Memory Initializes all memory settings.					
	Save	Saves all memory settings.		Χ	4-68		
	Communication: COM Port	Sets RS-232C communication.					
	Baud Rate	Sets the communication speed.	115200bps	☆	4-69		
	Data Length	Sets the number of bits of data.	8bit				
*14	Parity	Sets the parity.	None				

<sup>\*</sup>Memory Change O: Maximum 16 settings can be saved by performing memory change.

X: Settings cannot be changed by performing memory change.

<sup>☆:</sup>Settings are saved as common settings of all memories. Settings per each memory cannot be executed.

Class		Function	Details	Initial value	Memo ry chang e*	Ref. page
	RS-2	232C Output	Makes the settings of the measurer for RS-232C communication.	nent data output		
		RS-232C Output Mode	Sets the output mode of the measurement data.	Handshake	☆	4-70
etting		RS-232C Output Type	Sets the output type of the measurement data.	OUT1		
System Setting	Con	sole Setting	Performs various settings programmable display.	for compact		
Syst		Panel Lock	Prevents any error settings due to misoperation of compact programmable display.	OFF	☆	4-72
		Start-up Screen	Selects the next displaying screen after wake-up screen of compact programmable display.  OUT1 Di Screen			
	Self-	stop	Stops buffering operation automatically.	OFF	Х	4-77
	Buffering Mode		Loads the measurement data to PC by accumulating the data in the controller.	Continuous mode	Х	4-77
	Buff	ering Type	Selects the accumulating output.	OUT1	Х	4-79
gı	Buffering Rate		Loads the measurement data for a long-duration by decimating the measurement data during data accumulation.	1	Х	4-79
<b>Buffering Setting</b>	Accı	umulation Amount	Sets the accumulation data amount.	20000 data	Х	4-79
fering	Trig	ger Conditions	Sets the conditions of trigger generation.	At timing input on	Х	4-80
Buf	Trig	ger Delay	Delays the timing of accumulation after the trigger generation.	0	Х	4-81
	Trig	ger Point	Sets the trigger generation position in the accumulated data.	10000	Х	4-81
		ple Trigger ımulation Amount	Sets the accumulation data amount at every trigger generation.	1	Х	4-81
	Stat	us Readout	Checks the operation status of accu	ımulation.	Х	4-82
	Last	Data Point	Reads out the accumulation some assurement data amount.	tatus from the	Х	4-82
	Data	Read	Reads out the accumulated data.		Χ	4-83

<sup>\*</sup>Memory Change O: Maximum 16 settings can be saved by performing memory change.


X: Settings cannot be changed by performing memory change.

<sup>☆:</sup>Settings are saved as common settings of all memories. Settings per each memory cannot be executed.

# 4-3-1 Head Setting

#### Installation Mode

Measurement type can be selected from the diffuse reflection and specular reflection according to the kind of measurement object.



Setting for measuring any objects other than mirror-surface or transparent objects

Setting for measuring mirror-surface and transparent objects.

#### Supplemental remarks

Diffuse reflection is set as a default. Be sure to set to "Specular reflection" when measuring a mirror-surface or transparent object.

Note that the mounting angle is different between the diffuse reflection and the specular reflection.


Refer to →"1-3 Installation Method" for proper installation. If the settings or installation are not correct, accurate data cannot be acquired.

## O CHECK

In case that the initialization is done by connecting 10mm type (HL-C201A), the default is set to "specular reflection".

#### How to Use

1 Display the "Installation Mode" screen.




2 Touch "Installation Mode" key to select the installation mode.

The display changes between Diff Refl and Spec Refl by touching the key.

#### Setting screen of sensor head B





#### ■ Measurement Mode

The optimum digital processing type can be selected to measurement object types.

The measurement mode is a function for selecting the optimum measurement algorithm such as unbalance correction of received light waveform. Select the optimum measurement mode depending on the material of target or application purpose to get the stable measurement value. The below list shows all measurement modes and their details.

Setting item	Purposes & Applications	Effects	Recommended setting
Diffuse Reflection [Standard]	· Any objects other than mirror-surface or transparent objects · Metal, resin, ceramic, etc.	Standard setting suitable for many applications. Try this setting at first.	
Metal 1	· Hairline finished metal · Extrusion, rolled material, etc	Reduces the variation of measurement value caused from the metal surface effects.	Diffuse
Metal 2	· Hard hairline finished metal · Materials with tiny scratch, cutting mark, grinding mark	Enhances the effect in "Metal 1" mode.	Reflection
Penetration	· Half transparent objects · Half transparent resin	Reduces penetration of laser light to a target object.	
Specular Reflection [Standard]	· Mirror surface or transparent objects · Front and back surface of glass	Standard setting for measurement at specular reflection installation. Try this mode at first.	
Glass	·Clearance of glass, thickness	Performs measurement on thinner clearance than normal clearance.	Specular Reflection
Glass Pattern	· Pattern glass	Reduces the variation of measurement value due to different refractive index.	


<sup>\* &</sup>quot;Hairline" means the metal finishing with detailed continuous line patterns on its surface.

## **O**CHECK


- · Select appropriate "measurement mode" for your application by actually performing measurement.
- · Regardless of "Installation Mode (specular or diffuse reflection)", any measurement mode can be selected.

- How to use
  - 1 Display the "Measurement Mode" screen.


#### Setting screen of sensor head A



Setting screen of sensor head B



**2** Touch the appropriate measurement mode key to a target object.



## ■ Emission Adjustment

This function sets an appropriate emitted light intensity to a measurement object. AUTO is set as a default. "AUTO" automatically sets optimum emitted light intensity to meet the reflection light amount of the measurement target.

When the function is set to "AUTO", the current light intensity is displayed in percent figures.

In case that "Emission Adjustment" is set to "Fixed", set the value to approximately 600 to 700 while checking "Received Light Intensity Waveform Display" or "Received Light Intensity at Peak" of compact programmable display and Intelligent Monitor AiM.

#### **OCHECK**

Normally set the emission adjustment function to AUTO for use.

## TECHNIQUE


To measure the objects where light reflection may vary excessively, such as on an object having many holes or a connector pin in which light-shielding status and light-passing status may be repeated, alarm status may continue due to delayed feedback. In this case, for increasing the measurement speed, fix the appropriate light intensity to the measurement point.


The laser light reflection intensity excessively varies depending on the mounting condition of the sensor head, the surface condition or refractive index of the measurement object. If the settings of "Emission Adjustment" is not sufficient, change the "Sampling Cycle" for acquiring appropriate received light intensity.

When the measurement is executed with the sensor head mounted in specular reflection and the refractive index of the measurement object is high, the setting of the emission adjustment is not sufficient due to the excessive light reflection intensity. In this case, install ND filter unit (optional).

#### • How to use


1 Display the "Emission Adjustment" screen.








2 Set the emission intensity by ▲▼ key. The below shows the light intensity of 31 levels of the setting value.





## 4

## ■ Emission Adjustment Area

This function specifies an emission auto adjustment area. The light intensity feedback function operates between the two cells from starting cell to ending cell.

### TECHNIQUE

In case of measuring a transparent object where the high reflectance in the surrounding affects the emission, it is possible to adjust the emission on the beam receiving surface you wish to detect by specifying an emission adjustment area.


Emission Adjustment Area specifies two light receiving cells of Area-a and Area-b. The light intensity feedback function works so that the light received intensity is optimal among the specified areas. Area-a and Area-b are set in the range from 1 to 512 respectively.

#### **OCHECK**

- This is valid when Emission Adjustment is selected as "Auto".
- •In case the sampling cycle is set to 10 μs, set Area-a and Area-b in the range of 1 to 112 respectively.
- •In case the sampling cycle is set to 20  $\mu$ s, set Area-a and Area-b in the range of 1 to 256 respectively.
- The magnitude relation between Area-a and Area-b is automatically determined by the controller. However, do not set the two to the same value.
- •In case the setting range of the specified area is not appropriate, light will be emitted at 100% fixed and measurement alarm will go off.

#### ■How to use

1 Display the "Emission Adjustment Area -a" screen.



- 2 Touch Head A (or Area B) in order to input the values.
- 3 Touch the number keys to specify the area.



**4** Touch ✓ key to decide on the specified area.

Emi	ssion	Adju	ıst Aı	rea a	Hea	dΑ		Тор
1 2 3 cell								Menu
1	2	3	4	5	*	ES	CL R	Area b
6	7	8	9	0	ŀ	BS	Λ	▶
							75	$\overline{\gamma}$
							$\vdash$	3

## ■ Emitted Light Intensity Search

This function searches the received light intensity of a measurement surface and sets the appropriate emitted light intensity automatically.

## TECHNIQUE

Set this function when measuring the thickness of a transparent object with low received light. Without this function, "Emission Adjustment" function automatically optimizes the emitted light intensity based on another objects or surfaces with high received light. This results in failure of optimizing the emitted light intensity for any low-reflectance objects. This function is useful for measuring the setting surfaces at "Output Selection".

To optimize the received light intensity of an object with the least light intensity among the all setting received light surfaces at "Output Selection", determine the emitted light intensity of it from the fixed value of 31 levels and change the setting.

After the completion of "Emitted Light Intensity Search", the optimum value will be displayed within "0.04% fixed to 100% fixed". If the search is failed, "Emission Adjustment" is set to "AUTO".


### CHECK

When changing the initial setting of "Output Selection", perform it before starting the emitted light intensity search. Refer to "4-3-2 OUT Setting"-"Output Selection".

This searches the emission intensity in all areas regardless of the setting of emission adjustment area.

#### How to use

1 Display the "Emitted LI Search" screen.



Execution screen of sensor head B



2 Touch the Execute key to execute the "Emitted LI Search".

The right screen appears during emitted light intensity search. After the completion of the search, the below screens appears depending on the result.



When Search was completed.



When search was failed.

Emitted LI Search Head A WARNING
Emitted Light Intensity Search Impossible.
Set AUTO Emission Adjustment.

OK

The start screen of the step 1 appears again. On the screen, the current "Emission Adjustment" value can be confirmed.

When the search has been failed, the "Emission Adjustment" is set to "AUTO".

## Alarm Delay Times

This function holds the previous (latest) normal value up to the setting number of times when an alarm is issued.

This function relates to the digital measurement value, analog output, alarm terminal output, controller alarm indicator under an alarm status.

## TECHNIQUE

When "Fixed value" is set at the "Analog Output at Alarm", this function prevents the fixed outputting of an instantaneous alarm status due to the changes in the surface condition of the measurement object.

When an alarm is issued (due to insufficient light intensity, or when a measurement object is not in the measurement range), the previous normal value is on hold up to the setting number of times at this function.

If the alarm exceeds the setting number of times, the fixed value that has been set at "Analog Output at Alarm" or "Digital Output at Alarm" is output.

However, when the "Hold Previous Value" has been selected at "Analog Output at Alarm" or "Digital Output at Alarm", the alarm output is on hold during the alarm status irrespective to the alarm delay number of times.

## @ REFERENCE

For the alarm terminal output, irrespective to this setting, the "Alarm Output Delay Function" can reflect the alarm status to the measurement in real-time.

#### How to use

1 Display the "Alarm Delay Times" screen.

#### Setting screen of sensor head A

Alaı	Тор								
	old alue)	Menu							
1	1 2 3 4 5 ½ 등 유								
6	7	8	9	0	$\Box$	BS	٦	•	


#### Setting screen of sensor head B




- 2 Touch Head A (or Head B) and enter the setting value.
- 3 Set the alarm delay times by touching numerical key.

Set "0" to turn off the function, and set "65535" when the previous normal value is on hold.

**4** Touch the key to confirm the setting number of times.





## ■ Measurement Surface Reference


This function selects the counting reference of the setting surface at "Output Selection".

Before measuring a transparent object, select the measurement surface reference from "Near Setting" (counting the layer of the measurement surface which is set at "Output Selection" from the nearest surface to the farthest surface) or "Far Setting" (counting the layer from the farthest surface to the nearest surface) as shown below.


#### TECHNIQUE

The measurement surfaces can be recognized accurately only when they are within the measurement range of the sensor head.

Thus, if one of them goes off the measurement range due to movement of the sensor head or the measurement object, the actual measurement point may also be moved from the setting point. In this case, set the "Measurement Surface Reference" with concerning the moving area of the sensor head or the measurement object to prevent a detection error.



- How to use
  - 1 Display the "Meas Surf Ref" screen.








2 Select the measurement surface reference.

The key display is changed between Near and Far each time the key is touched.



## ■ Measuring Range

A given range can be specified for measurement.


## TECHN I QUE

When you want to measure thickness, etc. of a transparent object, operation in "Output selection" becomes impossible if there are seven or more measurement faces. Measurement becomes possible by specifying a face to be detected in measuring range specification.

In order to set a measuring range, specify the positions of two light receiving cells (Measuring Point a and Measuring Point b). The area in between the specified two points are set as the measuring range, and other areas are excluded from measurement.

Measuring Point a and Measuring Point b should be respectively set between 3 and 510.

Check the received light wave pattern indications on the compact programmable display and on the Intelligent Monitor AiM.



## O CHECK

- The relative sizes of Measuring Point a and Measuring Point b are automatically determined by the controller. Do not use the same value for two points.
- · When the sampling cycle is set to 10 μs, set Measuring Point a and Measuring Point b respectively between 3 and 112.
- $\cdot$  When the sampling cycle is set to 20  $\mu s$ , set Measuring Point a and Measuring Point b respectively between 3 and 256.
- · When a specified measuring range is inappropriate, the light emission level is fixed to 100%, and a measurement alarm is issued.

#### • How to use

1 Display the "Measuring Range" screen.

Setting screen for Sensor Head A


Measuring Range					Head A				Toķi	
Ро	Ponta ЖЖЖ cell						Me	ernu		
1	2	3	4	5	ź	g <sub>o</sub>	ğL	÷		
6	7	В	9	0		۰,	Ţ		•	

Setting screen for Sensor Head B


Mea	s unn	gRa	nge		Нее	dΒ		To	<b>3</b> ¢1
Po	onta ЖЖЖ cel				ı			Ме	k'Nu
1	2	3	4	5	z	g,	ğ۲	•	
6	7	В	9	0	$\cdot$	ь,	t		•



- 3 Touch Head A (or Head B) and enter the setting value.
- **4** Specify the area by touching the numeric keys.



**5** Enable the specified area by touching the key.



#### ■ Laser Control

This function switches ON/OFF of the laser emission.

With this function, laser emission, that is unnecessary except at measurement, can be stopped.


#### **OCHECK**

- While the laser emission stop is input (with LSRA and LSRB short-circuited) from the laser control terminal of the controller, the setting there influences this function.
   In that case, this function is invalid (due to the priority of the laser terminal input).
- When the laser control is set to "Stop" and then set to "Emission", the system becomes the data unfixed status temporarily. The strobe output is set to "OFF" under the data unfixed status. After recovered from the data unfixed status, the strobe output is set to "ON" and the analog output and the measurement value display are started. (Refer to →"2-5 Timing Chart".)
- The laser emission is not started by setting the laser control to "ON" while the laser emission OFF (IL is released) is set at the remote interlock function.

#### How to use

1 Display the "Laser Control" screen.

#### Setting screen of sensor head A




4

#### Setting screen of sensor head B



**2** Touch the "Laser Control" key and changes the setting.


The key display is changed between Emission and Stop each time the key is touched.



#### Calibration

This function corrects the deviation of the measurement value caused from the color, material, or surface condition of the measurement object.

As shown below, the value can be corrected by setting two points of "a" and "b" respectively to the point "A" and "B". The point "A" means the actual measurement value, and the point "a" means the correction value. The point "B" and the correction value "b" can be set as same as the above.



#### **OCHECK**

Before setting the calibration, be sure that the timing input, offset, and zero set is set to "OFF", the analysis mode is set to "NORMAL", OUT1 is set to "A" and OUT2 is set to "B" for the output selection. Then, perform the calibration setting in the appropriate measurement mode.

•


Calibration

5.000000 =


Meas A

#### How to use

1 Display the "Calibration" screen.



Setting screen of sensor head B



Head B

5.000000


Menu

Corr a

Лежя (mm) Corrb (mm) -5.0000000 - -5.0000000

**2** Touch the Change key The screen is changed.

Touch each key to change the screen.




- →For inputting the measurement value or correction value
- →For loading the measurement value from the current value

3 Set/change the measurement value or correction value. For setting or changing method of the measurement value and correction value, refer to "For inputting the measurement value or correction value" and "For loading the measurement value from the current value".

**4** Touch the Excute key.

\*Touch the Cancel key to cancel changing the value.

Calibration starts with the setting value.




Menu

Change

# For inputting the measurement value or correction value

1 Touch the Meas A, Meas B, Corr a or Corr b key to be input.

The screen for inputting the setting value appears.




[mm] Corra

5,000000 = 10,000000

Meas 8 [mm] Corr b [mm] -5,000000 - -10,000000

Meas A


2 Input the setting value (1), then, touch the wey (2) to confirm the setting.



**3** Touch the Return key to return to the step1 screen.


# For loading the measurement value from the current value


Touch the Load key.
 The screen for loading the measurement value appears.











## **O**CHECK

The setting contents of the output selection for OUT setting are reflected in the current value. Set OUT1 to "A" and OUT2 to "B" for the output selection.


# 4

## ■Peak Recognition Sensitivity

This function sets the peak of the received light waveform and the peak recognition level.



This function is effective when you cannot acquire the measurement value properly due to waveform instability.



## **O**CHECK

Setting range is 100 to 400. The initial value is set to 100.

- How to use
  - 1 Display the "Peak Recog. Sens." Screen.

Selection screen of sensor head A


Peak recog. sens. Head A								Тор
100							Menu	
1	2	3	4	5	*	ES	ÇL R	
6	7	8	9	0	$\Box$	BS	Ļ	■

<del>+</del> +

#### Selection screen of sensor head B

ſ	Peakrecog. sens. Head B								Тор
	100								Menu
I	1	2	3	4	5	*	ES	ÇL R	
ı	6	7	8	9	0	П	B <sub>S</sub>	Ţ	•

- **2** Set the peak recognition sensitivity.
  - (1) Touch the Head A (Head B) key to make the numerical value input possible.
  - (2) Input the numerical value.
  - (3) Touch the [4] key to confirm the value.




## ■Median Filter

Cut off changes in measurement values in order to prevent variation in measurement.

The setting of median filter can be selected from "OFF", "7 points", "15 points" and "31 points".

Median filter is effective to cut off sudden changes in measurement values.






## TECHNIQUE


This makes it possible to cut off spike values, while maintaining the measurement of steps and edges in measured shapes.

### O CHECK

- · When the sampling cycle is set to 10 µs or 20 µs, set the median filter to "OFF". An alarm is issued if a setting other than "OFF" is selected.
- How to use
  - 1 Display the "Median Filter" screen.



2 Switch between different settings of median filter by touching the ▲ ▼ keys. Settings are switched every time you touch the keys.



Head B

OFF

Тор

Menu

4

# 4-3-2 OUT Setting

## Output Selection

This function selects the output pattern of measurement values.

The below list shows the setting items and the output details.


Setting item	Function					
Α	Outputs the measurement value of the sensor head A.					
В	Outputs the measurement value of the sensor head B.					
-A	Outputs the measurement value of the sensor head A with putting a negative sign.					
-B	Outputs the measurement value of the sensor head B with putting a negative sign.					
A+B	Adds the measurement values of the sensor heads A&B and outputs the value.					
-(A+B)	Adds the measurement values of the sensor heads A&B and outputs the value with putting a negative sign.					
A-B	Subtracts the measurement value of the sensor head B from that of sensor head A and outputs the value.					
B-A	Subtracts the measurement value of the sensor head A from that of sensor head B and outputs the value.					
A Tr	Outputs the measurement value of a transparent object by using the sensor head A.					
B Tr	Outputs the measurement value of a transparent object by using the sensor head B.					
-A Tr	Outputs the measurement value of transparent object A with putting a negative sign.					
-B Tr	Outputs the measurement value of transparent object B with putting a negative sign.					
A1+B1[Tr]	Adds the measurement values of 1st surface of a transparent object measured by the sensor head A & B and outputs the value.					
-(A1+B1)[Tr]	Adds the measurement values of 1st surface of a transparent object measured by the sensor head A & B and outputs the value with putting a negative sign.					
A1-B1[Tr]	Subtracts the measurement value (1st surface of a transparent object) of the sensor head B from the measurement value (1st surface of a transparent object) of the sensor head A and outputs the value.					
B1-A1[Tr]	Subtracts the measurement value (1st surface of a transparent object) of the sensor head A from the measurement value (1st surface of a transparent object) of the sensor head B and outputs the value.					

## OCHECK

- Before measuring a transparent object, set "A Tr", "B Tr", "-A Tr", "-B Tr", "A1+B1[Tr]", "-(A1+B1)[Tr]", "A1-B1[Tr]", or "B1-A1[Tr]". In this case, set the "Installation Mode" to the specular reflection. (Note that the mounting method of the sensor head is different between specular and diffuse reflection. Also, set the "Measurement Surface Reference" and "Transparent Object". If not doing so, the measurement is executed up to the front surface of a transparent object from the sensor head. Set the recommended measurement mode for specular reflection.
- The settings of -A, -B, -(A+B), -A Tr, -B Tr, or -(A1+B1)[Tr] is reflected in all outputs such as the measurement value display and analog output.

- · How to use
  - 1 Display the "Output Selection" screen.


Selection screen of OUT1



2 Touch the ▲▼ key (1) to change the list display.

The list display is changed each time the key is touched.

3 Touch your desired key (2) for performing "Output Selection".



Тор


## ■ Transparent Object

This function selects a measurement surface from several surfaces in a transparent object.

According to the setting of "measurement surface reference", select a measurement surface in a transparent object. Single or several surfaces can be selected from 1st to the maximum surface. (Refer to the example of the next page.)

#### Supplemental remarks

• This function is valid when A Tr, B Tr, -A Tr, or -B Tr is selected at the "Output Selection". (If one of the above is not selected, the setting screen of this function does not appear.)




#### \*Maximum seven surfaces can be detected.

### O CHECK


- · Set the "Installation Mode" to the specular reflection. (Note that the mounting method of the sensor head is different between specular and diffuse reflection.)
- · Before measuring a transparent object, make sure to set the recommended measurement mode for specular reflection.
- · For selecting a measurement surface, confirm the setting of "Measurement Surface Reference". The measurement surface is changed by setting the measurement surface reference. If the setting is wrong, the measurement cannot be performed accurately.

- How to use
  - 1 Display the "Output Selection" screen.
    Selection screen of OUT1



Output Selection OUT1


- 2 Touch the ▲▼ key to select your setting of "Output Selection".
  - →"■ Output Selection"
- **3** Touch the ♠ key to change the screen for selecting the measurement surface of "Transparent Object".
  - \*The setting of the transparent object can be performed only when "A", "-A", "B", or "-B" of [Transparent Object] is selected at the "Output Selection".



**4** Touch the ▲ ▼ key to change the setting. The setting is changed each time the key is touched.



Ex When "Near setting" is set at the "Measurement Surface Reference", select the measurement surface referring the below figure.



#### Refractive Index Calculation

This function reflects the setting refractive index to the measurement result.


When the "Refractive Index Calculation" function is set to "ON" for measuring a transparent object, the setting refractive index becomes effective and it is reflected in the measurement result. For measuring the thickness of a transparent object, set the function to "ON", for measuring the clearance of a transparent object, set it to "OFF". When the function is set to "OFF", the setting refractive index is not reflected in the measurement result.

#### Supplemental remarks

The setting of the transparent object can be performed only when "A", "-A", "B", or "-B" of [Transparent Object] is selected at the "Output Selection".

#### O CHECK

- · Set the "Installation Mode" to the specular reflection. (Note that the mounting method of the sensor head is different between specular and diffuse reflection.)
- · When a single surface (1st, 2nd, 3rd, 4th, Max surface) is selected, the function is invalid even if the function is set to "ON".




#### How to use

## 1 Display the "Output Selection" screen.


Selection screen of OUT1










- 2 Touch the ▲▼ key to change the setting and select the key of your choice.
  - →" Output Selection"
- 3 Touch the ♠ key to change the screen for selecting a measurement surface of "Transparent Object".
  - \*The setting of the transparent object is valid only when "Transparent Object" is selected at the "Output Selection".














#### Refractive Index

This function is used for setting the refractive index of a transparent object to be measured.

Sets the refractive index of the measurement object. The setting range is 0.500000 to 2.000000. "1.000000" is set as a default.



#### Supplemental remarks

- · This function is valid when "A Tr", "B Tr", "-A Tr", or "-B Tr" is selected at the "Output Selection" and "several surfaces" (1st-2nd, 1st-3rd, 1st-4th, 1st-Max", 2nd-3rd, 2nd-4th, 2nd-Max, 3rd-4th, 3rd-Max, 4th-Max) is selected at the "Transparent Object".
- · The setting screen appears when "Reflective Index Calculation" is set to "ON".

#### O CHECK

Set the "Installation Mode" to the specular reflection. (Note that the mounting method of the sensor head is different between specular and diffuse reflection.

•


#### How to use

1 Display the "Output Selection" screen.

Selection screen of OUT1










- 2 Touch the ▲▼ key to change the setting and select the key of your choice.
  - →"
     Output Selection"
- 3 Touch the key to change the screen for selecting a measurement surface of "Transparent Object".
  - \*The setting of the transparent object is valid only when "Transparent Object" is selected at the "Output Selection".
- 4 Changes the setting by touching ▲ ▼ key of "Tr Obj".

The setting changes by touching the key.












5 Touch the "Refractive Index Calculation" key to change the setting to ON.




**6** Touch the **■** key to change the screen for setting "Refractive Index".



**7** Touch OUT1 (or OUT2) key to input the setting value.







## **OCHECK**

Note that it will take much time to set the "refractive index".

# 4

### ■ Zero Set

This function is used for forcibly setting the measurement value to "0".

Normally, the amount of displacement is displayed in reference to the center of measurement of the sensor head. However, after this function is set to "ON", the amount of displacement is displayed in reference to the position when the function is set to "ON".

## TECHNIQUE


Use this function to reset the measurement value of a reference object to "0" and measure the displacement amount or make "Judgment Output".

#### Supplemental remarks

The zero set function can be set to "ON/OFF" by using the zero set terminals (ZS1, ZS2) of the external input terminal. →"2-1 Functions and Arrangement of I/O Terminal Block"

The zero set terminals have both "zero set ON" and "zero set OFF" functions.

- When the zero set terminal is set to "ON" (short-circuited)\*, the zero set function is set to "ON". Keeping the zero set "ON" status for longer than 1 sec, then, 1 second later, the zero set is set to "OFF" status. (Thus, to set the zero set to "OFF", set the zero set to "ON" at first.)
- When repeating the zero set "ON" input, the zero set function is also repeated.



- \*More than the setting time of chattering prevention is necessary.
  - → "Chattering prevention of the terminal input"

#### CHECK

Note that the judgment output may be changed once because the zero set is set to "ON" immediately after the "zero set" is released by the external input terminal.


Ensure that the offset value remains after the zero set is released in case that the "Offset" is set to "ON".

During an alarm occurrence, zero set cannot be set to ON.


#### How to use

1 Display the "OUT1 (or OUT2) operation" screen.

Setting screen of O	UT1	Setting s
Meas OUT1 (A) mm	Top	Meas OuT2
123.45678	Menu 👍	123.
□ 4L □ HI Hold Timing	Wave	
☐ST ☐LO Zero Sett Reset	•	<b>□</b> sī <b>□</b> ū



2 Touch the Zero Set key to set the measurement value to "0".





Zero set "OFF"



Zero set "ON"

3 Touch the Zero Set key again to return to the measurement reference position to the center of measurement (default) by zero set function.

## ■ Timing

The measurement value can be on hold at the desired timing. The measurement value is on hold by the timing terminal (TM1, TM2) of the external terminal input or by pressing the timing input button of compact programmable display. The judgment output is also on hold simultaneously. For the details, refer to  $\rightarrow$  "Timing Chart".

## TECHNIQUE

"Judgment Output" is on hold by setting the timing input to "ON" at the desired timing. This enables loading of the judgment result at a later time.

#### N Supplemental remarks


- Timing input cannot be controlled by the compact programmable display while it is set to "ON" by the external terminal input. The external terminal input has higher priority than the compact programmable display. Even when the timing input is set by both of them simultaneously, the setting of the external terminal input overrides the compact programmable display.
- While the timing input is set to "ON" by the external terminal input, the function cannot be set to "OFF" by pressing the timing input button of compact programmable display and the button display of compact programmable display is forcibly returned to "OFF". Moreover, even when the function is set to "OFF" by the external terminal input while the timing input is set to "ON" by pressing the timing input button of compact programmable display, the button display of compact programmable display is forcibly returned to "OFF".

#### **OCHECK**

The timing input status cannot be stored even by executing "Save" function.

- How to use
  - 1 Display the "OUT1 (or OUT2) operation" screen.






**2** Touch the <u>Timing</u> key to hold the judgment output and measurement value.



Timing input is released.



Timing input is executed.

3 Touch the Timing key again to release the timing input.

#### Reset

This function resets the measurement value.

The measurement value can be reset by touching the "Reset" button. When executing the "Peak measurement", "Bottom measurement", or "Peak to Peak measurement", the measurement value that has been on hold can be reset at the desired timing.

The measurement value display of compact programmable display is turned to the data unfixed status by executing "Reset" function, and the fixed value(-999.99999), the setting fixed value for analog output (default: "-10.800[V]"), and the judgment output are all turned to "OFF". For the details, refer to  $\Rightarrow$  "Timing Chart".



#### Supplemental remarks

- · The measurement value can be also reset by the reset terminal (RS1, RS2) of the external input terminal.
  - → "2-1 Functions and Arrangement of I/O Terminal Block"

# TECHNIQUE

When the reset input is set to "ON", the "Judgment Output" is set to "OFF". This function is effective to perform judgment for each measurement object at Peak, Bottom, and Peak to Peak measurements.

#### How to use

1 Display the "OUT1 (or OUT2) operation" screen.

Selection screen of OUT						
<u>Meas</u>	OUT1	Тор				
	2. 0	Menu				
	밀빖	Hold	Timing	Wave		
□ST	80	Zero Set	Reset	•		




2 Touch the Reset key.

Touching the Reset key sets the temporary data unfixed status, and the display value of compact programmable display and analog output value are fixed.







Reset in progress

\* When the reset function is set to "ON", the right screen appears temporarily, and immediately after that, the left screen appears and the setting is released. After the completion of reset, the measurement value is displayed after a fixed duration passed.

# ■ Hold

This function stops the updating of the measurement value display.

The updating of the measurement value display is stopped by touching the Hold button on the compact programmable display. This is a function only available for compact programmable display.

# TECHNIQUE


The instantaneous measurement value can be read at the compact programmable display by locking the updating of the measurement value display at the desired timing.


### **OCHECK**

- This function does not hold the measurement display of the analog output, judgment output, alarm output, and Intelligent Monitor AiM.
- The hold function for the analog output, judgment output, and alarm output on the external terminal I/O shall be controlled by "Timing" function.
- The "Hold" status of compact programmable display is not stored even by executing "Save" function.

### How to use

1 Display the "OUT1 (or OUT2) operation" screen.






**2** Touch the Hold key to hold the measurement value.



"Hold" is released.




"Hold" in progress

3 Touch the Hold key again to release the hold input.

# Analysis Mode

This function performs the setting of the analysis mode.


The below shows the function of each analysis mode.






Peak to Peak can be used for the vibration or eccentricity measurement.


- How to use
  - 1 Display the "Analysis Mode" screen.



2 Touch the ▲▼ key to change the analysis mode.

The key display is changed in the below order each time the **\( \)** key is touched. Touching the **\( \)** key switches the analysis mode reversely.





# ■ Filter Operation

This function cuts the unnecessary signal element to stabilize the measurement data.

The filter operation is selectable from the moving average, low-pass filter, and high-pass filter. The filter picks out the measurement data for required amount of frequency, cuts the unnecessary signal element, then, acquires the stabilized measurement value.


### Filter setting

### Moving average

Performs moving average on the measurement result for the setting average times.

### Low-pass filter

Select Low-pass filter when you want to pick out only the signal with low frequency from the measurement data. The signal elements lower than the setting cutoff frequency are picked out.



### TECHNIQUE

Low-pass filter is able to measure the stabilized displacement by minimizing noise that might occur depending on the metal surface condition.

# **High-pass filter**

Select High-pass filter when you want to pick out only the signal with high frequency from the measurement data. The signal elements higher than the setting cutoff frequency are picked out.



# TE

### TECHNIQUE

High-pass filter is effective for detecting a joint line or slot of objects such as the eccentricity of a revolving object under a state of largely vibration or inclination since the influence of gradual change is minimized.

### Average Times

Sets the average times for performing the moving average. This is used for stabilizing the unstable (including variation) measurement value. This becomes valid when "Moving Average" is selected.


### Cutoff Frequency


Sets the cutoff frequency for Low-pass filter and High-pass filter. This becomes valid when "Low-pass Filter" or "High-pass Filter" is selected. For stability of filter effectiveness, set the value to below than 1/2 of the "Sampling Cycle" setting value. For setting of the "Sampling Cycle", refer to

→ "4-3-3 Common Setting" - "Sampling Cycle".


# **OCHECK**


- Make sure to perform the actual measurement and confirm the results before setting the cutoff frequency because of the different conditions.
- How to use
  - 1 Display the "Filter Operation" screen.





**2** Touch the "Filter Selection" key to select the desired filter.







Setting of the average times:

a counterclockwise direction.

Touch the ▲▼ key of "Average Times" to select the desired average times.


The display changes as below by touching the 
▲ key. Touching the ▼ key changes in







Setting of Low-pass/High-pass filter:

**3** Touch the ▲▼ key of "Cutoff Frequency" to select the desired cutoff frequency.








# 4

# **■**Operation Coefficient

This function is used for multiplying the measurement value by the operation coefficient and outputting the data.

Final measurement value = Operation coefficient x Measurement value + Offset value



### How to use

1 Display "Ope. Coef." Screen.


Selection screen of OUT1

Эре	9. CC	ef.		OUT	1			Тор	
		1	. 0	00	oc	00	О	Menu	•
1	2	3	4	5	*	ES	CE E		4
6	7	8	9	0	$\Box$	BS	Ļ	•	
	Јре 1 6	1 2 6 7	0pe. coef. 1 1 2 3 6 7 8					1 2 3 4 5 ½ % % 6 7 8 9 0	

### Selection screen of OUT2



- 2 Set the operation coefficient.
  - (1) Touch the OUT1 (OUT2) key to make the numerical value input possible.
  - (2) Input the numerical value.
  - (3) Touch the [4] key to confirm the value.



# Offset

The desired setting value can be added to/subtracted from the measurement value.



Set the offset value by measuring the size of a master (reference) measurement object. When measuring an object, set the Zero Set "ON" so that the judgment of the size tolerance can be performed easily because of the combination of the zero set and judgment output functions.

# **O**CHECK

- · Set "Offset" and set "Zero Set" to "ON" to make the setting value offset value.
- · The display limit of the measurement value is  $\pm 950.000000$ mm. Be sure to set the offset value within the range.
- How to use
- 1 Display the "Offset" screen.


Selection screen of OUT1

Тор	nm	1	T1	OU.			<u>set</u>	Offs
Menu	0	0 (	0 0	0 (	. (	0		
	ÇL R	ES	½	5	4	3	2	1
•	Ļ	B <sub>S</sub>	$\lceil \cdot \rceil$	0	9	8	7	6


### Selection screen of OUT2


Тор	nm	1	Τ2	OU.			et	Offs
Menu	0	0	o c	0	C	Ο.		
	gL R	ES	½	5	4	3	2	1
•	Ţ	B <sub>S</sub>	$\Box$	0	9	8	7	6

Touch the OUT1 (or OUT2) key to prepare for inputting the setting value.



3 Set the setting value by the numeric keys. The input range is -950.000000 to +950.000000[mm].





# ■ Upper/Lower Limit Value of Judgment Output


This function sets the upper and lower limit values for judgment of the measurement value.

The output status changes in three types as the below:

measurement value > upper limit value: HI Output

lower limit value  $\leq$  measurement value  $\leq$  Upper limit value: GO Output

measurement value < lower limit value : LO Output



# Supplemental remarks

- The input range of both upper/lower limit values is -950.000000 to +950.000000[mm].
- The initial value of the upper limit value is the positive upper limit of the measurement range.

The initial value of the lower limit value is the negative lower limit of the measurement range.


# OCHECK

Make sure that the upper limit value is higher than the lower limit value.


### How to use

1 Display the "Up Lmt Val" screen.

36	Selection screen of OoT I								
Up	Up Lmt Val OUT1 mm						nm	Тор	]
	5. 000000					Menu	]		
1	2	3	4	5	*	ES	ÇL R	₩	1
6	7	8	9	0	⊡	B <sub>S</sub>	Ļ	•	•




2 Touch the keys to change the screen between "Up Lmt Val" and "Lo Lmt Val".



- Touch the OUT1 (or OUT2) key to prepare for inputting the setting value.
- **4** Set the setting value by touching the numeric keys.

The input range is -950.000000 to +950.000000[mm].

5 Touch the key to confirm the offset value.




# ■ Upper/Lower Hysteresis of Judgment Output

This function stabilizes the judgment output against the chattering of the measurement value.

The below example graphically shows the correlation between the hysteresis value and ON/OFF of the output. The function acts on the upper/lower limit values when the output is in "ON" status.

# Ex In case of GO output



# TECHNIQUE

In case that the measurement value fluctuates around the upper/lower limit value of the judgment output, the output repeats "ON/OFF" status. This may cause the unstable judgment output.

In this case, set the upper/lower limit hysteresis to prevent such chattering.


# Supplemental remarks


The input range of both upper/lower limit hysteresis values is +000.000000 to +950.000000 [mm].

# CHECK


After setting the operating condition, make sure to check a rough deviation of the measurement value at P-P before setting the hysteresis value because the deviation differs depending on measurement object and setting of "Average Times". Set the upper/lower limit hysteresis smaller than the upper/lower limit value of judgment output.


- How to use
  - 1 Display the "Up Limt Hys" screen.





- 2 Touch the **\|** keys to change the screen between "Up Lmt Hys" and "Lo Lmt Hys".
- 3 Touch the OUT1 (or OUT2) key to prepare for inputting the setting value.






**4** Set the setting value by touching the numeric keys.

The input range is +000.000000 to +950.000000[mm].

**5** Touch the key to confirm the offset value.




# Analog Scaling

This function executes scaling of the analog voltage output to a desired value.

The system performs scaling of the analog voltage output to the desired value within  $\pm 10$ V.

Fix two points of the desired voltages to "a" and "b" for each A and B of the current voltage. Input the current measurement value as the value "A", and input the desired voltage as the value "a". Also, set the value "B2 and "b" in the same manner. Then, the analog voltage output can be scaled easily.



### Supplemental remarks

- · The input range of both measurement value A and B is -950.000000 to +950.000000 [mm], and that of both voltage a and b is -10.000 to +10.000 [V].
- The initial value of the measurement A is positive upper limit value of the measurement range and that of the measurement B is negative lower limit value of the measurement range, that of the voltage a is +5.000[V], and that of the voltage b is -5.000[V].
- The display limit of the measurement value is ±950.00000mm. Make sure that the setting value does not exceed the display limit.

# 

- The analog current output interlocks the setting of the analog voltage output. (The voltage and current cannot be set individually.) The default is set to 4mA at -5.000[V], 20mA at +5.000[V]. → "8-6 Characteristics" "Output Characteristics and Measurement range Indicator"
- · Check the input range of your input device such as AD board before setting.


### How to use

1 Display the "Analog Scaling" screen.

Selection	n so	creen	of C	UT1
Analog Sca	ling	OUT1		Тор
Mono A	, ,	Malt a	f. a	


Analog Scali	ng	OUT1		Тор
Meas A	[mm]	Volt a	[v]	Menu
5.000000	-	5.000		Change
Meas B	[mm]	Volt b	[v]	Change
-5.000000	=	-5.000		•







Selection screen of OUT2

2 Touch the Change key. The screen is changed.




3 Change the screen by each key.





- →For inputting the measurement value or voltage value
- →For loading the measurement value from the current value
- 4 Set/change the measurement value or voltage value. For input method of the measurement value and voltage value, refer to →"For inputting the measurement value or voltage value", and For loading method of the measurement value, refer to →"For loading the measurement value from the current value".
- **5** Touch the Execute key.

  Touch the Cancel key to cancel inputting.



5.000

[v]

Change

Execution of the analog scaling function starts with the setting value.

In case that the setting value is invalid, the right screen appears. Touch the OK key and confirm the setting value, then, execute again.

After the completion of setting, the screen of step 1 appears again.



[mm] Volt b


2.500000 =

Meas B


# For inputting the measurement value and voltage

1 Touch the key you want inputting the value.


Touch the Meas A, Meas B, Volt a, or Volt b key. The screen changes.



**2** Touch the OUT1 (or OUT2) key to prepare for inputting the setting value.



3 Input the value (1), and touch the [4] key to confirm the value.




For returning the above step 5, touch the Return key.

### For loading the measurement value from the current value

1 Touch the key you want to load the value.


Touch the Load key of the measurement value

A or B. The screen is changed.



**2** Touch the Load Meas Val A from Curr val. key. The current value is input at the up side of the measurement value.

For returning the above step 5, touch the



4-47

# ■ Analog Output at Alarm

This function sets the analog output status when an alarm is issued.

It can select whether holding the previous value or setting a fixed value for the analog output under an alarm operation status (poor light intensity, or measurement disabled when a target object goes off the measurement range).

# Supplemental remarks


- · The input range of fixed value is -10.800 to +10.800[V], and the initial value is +10.800[V].
- The current output varies on load impedance. The maximum value is 25.0[mA].

### **OCHECK**

- · Check the input range of AD board before setting.
- · Before setting of analog output at alarm, read → "4-4-1 Alarm Setting and Outputs" carefully.

### How to use

1 Display the "Analog Output at Alarm" screen.








Touch the "Analog Output at Alarm" key.
The display is changed between


Hold Pre Val and Fixed Value each time the key is touched.




# When selecting "Fixed Value"

3 Touch the ▶ key.

The screen for inputting the fixed value appears.



- 4 Input the fixed value.
  - (1) Touch the OUT1 (or OUT2) key to prepare for inputting the setting value.
  - (2) Input the value.
  - (3) Touch the [4] key to confirm the value.



# Analog Output at Data Unfixed

This function sets the analog output when the data is unfixed.

"-999.99999" is displayed for the measurement value of the digital output at data unfixed and AiM.

### **OCHECK**

- The output range is -10.800 to +10.800[V], and the initial value is -10.800[V].
- · The analog current output interlocks this setting.
- The current output varies with load impedance. The maximum value is 25.0[mA].
- · Setting of the voltage and current cannot be performed individually.
- · Check the input range of AD board before setting.
- Before setting of analog output at data unfixed, carefully read → "4-4-2 Conditions When Output Data becomes Unfixed.".

### How to use

1 Display the "Analog O/P at Data Unfixed" screen.

| Selection screen of OUT1 | Analog O/P at Data Unfixed | OUT1 | Top | Fixed Val - 1 O . 8 O O v | Menu | 1 2 3 4 5 2 8 8 4

Selection screen of OUT2


Analog O/P at Data Unfixed OUT2 Top

•

•



- 2 Input the fixed value.
  - (1) Touch the OUT1 (or OUT2) key to prepare for inputting the setting value.
  - (2) Input the value.
  - (3) Touch the [4] key to confirm the value.



# ■ Digital Output at Alarm

This function sets the digital output status when an alarm is issued.

It can select whether holding the previous value or setting a fixed value for the digital output (measurement value display of compact programmable display and the judgment output Intelligent Monitor AiM) under an alarm operation status (poor light intensity, or measurement disabled when the target object goes off the measurement range). When selecting the fixed value, the digital data is displayed "+999.99999". When selecting the "Hold the Previous Value", the hold value is displayed.

# TECHNIQUE

Selecting the fixed value can detect an alarm issued status easily from the measurement result. Especially this function is effective in that an alarm status can be confirmed when the measurement value is loaded by performing the data buffering function.

# Supplemental remarks

"Hold Previous value" is set as a default.

# O CHECK


- · In case of selecting the fixed value, the judgment output is on hold at "HI" by interlocking with the digital output when an alarm is issued.
- · For setting of the digital output at alarm, read **→**"4-4-1 Alarm Setting and Outputs" carefully.

•

- How to use
  - 1 Display the "Digital Output at Alarm" screen.

Selection screen of OUT1









**2** Change the setting of the digital output status when an alarm is issued.

Touch the "Digital Output at Alarm" key. The display is changed between





# Alarm Output Delay

This function delays the output from the alarm terminal.

It can select whether outputting at a real time or holding the previous normal value up to the setting number of times under an alarm operation status (poor light intensity, or measurement disabled due to deviation from the range).

# TECHNIQUE


Even loading the measurement value ignoring the alarm status for the setting number of times (set at "Alarm Delay") since you do not want to reflect the alarm status to the measurement value, the alarm occurrence status from the alarm terminal can be checked by setting "Alarm Output Delay" to "OFF".

### **OCHECK**

- · When this setting is "OFF", in regardless with the setting of number of alarm delay times, the alarm status is output to the alarm output terminal at a real time.
- · For setting of "Alarm Output Delay", read → "4-4-1 Alarm Setting and Outputs" carefully.


### · How to use

1 Display the "Alarm Output Delay" screen.






•





**2** Change the setting of the output delay at alarm.

The display is changed between ON and OFF each time the key is touched.



# ■ Digit Number of Measurement Value

This function sets the display digit number of the measurement value.

It can set the display of the number of decimal places on compact programmable display. The display of the number of decimal places can be selected among six settings: 6digits/5digits/4digits/3digits/2digits/1digit. When omitting the number of decimal places, round off the value.


### **OCHECK**

- "Digit Number of Measurement Value" can be set at "OUT1", "OUT2", and "Measurement Value" menu screens. The same performance is done in either setting.
- The measurement value display of AiM interlocks with this setting.
- How to use

Setting at "OUT1" or "OUT2" menu

1 Display the "Digit No of Meas Val" screen. Setting screen of OUT1








**2** Touch the ▲▼ key of "Digit No of Meas Val" to change the setting.

The number of digits display is changed as below by touching the vector key. Also, it is changed in counterclockwise by touching the key.





### Setting at "Measurement Value" menu


1 Display the "Digit No of Meas Val" screen.



2 Touch the ▲▼ key of "Digit No of Meas Val" to change the setting.

The number of digits display is changed as below by touching the ▼ key. Also, it is changed in counterclockwise by touching the ▲ key.





# 4-3-3 Common Setting

# Sampling Period

This function sets the sampling cycle of measurement.

# TECHNIQUE

When measuring an object with poor received light intensity such as black rubber, extend the sampling cycle to get sufficient light for performing stable measurement.

Cycle [µs]	Frequency	Measurement range	Meas. object
10µs	100KHz	Differs depending on	Bright
20µs	50KHz	product type	7
40 µs	25KHz		object
100µs	10KHz		s of e
200µs	5KHz	All in the	S S
400µs	2.5KHz	measurement range	Brightne
1ms	1KHz		Δ
2ms	500Hz		Dark

<sup>\*</sup>The measurement range may become narrow depending on measurement object type.

# **OCHECK**

- •When the sampling cycle is set to 10  $\mu s$  or 20  $\mu s$ , the measurement range is limited.
- •When the sampling cycle is set to 10  $\mu s$  or 20  $\mu s$ , the functions of median filter are limited.

As for the functions of median filter, refer to "4-3-1 Head Setting" - 'Median Filter'.

# Ex In case of HL-C203B

In case of setting the installation mode to "diffuse reflection", the measurement range is 3.8 to 5.0[mm] for the sampling cycle  $10\,\mu s$ , 0 to 5.0[mm] for the  $20\,\mu s$ , or  $\pm 5 \text{mm}$  for the other cycles. For the setting range for each product type, refer to "8-2 Sensor Head Specifications".


- If the sampling cycle is changed, the data unfixed status occurs because the sampling sequence is executed again. When the data becomes unfixed, the strobe output is set to "OFF", and after the data become fixed, the strobe output is set to "ON" and the measurement data display starts.
- The resolution of the received light intensity waveform is also limited.

- How to use
  - 1 Display the "Sampling Cycle" screen.



2 Touch the ▲▼ keys of Sampling Cycle to change the setting.

The sampling cycle display is changed as below by touching the  $\boxed{\blacktriangledown}$  key. Also, it is changed in counterclockwise by touching the  $\boxed{\blacktriangle}$  key.





# ■ Terminal Input Control

Using this function, two outputs (OUT1 & OUT2) can be controlled by one input operation.

Two outputs (OUT1 & OUT2) can be operated by inputting only OUT1 (the timing input, zero set input, and reset input).

# TECHNIQUE

Select "All" to control the two sensor heads at the same timing, e.g. when checking the inclination of a measurement object. This can minimize the deviation caused by control signals input from terminal.


# **OCHECK**

When "All" is set, the operation can be performed only from OUT1. Note that OUT2 becomes invalid in this case.

- How to use
  - 1 Display the "Terminal Input Control" screen.
  - 2 Touch the "Terminal Input Control" key to change the setting Independent or All.

    The setting display is changed between Independent and All each time the key is touched.






# ■ Chattering Prevention of Terminal Input

This function can prevent the chattering of the terminal input.

This function is used to prevent chattering for terminal input using the relay contact or switch contact. The below list shows three settings of the function.

Setting	Function	
OFF	Continuous input of longer than 50µs	
ON1	Continuous input of longer than 20ms	
ON2	Continuous input of longer than 100ms	





When acted in level, the chattering prevention functions while input is OFF.

# **OCHECK**

Only "ON2" is used for the laser emission stop input, remote interlock input, and memory change input to prevent misoperation.

- How to use
  - 1 Display the "Chattering Prev for Term I/P" screen.
  - 2 Touch the "Chattering Prevention for Terminal Input" key to select the setting. The display is changed as below each time the key is touched.








# ■Judgment Output Off Delay


This function is used for delaying the timing of switching OFF from ON of judgment output.

# TECHN I QUE

This function is effective for loading quickly fluctuated output into a sequencer, etc.

Setting	Function
OFF	Output corresponding with a sampling cycle
2ms	Off delay for 2ms
10ms	Off delay for 10ms
100ms	Off delay for 100ms
Hold	Hold when once turned ON. Reset input to release it.






# **O**CHECK


- When the actual terminal output operation is faster than the off delay setting time, the off delay time becomes effective from the last turning OFF point.
- How to use
  - 1 Display the "Judg. O/P OFF Delay" screen.



2 Touch the "Judgment Output OFF Delay" key to select the setting.

The display is changed as below each time the key is touched.





### ■Interference Prevention

This function is used for preventing interference between 2 sensor heads.

Set this function when beam from the other sensor head enters into the mutual interference area.

→ "8-6 Characteristics" – "Mutual Interference Area"

# TECHNIQUE

When connecting two sensor heads, there is the case that one sensor head receives beam from the other sensor head, and this might cause a measurement error if the setting distance between the two sensor heads is close. In this case, by setting the Interference Prevention function to ON, two sensor heads emit beam in turn and are not susceptible to the interference of the other sensor head. The data update increases twice of the setting sampling cycle.

# **OCHECK**


In case of connecting one sensor head, sampling cycle doubles when this function is set to ON. Make sure to set this function to OFF when one sensor head is connected.

- How to use
  - 1 Display "Interference Prevention" screen.



**2** Switch the setting of interference prevention.

The display is switched ON and OFF each time the "Interference Prevention" key is touched.



# 4-3-4 System Setting

# ■ Display Update Cycle of Measurement Value

This function sets the display update cycle of the measurement value on the compact programmable display.

Set the display update cycle to slower (longer) as possible because fast (short) display update cycle causes the measurement value display hard-to-read due to quickly change in the measurement value.

Setting	Function
Fast	Updates at each sampling cycle.*
Standard	Updates at each approx. 0.3ms.
Slow	Updates at each approx. 500ms.
Very slow	Updates at each approx. 1000ms.

<sup>\*</sup>Note that the limitation of programmable display speed is applied to this cycle.

This setting is applied to the measurement value display of compact programmable display, alarm output, strobe output, and judgment output.

Terminal outputs (analog output, alarm output, strobe output, judgment output) are updated at every sampling cycle.


### CHECK

"Display Update Cycle of Measurement Value" can be set at either of "System" menu or "Measurement Value" menu. Setting at either of them is reflected in another menu setting.

### How to use

# Setting at "System" menu

1 Display "Update Cycle of Meas Val" screen.




System

2 Touch the "Update Cycle of Meas Val" key to select the setting.

The display is changed as below each time the key is touched.



Update Cycle of Meas Val



### Setting at "Measurement Value" menu

1 Display "Update Cycle of Meas Val" screen.



Standard

Update Cycle of Meas Val

Display Update
Cycle of Meas Val

**2** Touch the "Update Cycle of Meas Val" key to select the setting.

The display is changed as below each time the key is touched.



**3** Touch ♠ key to return to the "Measurement Value Display" screen.



# ■Change Indication Unit

This function is used for changing the indication unit of the measurement value on compact programmable display.


The indication unit of the measurement value is selectable from mm unit and  $\mu m$  unit.

# **O**CHECK

- •This function is invalid for the setting value indication. The setting value is always indicated in mm unit.
- •When selecting µm unit, the setting of "Digit Number of Measurement Value" becomes invalid.

#### How to use


1 Display "Change Indi. Unit" screen.



2 Switch the setting of Indication Unit.

The display is switched mm Unit and

um Unit each time the "Indication Unit" key is touched.



# ■Output Setting Copy


"OUT Setting" contents can be copied between OUT1 and OUT2.

The setting contents related to the memory output that is specified at "Memory Change" function can be copied between OUT1 and OUT2 (OUT1→OUT2, OUT2→OUT1).


# **OCHECK**

This function cannot copy the timing, reset, and hold outputs.

- How to use
  - 1 Display the "Copy O/P Setting" screen.



Touch the CopyOutput 1 to Output 2 key or CopyOutput 2 to Output 1 key.




**3** The confirmation screen appears.

Touch the Yes key to copy, or touch the No to display the Step 1 screen.



**4** The screen of notifying the completion of copy appears.

Touch the OK key to return to the "System Menu 1/2".



# ■ Priority Setting of Memory Change


This function sets priorities among command or terminal memory changes.

In case that the command is received a higher priority for memory change, memory change by the terminal is ignored (set the priority to "Terminal" before performing memory change from the terminal).

In case that the terminal is received a higher priority for memory change, the memory change by command is ignored (set the priority to "Command" before performing memory change by command).


#### How to use

1 Display the "Priority of Mem Chg" screen.



2 Touch the "Priority Setting of Memory Change" key to change the setting between Command and Terminal.

The display is changed between Command and Terminal each time the key is touched.



# ■ Memory Change

This function specifies the destination (memory) for storing the setting contents.

When starting up the system with the specified memory No. (other than the default setting), set the priority to command or terminal as below.

"Priority Setting of Memory Change"	Function operation at start-up
	Starts-up the system with the last specified memory No. at the memory change function.
Terminal priority	Starts-up the system with the memory No. that is input by terminal.


# **OCHECK**

- Even the memory change is set in the system operation, the setting cannot be reflected (memory change is not executed) until memory change is executed in the next start-up.
- · When the memory change is executed, the data unfixed status may occur temporarily. At data unfixed status, the strobe output is set to "OFF", and after the data become fixed, the strobe output is set to "ON" and the measurement data display starts.
- Note that the setting contents are deleted at the next start-up if the memory change setting is not saved.


### How to use

1 Display the "Memory Change" screen.





2 Press the selection memory No. button. The default is set to No.0.





**↑** 

# Memory Copy

The stored contents in the memory can be copied to the other memories.

If the destination and source memory is the same, the data in the memory is just overwritten.

# **O**CHECK

· Note that the copied setting contents are deleted at the next start-up if the copied setting content are not saved.

### How to use


1 Display the "Memory Copy" screen.




- 2 Select the copy source No. (0 to 15).


  Touch the CopySourceMemoryNo key to change the copy source No. in the order of 0 to 15.
- 3 Select the copy destination No. (0 to 15).

  Touch the Copy Destination Memory No. | key to change the copy destination No. in the order of 0 to 15.
- 4 Touch the Copy key.





Touch the OK key to return to the "System Menu 1/2".



Finished Copying.

# Initialization

This function deletes all setting contents in the memory and initializes the settings again.

If the initialization is not saved, the system operates with the previous settings at the next start-up.

Setting	Function
Initialize	Initializes the settings other than the common memory settings.
Initialize All Memory	Initializes the all settings including the common memory settings.

# **OCHECK**

Note that the initialized setting contents are deleted at the next start-up if the initialized setting contents are not saved.

Refer to →"Save".

When the initialization is executed, the data unfixed status may occur temporarily. At data unfixed state, the strobe output is set to "OFF", and after the data become fixed, the strobe output is set to "ON" and the measurement data display is started.

#### How to use


In case of initializing the memory setting in current use


- 1 Display the "Initialize" screen.
- **2** Touch the <u>Initialize</u> key.

  The confirmation message appears.
- **3** Touch the Yes key.

  The message of notifying the completion of initialization appears.
  - \*Touch the No key to cancel the initialization and return to step 1.
- **4** Touch the OK key.

  Touch the OK key to return to the "System Menu 1/2".







### In case of initializing the settings of all memories


- 1 Display the "Initialize" screen.
- **2** Touch the <u>Initialize All Memory</u> key. The confirmation message appears.
- **3** Touch the Yes key.

  The message of notifying the completion of initialization appears.
  - \*Touch the No key to cancel the initialization and return to step 1.
- **4** Touch the OK key.

  Touch the OK key to return to the "System Menu 1/2".







# ■ Save

This function saves the setting contents in all memories.

Be sure to "save" the setting change before turning off the system. Failure to do deletes all setting change when the system is turned off.

When re-starting up the system, the last setting contents (saved at last) appear. If all the settings are not saved, all of them are set to default value.

# O CHECK

This function cannot save the status of "Timing Input" and "Hold" setting.


- How to use
  - 1 Display the "Save" screen.

return to step 1.

Menu 1/2".

- **2** Touch the Save All Memory key. The confirmation message appears.
- Touch the Yes key.The message of notifying the completion of save appears.\*Touch the No key to cancel the save and
- **4** Touch the OK key.

  Touch the OK key to return to the "System"



### ■ Communication: COM Port

This function specifies the baud rate, the data length, and parity for RS-232C communication.

These settings are used for communication with PC using RS-232C connector. Make sure to save the changed setting values, and then restart the power supply of the controller to validate the settings.

Setting item	Details
Baud rate	Sets the communication speed. Select from 9,600bps/19,200bps/38,400bps/115,200bps.
Data length	Sets the data bit number. Select from 7bit/8bit.
Parity	Sets the check bit for securing the reliability of communication. Select from even/odd/none.

For more further detail of RS-232C communication, refer to → "5-1 RS-232C Communication Control".


### How to use

1 Display the "Communication: COM Port" screen.

### **Baud Rate setting**

**2** Touch the "Baud Rate" key to select the communication speed.

The display is changed as below each time the key is touched.



# Data length setting

**2** Touch the "Data Length" key to select the data length.


The display is changed between 8 (8bit) and 7 (7bit) each time the key is touched.


### Parity Setting


2 Touch the "Parity" key to select the parity setting.


The display is changed as below each time the key is touched.











# ■RS-232C Output

This function is used for performance setting of the measurement data output from RS-232C to an external device.

### RS-232C Output mode

RS-232C output is selectable from three modes.

The initial value is set to "Handshake".

Setting item	Contents
Handshake	In response to a request command from an upper device, transmits the result data as a reply command.
	Transmits the measured value in the exclusive output format at timing input ON during Timing mode is selected.
Continuous	Transmits the measured value continuously in the exclusive output format after Continuous mode is selected.

Refer to the page 5-12 for details of the exclusive output format.

# O CHECK

Note that the command send/receive when RS-232C output mode is set to Continuous or Timing operates as the followings:

[RS-232C port]

Any other commands than "RS-232C Output Mode" is ignored. When "RS-232C Output Mode" is received, it transmits the reply and shifts to each mode.

[USB port]


Send/receive of all commands is available.

### RS-232C output type

When Timing or Continuous is selected for "RS-232C Output Mode", an output destination of the measurement data is selectable from OUT1, OUT2, and both OUT1&OUT2.

The initial value is set to "OUT1".


- How to use
  - 1 Display "RS-232C Output" screen.




For RS-232C output mode:

**2** Touch the "Output mode" key to select the output mode.

The display is changed as below each time the key is touched.







For RS-232C output type:

**2** Touch the "Output type" key to select the output type.

The display is changed as below each time the key is touched.





# ■ Console Setting

This function sets "Panel Lock" and "Start-up Screen" of compact programmable display.

#### Panel Lock

"Panel Lock" is used for prohibiting the setting change on the compact programmable display to prevent any setting error occurrence due to unintentional operation on the compact programmable display. When this function is set to "ON", any operations except for screen display change and setting off of "Panel Lock" are prohibited.

\* Save function, however, can be executed and the "Panel Lock" is valid at the next system start-up by saving the setting.

### Start-up Screen

"Start-up Screen" is used for selecting the screen which is displayed after the wake-up screen of compact programmable display.

Select from 16 screens shown in the next page.

By selecting the screen that are often used or used for setting confirmation as a start-up screen, the setting steps can be shortened.

## **OCHECK**

Make sure to save the setting to fix the selected start-up screen.


- How to use
  - 1 Display the "Console Setting" screen.


## Panel Lock setting

2 Touch the Panel Lock key to select ON or OFF.

The key display is changed between ON and

The key display is changed between ON and OFF each time the key is touched.







## Start-up Screen setting

2 Touch the ▲ ▼ key of "Start-up" to select the screen which is displayed after the wake-up screen of compact programmable display.

The display is changed as below by touching the very key. Also, the display is changed in counterclockwise by touching the key.







Displays the measurement value of OUT1.

Sets the measurement value of OUT1, output (alarm, strobe, judgment output), and status of the hold, timing, zero set, and reset input.






Displays the measurement value of OUT2.

#### OUT2 Operate




Sets the measurement value of OUT2, output (alarm, strobe, judgment output), and status of the hold, timing, zero set, and reset input.

#### OUT1&2 Display



Simultaneously displays the measurement values of OUT1 and OUT2.






Displays the received light waveform of the sensor head A.

#### Waveform(B)




Displays the received light waveform of the sensor head B.

Top



Displays the Top menu screen.

#### Setting



Displays the Setting menu screen.

### Head A Menu

Head A Menu				To	op
Install Mode	Emiss Adjust	Emit LI Search	Alarm Delay Times		•
Meas Mode	Meas Suf Ref	Laser Control	Calibra- tion	•	<b>≖</b>

Displays the Head A Menu screen.

#### Head B Menu

Head B Menu				To	p
Install Mode	Emiss Adjust	Emit LI Search	Alarm Delay Times		_
Meas Mode	Meas Suf Ref	Laser Control	Calibra- tion	+	<b>∓</b>

Displays the Head B Menu screen.

#### OUT1 Menu

OUT1 Menu 1/2				To	op
Output Selection	Analysis Mode	Fitter Operate	Offset		•
Up/Lo Lmt Val	Up/Lo Lmt Hys	Digit No Meas	Analog Scaling	•	<u>*</u>


Displays the OUT1 Menu1/2 screen.

#### OUT2 Menu

OUT2 Menu 1/2				To	эp
Output Selection	Analysis Mode	Fitter Operate	Offset		_
Up/Lo Lmt Val	Up/Lo Lmt Hys	Digit No Meas	Analog Scaling	•	▮


Displays the OUT2 Menu1/2 screen.

#### Common Menu




Displays the Common Menu screen.

### System Menu



Displays the System Menu1/2 screen.

#### Meas Val Menu



Displays the Measurement Value Menu screen.

# 4-3-5 Buffering Setting

Buffering is a function for accumulating the measurement data in the controller memory and loading them to the external control device (PC).

Maximum 65,000 measurement data can be temporarily accumulated in the controller memory before loading them to PC. All accumulated data can be loaded by using the communication control with RS-232C or USB, or Intelligent Monitor AiM.

## TECHNIQUE

With an optional Intelligent Monitor AiM, accumulation and loading of the measurement data can be executed easily by mouse operation. This Intelligent Monitor AiM is also useful for confirmation or verification of the measurement data because it can convert the data into CSV data format. CSV data can be used for graphic display, save, replay of the measurement data, and it can be opened in Microsoft Excel application.

## Supplemental remarks


For buffering by RS-232C communication, refer to → "HL-C2 Series USER'S MANUAL RS-232C Communication Control" – "Chapter 5 Buffering Command".

For buffering by USB communication, refer to \(\bullet\)"HL-C2 Series USER'S MANUAL USB Communication Control" - "2-2-6 Setting (Buffering)".

## O CHECK

A program is required for executing buffering by communication control with RS-232C or USB.

# ■ Data Buffering Operation



All the settings related to buffering cannot be changed during the buffering operation. Change the settings after buffering operation stops.

# ■ Buffering Operation

This function accumulates the data during buffering operation.

Set necessary parameters in advance and start buffering operation.

### O CHECK

- The starting of the buffering operation requires the buffering type and the accumulation amount to be set within the setting range.
- · All settings related to buffering cannot be changed during buffering operation.
- · Non-buffering status cannot be set by only stopping the buffering operation.

## ■ Self-stop

This function stops the buffering operation automatically at completion of accumulation.

When the Self-stop function is set to ON (buffering operation is automatically stopped), stop input for buffering operation becomes unnecessary. This function is valid when the buffering mode is set to the continuous mode, trigger mode, or sample mode. This function is invalid when the timing mode is selected. When OUT1/OUT2 is set for the buffering type, this function operates immediately after completion of accumulation for OUT1/OUT2. When OUT1&OUT2 is selected, the self-stop function operates at completion of accumulation for both OUT1&OUT2.

## Buffering Mode

Four types of buffering mode can be selected.

"Continuous Mode" is set as a default.


#### **Continuous Mode**

- · When buffering operation starts, data accumulation to the controller memory also starts.
- Accumulation stops when the accumulation amount has reached the setting value or when buffering operation stops.




### Trigger Mode

- · When buffering operation starts, the trigger generation is turned to stand-by status.
- The measurement data before and after the trigger point where the trigger is generated is accumulated into the controller memory.
- · Accumulation stops when the accumulation amount has reached the setting value or when buffering operation stops.



### **Timing Mode**

- When buffering operation starts, the timing input is turned to stand-by status.
- Changing the timing input from "ON" to "OFF" during stand-by status starts data accumulation to the controller memory.
- •Timing input stops when the accumulation amount has reached the setting value or when buffering operation stops.




## **OCHECK**

Changing the timing input from "ON" to "OFF" again deletes the previous data and starts new data accumulation. Make sure to stop the buffering operation once and load/save the accumulated measurement data before performing the next accumulation.

### Sample Trigger Mode

- · When buffering operation starts, the trigger generation is turned to stand-by status.
- · Accumulation of the measurement data for the setting sample trigger accumulation amount starts after the setting trigger condition is generated.
- After completion of sample trigger accumulation, the trigger generation is turned to stand-by status again.
- · When the setting trigger condition is generated again, accumulation of the setting sample trigger amount starts.
- · Accumulation operation stops when the accumulation amount has reached the setting value or when buffering operation stops.



## **OCHECK**

Be sure to set the sample trigger accumulation amount so that (accumulation amount) ÷ (sample trigger accumulation amount) is an integer value.

# Buffering Type

This function selects individual data accumulation or simultaneous data accumulation on OUT1 and OUT2.

OUT1 is set as a default.

### **OCHECK**

The maximum accumulation data amount differs depending on buffering type.

# ■ Buffering Rate

The buffering rate can be set for accumulating the measurement data for a long-duration by taking an adequate interval to the sampling cycle.

Select from 1 (All measurement data), 1/2, 1/4, .....to 1/32768.

1(All measurement data) is set as a default.

(If selecting 1/4, the measurement data is accumulated only at once in four sampling cycles.)

## TECHN I QUE

All the measurement data can be accumulated, however, in case that the deviation amount of the measurement data is small to a sampling cycle, setting the data accumulation interval can execute a long-duration data accumulation than measurement at every sampling cycle. This is useful for the effective use of memory since the data accumulation amount is limited.

### Accumulation Amount

This function sets the accumulation amount of the measurement data.

Specify the accumulation amount within 1 to Max. accumulation amount.

Maximum accumulation amount is different between two buffering types.

OUT1 or OUT2 ······ Max accumulation amount = 65,000 data

OUT1 & OUT2 ········ Max accumulation amount = 32,500 data "20000" is set as the default.

## **O**CHECK

Accumulation cannot be started when the setting of the range of "accumulation amount" for each "buffering type", settings of "trigger point" and "sample trigger accumulation amount" corresponding with the "accumulation amount" are not correct (out of the setting range).

# ■ Trigger Conditions


This function is used for setting the trigger generation conditions when the buffering mode is set to trigger mode or sample trigger mode.

The trigger conditions are selectable from "At timing input ON", the results of "judgment output" (HI, LO, HI or LO, HI to GO, LO to GO, HI or LO to GO), "At an alarm occurred", and "At an alarm released".

The initial value is set to "At timing input ON".

### **OCHECK**

- · Note that the settings of "Upper Limit/Lower Limit Value of Judgment Output" and "Upper Limit/Lower Limit Hysteresis of Judgment Output" become effective when the result of judgment output is set as a trigger condition.
- · Note that the setting of "Number of Alarm Delay Times" becomes effective when "At an alarm occurred" is set as a trigger condition.
- Ex) When the "Buffering Mode" is set to trigger mode, the operations of each trigger condition are shown as follows:



## **O**CHECK

Normally, the measurement value is on hold at timing input ON status; however, only in the case that the buffering mode is set to trigger mode or sample trigger mode, and this function is set to "At timing input ON", the measurement value is not on hold at timing input ON status during buffering operation.

# ■ Trigger Delay

This function is used for delaying the timing of trigger detection when the buffering mode is set to trigger mode or sample trigger mode.

Sets number of sampling times as the trigger delay value. Setting range is 0 to 100000000.

The status during the trigger delay is indicated as "Accumulating". The initial value is set to "0".

### For trigger mode:

Loads the measured data from the actual trigger generated point to the delayed trigger point that has been set for this function.

### For sample trigger mode:

Starts accumulation of the measured data from the delayed trigger point that has been set for this function after the trigger was generated. The function ignores even if a new trigger is generated during the trigger delay operation.

### O CHECK

When the buffering rate is already set, the trigger delay is counted with the extended sampling in accordance with the setting.

# ■ Trigger Point

When the buffering mode is set to trigger mode, the measurement data can be loaded by setting the data at the trigger generated as a trigger point.

Setting range is 1 to setting "accumulation amount".

The initial value is set to "10000".

## **OCHECK**

- · If the "trigger point" is set to a larger value than the setting "accumulation amount", accumulation cannot be started.
- · When the "Trigger Delay" function is set, the measurement data from the trigger delayed data point after the setting trigger is generated can be loaded.

# ■Sample Trigger Accumulation Amount

When the buffering mode is set to sample trigger mode, the sample trigger accumulation amount can be set at every trigger generation.

Setting range is 1 to setting "accumulation amount". The initial value is set to "1".

## **O**CHECK

Be sure to set the sample trigger accumulation amount so that (accumulation amount) ÷ (sample trigger accumulation amount) is an integer value.

## ■ Status Readout

This function checks the status of the measurement data accumulation.

Use this function for checking the accumulation status before reading the accumulated data. After having checked the status, the controller replies one of the next status.

Status	Contents
Non-buffering	Buffering operation is not executed at all after turning on the power supply or after initialization, or buffering operation is stopped while waiting for trigger after buffering has started.
Wait for trigger	Wait for trigger status after buffering operation has started.
Accumulating	Buffering operation has started and measurement data is being accumulated, or trigger has being generated and measurement data is being accumulated.
Accumulation completed	Accumulation amount has reached the setting value or the buffering operation has stopped.

### ■ Final Data Point

The accumulation status can be read from the data amount.

"Final Data Point" is set to "0" when the "Status Readout" is set to "Non-buffering".

## ■Trigger Counter Readout

When the buffering mode is set to sample trigger mode, the number of times of the final trigger generation can be read out.

## OCHECK

When readout of the trigger counter is performed, stop the data accumulation operation and confirm the "Final Data Point". If the result of "Status Readout" is indicated as accumulation completed and the "Final Data Point" is any values other than "0", readout of the trigger counter can be started.

## ■ Data Read

The accumulated measurement data in the controller memory can be read out.

The below shows two reading methods.

Read method	Contents
Normal read	Simply reads the accumulated measurement data as is.
Rapid read	Reads the accumulated data by the difference from the previous data.  Since data with less difference decreases with decreasing variation, the total transmission data amount decreases and the communication time is shortened.

## **OCHECK**


To read the buffering data, stop buffering operation and check the "Final Data Point". The accumulated data to the final data point can be read only when the result of "Status Readout" is "Accumulation Completed" and the final data point is the value "other than 0".

# 4-4 Supplemental Explanation

This section provides supplemental explanation for enhancing understandings of the system functions.

# 4-4-1 Alarm Setting and Outputs

"Alarm status" means the measurement disabled status due to poor light intensity or out of measurement range.



\*1 In case of selecting "A+B" for the output selection, an alarm is output when either of the sensor head A or B goes into an alarm status.

	Function
Alarm Delay Times	Holds the previous normal value up to the setting number of times when an alarm is issued.  Refer to → "Alarm Delay Times".
Digital Output at Alarm	Sets the measurement value display in case that an alarm status continues more than the setting number of times.  Refer to → "Digital Output at Alarm".
Analog Output at Alarm	Sets the analog output value in case that an alarm status continues more than the setting number of times.  Refer to → "Analog Output at Alarm".
Alarm Output Delay	Enables the alarm output at a real time regardless of the alarm delay times.  Refer to → "Analog Output Delay".


# 4-4-2 Conditions When Output Data become Unfixed

At immediately after change of "head Setting" or "OUT Setting", or when the reset or laser emission stop is input, the operation status becomes "Data unfixed status" (data is not determined). This status is not an alarm status.

The data unfixed status starts at the measurement re-start after the setting change or executing reset, and then, stops when the average times of data is reached.

Under data unfixed status, the display of the compact programmable display is -999.999999[mm], the analog output is -10.800[V]\*<sup>1</sup>, the judgment output is set to OFF, and the strobe output is set to OFF.

- \*1 This is the initial value. Under data unfixed status, the analog output can be changed to the fixed value. Refer to \(\rightarrow\)"Analog Output at Data Unfixed".
- \*2 Under data unfixed status, the zero set input is ignored.
- \*3 For releasing the data unfixed status, refer to \(\rightarrow\) "Chapter 7 Troubleshooting".



	Data unfixed status	Alarm status
Status	Measurement data is unfixed. (Average buffer has not reached the setting number of times.)	Measurement disabled status due to poor light intensity or when a target object goes off the measurement range.
Meas val display on compact programmable display	-999.999999[mm]	Hold previous value (default)
Judgment output	OFF	Interlocks with the digital output
Alarm output	Interlocks with the alarm status	ON
Strobe output	OFF	ON

### Alarm Code

In case an alarm occurs, check the alarm code of alarm output read by RS-232C or USB communication.

Alarm code	Name	Description
0	Normal	Normal measurement status.
1	Measurement alarm	Measurement is not possible due to insufficient light intensity, or when the measurement surface specified by the transparent object setting cannot be detected or under any other circumstances where the setting and the actual condition do not match.  ⇒Check the mounting condition and setting so that the light intensity is sufficient.
3	Controller Memory Error 1	The alarm occurs when saved settings cannot be retrieved during startup.  ⇒Turn the power off and on again. If this alarm still occurs, it is likely that saved settings have been destroyed. Thus, initialize all memories and save it. Then, turn the power on again. In this case, saved settings will return to default settings.
4	Controller Memory Error 2	The alarm occurs when settings cannot be saved. ⇒ Execute "save" again.
5	Sensor head unconnected	Sensor head A and B are unconnected, or sensor head is connected to HEAD B in the case of using only one sensor head. This alarm also appears when the cable for connecting sensor head is disconnected. ⇒Connect the sensor head to HEAD A when using only one sensor head. If this alarm code appears again in spite of correct connection, the connecting cable may be disconnected. Please contact our sales person in charge.
6	Sensor head unadapted	The export controlled sensor head is connected to the export uncontrolled controller. ⇒Connect in the correct combination.
7	Head connection check error	Controller is not recognizing sensor head correctly. Sensor head is not operating properly due to external noises or sensor head is malfunctioning.  ⇒Carry out measures to noise then restore the power.
8	Automatic Head Adjustment Error	The darkness level of received light waveform cannot be recognized correctly. Normal startup is interfered possibly by extraneous light or external noise.  ⇒ Check use environment (extraneous light, for example), take measures against noise, and turn the power on again.
9	Head System Error	The sensor head system does not work properly. The inner part of the sensor head is possibly damaged.  ⇒The sensor head has possibly failed. Contact our sales person in charge.

Refer to → "7-1 Corrective Actions".

The conditions of causes of data unfixed status and the measurement status are shown as below.

Conditions when output data become unfixed status	Measurement status
Remote interlock is input at power-on	
"Sampling Cycle" setting is changed.	Both OUT1 and OUT2 become the data unfix status.
"Initialization"	
"Laser Emission Stop" is input.	The sensor head which is set at the output selection
"Installation Mode" setting is changed.	for each OUT becomes data unfixed status.  Ex In case that A+B is set for OUT1, -B is set for
"Measurement Mode" setting is changed.*	OUT2, and the setting of sensor head A is changed, OUT1 becomes the data unfixed status,
"Measurement Surface Reference" setting is changed.	and OUT2 continues the measurement.
"Calibration" setting is changed.	
"Output Selection" setting is changed.	
"Transparent Object", "Refractive Index", and "Refractive Index Calculation" settings are changed.	When changing the setting of OUT1, OUT1 becomes the data unfixed status, and OUT2 continues the measurement. In the same manner, when changing the setting of OUT2 OUT5 becomes the data unfixed.
"Analysis Mode" setting is changed.	setting of OUT2, OUT2 becomes the data unfixed status, and OUT1 continues the measurement.
"Average Times" setting is changed.	

<sup>\*</sup>There are cases where the data unfixed status does not occur depending on the setting conditions.

# 4-4-3 Memory Save and Terminal Setting

The setting contents for each function can be stored in 16 different patterns in the controller memory.

This function stores the measurement or judgment conditions for each measurement object respectively, so without re-inputting of various function setting, the condition change can be performed only by changing the memory No. "Memory change" can be executed by "Compact Programmable display" or "External Terminal Input (M0 to M3)".

# ■ Storable Functions in Memory

The function settings which can be stored in the memory are divided into two types. One is the function which can be stored in each specified memory No., and another is the function which can be stored as common setting value among all memories. For the detail of the above two type storable functions, refer to → "4-3 Function List & Initial Values".

## ■ Memory Change Procedure by External Input Terminal

- 1 Select Memory No. to be stored.

  For setting by compact programmable display, refer to → "4-3-4 System Setting" "Memory Change".
- 2 After selecting memory No., input the setting value for each function. For memory changeable functions, refer to → "4-3 Function List & Initial Values".
- 3 Set "Terminal" at "Priority Setting of Memory Change".

  For "Priority Setting of Memory Change", refer to → "4-3-4 System Setting"


   "Priority Setting of Memory Change".
- 4 Execute all memory save. If not doing so, "Terminal" cannot be set. For "Save" function, refer to →"4-3-4 System Setting" – "Save".
- **5** Set the memory No. to be used to the external terminal input (M0 M3). \*The setting can be input by manually on the compact programmable display, or by the command of RS-232C and USB communication control, or Intelligent Monitor AiM.

With the above five steps, the memory No. change can be performed by the external input terminal.

# ■ External Input Terminal Setting

Memory	Exte	ernal inp	out term	inal
No.	M0	M1	M2	M3
0	OFF	OFF	OFF	OFF
1	ON	OFF	OFF	OFF
2	OFF	ON	OFF	OFF
3	ON	ON	OFF	OFF
4	OFF	OFF	ON	OFF
5	ON	OFF	ON	OFF
6	OFF	ON	ON	OFF
7	ON	ON	ON	OFF
8	OFF	OFF	OFF	ON
9	ON	OFF	OFF	ON
10	OFF	ON	OFF	ON
11	ON	ON	OFF	ON
12	OFF	OFF	ON	ON
13	ON	OFF	ON	ON
14	OFF	ON	ON	ON
15	ON	ON	ON	ON

### МЕМО



# **External Communication Control**

This chapter explains control method of system by RS-232C/USB/Ethernet communication.

5-1	Communication Control by RS-232C ····· 5	5-2
	5-1-1 Specifications	5-2
	5-1-2 Type and Format of Commands	5-5
	5-1-3 Command List5-	-14
5-2	USB Communication Control5-	-24
5_2	Ethernet Communication Control5-	20

# 5-1 Communication Control by RS-232C

# 5-1-1 Specifications

# ■ Communication Specifications


The specifications related to communication are listed in the table below. The configurations can be changed to the requirements of external host device.

Item	Settings	Default
Communication speed	9,600/19,200/38,400/115,200 bps	115,200 bps
Communication system	Full-duplex	-
Synchronization system	Asynchronous	-
Transmission code	ASCII	-
Data length	7 bit/8 bit	8 bit
Parity check	Even/Odd/None	None
Stop bit length	1 bit	-
End code	CR(0DH)	_
BCC	Yes*1	_

<sup>\*1</sup> To omit BCC calculation, enter "\*\*" (2AH, 2AH) to BCC.

# ■ Pin Arrangement


The system uses a D-SUB male connector with 9 pins.



Pin	Signal	Signal direction	Description	
No.	name <sub>HL-C2</sub> Host		Description	
1	CD(DCD)	Not used	-	
2	RD(RxD)	IN OUT	Received data signal Usually connected to SD(TXD) of external device.	
3	SD(TxD)	OUT IN	Transmitted data signal Usually connected to RD(RXD) of external device.	
4	ER(DTR)	Not used	-	
5	SG(SG)	<b>←</b> Connected <b>→</b>	Signal ground Usually connected to SG(SG) of external device.	
6	DR(DSR)	Not used	-	
7	RS(RTS)	Not used	-	
8	CS(CTS)	Not used	-	
9	CI(RI)	Not used	-	


# ■ Connecting Example with External Device

## Configuration



### Connection

HL-C2 and external host device should be connected as below.



## **OCHECK**

Signals other than RD, SD, SG and Shield should be kept unused. Do not connect with HL-C2.

### ■ Communication Procedures

- Configure communication specifications
- 1. Configure communication specifications of HL-C2

The communication specifications of RS-232C on HL-C2 are listed in the table in "5-1-1 Communication Specifications". Set them according to situations.

### 2. Configure communication specifications of host device

Read the manuals related to the communication specification of external host device before setting them. Change the specifications so they will be the same as the settings of HL-C2, or set the specifications on HL-C2 according to the settings on the external host device.

# ■ Change of Communication Conditions

After changing the settings of communication conditions on baud rate, data length or parity check, make sure to save the new setting values and then restart the controller to reflect them.

# 5-1-2 Type and Format of Commands


# ■ Data Transmission/Reception

### Data transmission/reception

This section explains how to set or change various parameters or to confirm or read measurement values by sending a command from the external host device to HL-C2.


### (1) Normal sequence to read setting data

The figure below shows the data transmitting/receiving sequence in case the request communication data instructing setting data read (in this case the head character of the command on the request communication data is "R"), which is transmitted from the external host device to HL-C2, is normal.




## (2) Normal sequence to transmit/receive data on data setting or operation instruction

The figure below shows the data transmitting/receiving sequence in case the request communication data related to data setting or operation instruction (in case the head character of the command on the request communication data is "W"), which is transmitted from the external host device to HL-C2, is normal.



## (3) Abnormal sequence to transmit/receive data

The figure below shows the data transmitting/receiving sequence in case the request communication data transmitted from the external host device to HL-C2, is abnormal such as data range error or garbled characters.



### • Error code

Code No.	Code type	Description					
01	Format error	The first four characters are not \( \( \bar{E} \bar{E} \).					
02	Command error	The command is undefined.					
03	Command code error	The forth character from the head is neither R nor W.					
04	Code error	The code is other than that specified per the command.					
05	Data error	The data length does not correspond to the command.					
07	Setting error	The setting for the command is out of the range.					
08	BCC error	BCC check was not conformable.					
10	Control flow error	<ul> <li>Memory Change command was received while "Terminal" was selected on "Priority Setting of Memory Change".</li> <li>Timing input was turned to OFF by a command while the timing input terminal is ON.</li> <li>Timing input was turned to ON by a command while the timing input terminal is OFF.</li> </ul>					
11	Communication error	<ul> <li>A parity error occurred during data reception.</li> <li>A framing error occurred during data reception.</li> <li>An overrun error occurred during data reception.</li> </ul>					
20	Execution error	Calibration or analog scaling is inexecutable.					
21	Buffering condition error 1	Setting of buffering was to be changed without stopping buffering operation.					
22	Buffering condition error 2	Buffering operation was to be initiated with inadequate buffering setting.					
23	Buffering condition error 3	<ul> <li>Data was read while buffering operation is "Start".</li> <li>Data was read while the status is other than "Accumulation Completed" status.</li> <li>Data other than the read result of first data point to the final one was specified to be read.</li> </ul>					


## **O**CHECK

• If an abnormal response is received, check if the transmitted data has errors. Correct them if it does. In case an error occurs on the system even the data has no errors, a temporary abnormal status due to noise or system abnormality on the controller or external host device may occur. Check them by restoring the power

## ■ Command Classification

### Communication data format

The figure below shows the basic format of request communication data and response communication data.



The specifications of respective sections are explained in the table below.

## **O**CHECK

For ASCII and alphabetical characters, only capital characters can be used.

Section	Description
Header	This section indicates the type of communication data.
Command	This section specifies the command. 3-character command is specified to instruct operation to HL-C2.  R * * : Read request (response) communication data W * * : Data setting request (response)  Refer to "5-3 Command List" for types of commands.
Code	This section indicates the identification code. It specifies the function classification and sensor head for the command.  □: System □: Head B □: OUT2 □: Head A □: OUT1 □: Common  The selectable code varies depending on the command.  → Refer to "HL-C2 Series USER'S MANUAL RS-232C Communication Control" for the details.
Data	This section is used only to read buffering data.
Subdata	This section stores setting values and measurement values.  This section is omitted in read request communication data command (R*) and write command (W**).
всс	This is the block check code. The exclusive OR is executed from the header to final characters of communication data and 8-bit data is converted to 2-character ASCII code. BCC can be omitted at transmission by storing (2AH, 2AH). In this case, the BCC in the response data is ** (2AH, 2AH), too.
Delimiter	This code is used to identify the end of communication data (delimiter). It is fixed to CR (0DH).

# ■ Request Communication Data Format

This section explains the 6 format patterns of request communication data transmitted from the external host device to HL-C2.


### Read request

The figures below show the format for read request.

There are two types of pattern, depending on whether data section is included or not. The request communication data does not contain subdata section.


#### (Basic format: data section is not included)





### (Special format: data section is included (buffering))

# FORMAT 2 Normal read of buffering data




## Data setting request


The figures below show the format for data setting request.

The response communication data does not contain subdata section.


# FORMAT 3 Code setting command




## FORMAT 4 Value setting command 1



integral part (no zero suppress) + decimal point + 6-character decimal part




# FORMAT 6 Normal write of buffering data




# ■ Response Communication Data Format

This section explains the 10 format patterns of response communication data transmitted from HL-C2 to the external host device.

### • Read response



# 5 Special format 2:2 Output check



The measurement value consists of 1-character symbol, 3-digit integral part (no zero suppress), decimal point and 6-digit decimal part.

The following outputs are stored in (1) to (12) (OFF:  $\boxed{0}$  / ON:  $\boxed{1}$ ).

No.	Output				
(1)		Strob	e		
(2)		ent t	HI		
(3)	OUT1	Judgment output	GO		
(4)			LO		
(5)		Reserve			
(6)		Alarr	n		


No.	Output					
(7)		Strobe				
(8)	OUT2	Judgment output	HI			
(9)			GO			
(10)			LO			
(11)		Reserve				
(12)		Alarm				

## **OCHECK**

BCC


Response to (5) and (11) above are unfixed (either 0 or 1).

# FORMAT 6 | Special format 4: Normal read of buffering data



Subdata: Repeat of "1-character symbol + 3-digit integral part (no zero suppress) + decimal

point + 6-digit decimal part"



The data of specified head point is stored with the head data format shown below. For the data of second point and subsequent points, the differential by the previous data (the data based on the 6 places of decimals) is responded.


### Head data format

- 1-character symbol + 3-digit integral part (no zero suppress)
- + decimal point + 6-digit decimal part


⟨Example using the reply command shown above⟩

- $+12.345678, +12.345801, +12.345576, +12.345652, \dots, +12.345599, +12.34554, +12.345543, +12.345621, \dots, +12.345678, +12.345643, +12.345644, +12.345644, +12.345644, +12.345644, +12.345644, +12.345644, +12.345644, +12.345644, +12.345644, +12.345644, +12.345644, +12.345644, +12.345644, +12.345644, +12.345644, +12.345644, +12.345644, +12.34564, +12.34664, +12.3464, +12.3466$ 
  - ↑ ↑ ↑ (+123) (-225) (+76)

FORMAT 8 Special format 7: Exclusive output format for RS232C output mode




For RS232C output type OUT1&OUT2



The measurement value consists of 1-character symbol, 3-digit integral part (no zero suppress), and 6-digit decimal part.


### Normal response

The normal response communication data for data setting request is common in all formats.



### • Abnormal response

The abnormal response communication data is common in all formats.




## ■ BCC

BCC is the code for horizontal parity check to improve the reliability of communication data. The exclusive logical sum from the header (%) to the final character of communication data is calculated and resultant 8-bit data is converted to 2-character ASCII code. The controller checks whether the exclusive logical sum of received message (from the header to the final character of communication data) is consistent with the value transmitted by the personal computer. The difference in BCC between at transmission and at receipt indicates that an error occurred in the message during communication. To omit BCC calculation, enter \*\* (2AH, 2AH) to BCC. In this case, the BCC in the response data is \*\* (2AH, 2AH), too.

### **OCHECK**

For Special format 7 of FORMAT 8: As for the exclusive output format for RS232C output mode, the controller always delivers the measurement value attaching the BCC calculation result.

### BCC creation example



# 5-1-3 Command List

Refer to "HL-C2 Series USER'S MANUAL RS-232C Communication Control" for the details of respective commands.

Item	Comma	and	Code	Subdata*1	Setting value
Installation	DMM M	WMM	1/2	00000	Diffuse reflection
Mode	KIVIIVI			00001	Specular reflection
				00000	Auto
				00001	0.04%
				00002	0.05%
				00003	0.06%
				00004	0.08%
				00005	0.11%
				00006	0.14%
				00007	0.18%
				80000	0.24%
				00009	0.31%
				00010	0.40%
				00011	0.53%
				00012	0.68%
				00013	0.89%
				00014	1.16%
Emission	RFB V	A/ED	1/2	00015	1.50%
Emission Of Adjustment	KFB V	WFB	1/2	00016	1.95%
+				00017	2.54%
				00018	3.30%
				00019	4.29%
				00020	5.58%
				00021	7.25%
				00022	9.43%
				00023	12.3%
				00024	15.9%
				00025	20.7%
				00026	26.9%
				00027	35.0%
				00028	45.5%
				00029	59.2%
			-	00030	76.9%
				00031	100%
	REA V	NEA	1 /2	-	00001 to 00512
Adjustment b	REB V	NEB	1/2	-	00001 to 00512

<sup>\*1</sup> Subdata section consists of 5 digits (zero suppress is omitted) indicated by decimal.

	Item		Com	mand	Code	Subdata*1	Setting value	
	Б			WFC	1/2	00000	None	
	Emission Search	RFC	00001			Execute		
	Scarcii					00002	Searching	
	Alarm				WHC			00000: OFF
	Delay 7	Γime	S	RHC		1/2	-	to
	2 clay							65535: Hold Previous Normal Value
							00000	Diffuse [Standard]
							00001	Specular [Standard]
							00002	Metal 1
	Measur	eme	nt	RSM	WSM	1/2	00003	Metal 2
	Mode						00004	Penetration
							00005	Glass
							00006	Glass
							00000	Pattern
	Meas S Ref	urt		RBF	WBF	1/2	00000 00001	Near
	- T							Far
	luring 1	Poin		RPA	WPA	1/2	-	00003 to 00510
Head	Range	Poin	t b	RPB	WPB	1/2	-	00003 to 00510
He	Calibrat Meas.		A	RCA	WCA	1/2	-	-950.000000 to +950.000000 [mm]
	Value		В	RCB	WCB	1/2	-	-950.000000 to +950.000000 [mm]
	Calibrat Correct	Calibration		RHA	WHA	1/2	-	-950.000000 to +950.000000 [mm]
	Value		b	RHB	WHB	1/2	-	-950.000000 to +950.000000 [mm]
		Calibration -					00000	None
	Calibra			-	WCE	1/2	00001	Execute
							00002	Cancel
	Laser			D. D	WLR	1./0	00000	Laser ON
	Control		RLR	WLK	1/2	00001	Laser OFF	
	Read Received Light Intensity		RID		1/2	-	00000 to 01023	
	Peak Recognition Sensitivity		RTH	WTH	1/2	-	00100 to 00400	
							00000	OFF
	Median	. 17214		DME	WMF	1/2	00001	7 point
	iviedian	ı Fill	ıer	KIVIF	VVIVIE	WMF 1/2	00002	15 point
L						1: - : 4 - 7	00003	31 point

<sup>\*1</sup> Subdata section consists of 5 digits (zero suppress is omitted) indicated by decimal.

Item		Command		Code	Subdata <sup>*1</sup>	Setting value
					00000	A
					00001	В
					00002	-A
					00003	-B
					00004	A+B
					00005	-(A+B)
					00006	A-B
	Output	DOC	WOO	2/4	00007	B-A
	Selection	ROS	wos	3/4	00008	[A] [Tr]
					00009	[B] [Tr]
					00010	[-A] [Tr]
				ı	00011	[-B] [Tr]
					00012	A1+B1 [Tr]
					00013	-A1+B1 [Tr]
					00014	A1-B1 [Tr]
					00015	B1-A1 [Tr]
	Transparent Object				00000	1st Surface
					00001	2nd Surface
$\vdash$					00002	3rd Surface
OUT					00003	4th Surface
					00004	Up Lmt Surf
					00005	1st-2nd Surf
					00006	1st-3rd Surf
		RMN	WMN	3/4	00007	1st-4th Surf
					00008	1st-Up Surf
					00009	2nd-3rd Surf
					00010	2nd-4th Surf
					00011	2nd-Up Surf
					00012	3rd-4th Surf
					00013	3rd-Up Surf
					00014	4th-Up Surf
	Refractive		WGK		00000	OFF
	Index Calculation	RGK		3/4	00001	ON
	Refractive Index	RGR	WGR	2		+000.500000
				3/4	-	to +002.000000
		RZS	WZS	3/4	00000	OFF
	Zero Set				00000	ON
					00001	011

<sup>\*1</sup> Subdata section consists of 5 digits (zero suppress is omitted) indicated by decimal.

	Item	Comi	mand	Code	Subdata*1	Setting value
	T::	DTI	WTI	3/4	00000	OFF
	Timing	RTI	VVII	3/4	00001	ON
	D 4		WDO	2/4	00000	OFF
	Reset	RRS	WRS	3/4	00001	ON
	** 11	D. 10	\A/! ID	2/4	00000	OFF
	Hold	RHD	WHD	3/4	00001	ON
					00000	Normal
	Analysis	DUM	WHM	3/4	00001	Peak
	Mode	KHIVI	WHIVI	3/4	00002	Bottom
					00003	Peak to Peak
					00000	Moving Average
	Filter Operation	RFL	WFL	3/4	00001	Low-pass Filter
					00002	High-pass Filter
L					00000	1 time
OUT					00001	2 times
0					00002	4 times
					00003	8 times
					00004	16 times
					00005	32 times
					00006	64 times
					00007	128 times
	Average Times	RAV	WAV	3/4	00008	256 times
					00009	512 times
					00010	1024 times
					00011	2048 times
					00012	4096 times
					00013	8192 times
					00014	16384 times
					00015	32768 times
					00016	65536 times

<sup>\*1</sup> Subdata section consists of 5 digits (zero suppress is omitted) indicated by decimal.

	Item		Com	mand	Code	Subdata*1	Setting value
					00000	1[Hz]	
						00001	2[Hz]
					00002	4[Hz]	
						00003	10[Hz]
						00004	20[Hz]
	Cutoff		RCO	WCO	3/4	00005	40[Hz]
	Frequency					00006	100[Hz]
						00007	200[Hz]
						00008	400[Hz]
						00009	1000[Hz]
						00010	2000[Hz]
	Operation Coefficient		RMK	WMK	3/4	-	+000.100000 to +009.999999
	Offset		RML	WML	3/4	-	-950.000000 to +950.000000 [mm]
	Judgment Output Upp Limit Value		RHL	WHL	3/4	-	-950.000000 to +950.000000 [mm]
	Judgment Output Lower Limit Value		RLL	WLL	3/4	-	-950.000000 to +950.000000 [mm]
UT	Judgment Output Upp Limit Hysteresis	er	REH	WEH	3/4	-	+000.000000 to 950.000000 [mm]
0	Judgment Output Low Limit Hysteresis	er	REL	WEL	3/4	-	+000.000000 to 950.000000 [mm]
	Analog	A	RAH	WAH	3/4	-	-950.000000 to +950.000000 [mm]
	Scaling Measureme nt Value	В	RAL	WAL	3/4	-	-950.000000 to +950.000000 [mm]
	Analog	a	RVH	WVH	3/4	-	±010.000000[V]
	Scaling Vol.	b	RVL	WVL	3/4	-	±010.000000[V]
						00000	None
	Analog Scalin	ng	-	WAS	3/4	00001	Execute
		_			- · ·	00002	Cancel
	Analog Outp	ut	RAA	WAA	2/4	00000	Hold Previous Value
	at Alarm		KAA	WAA	3/4	00001	Fixed Value
	Fixed Value		RFM	WFM	3/4	-	±010.800000 [V]
	Analog O/P a Data Unfixed		RDA	WDA	3/4	-	±010.800000 [V]
	Digital Outpu	ıt	RAD	WAD	2 / 4	00000	Hold Previous Value
	at Alarm		KAD	WAD	3/4	00001	Fixed Value
	Alarm Outpu	t	RAC	WAC	3/4	00000	OFF
	Delay		NAC	WAC	3/4	00001	ON

<sup>\*1</sup> Subdata section consists of 5 digits (zero suppress is omitted) indicated by decimal.

	Item	Com	mand	Code	Subdata*1	Setting value
					00000	6 Decimal Places
	Digit Number of				00001	5 Decimal Places
		RKT	WKT	3/4	00002	4 Decimal Places
	Measurement Value	KNI	WKI	3/4	00003	3 Decimal Places
					00004	2 Decimal Places
					00005	1 Decimal Places
	Measurement Value Read	RMD	1	3/4	-	-999.999999 to +999.999999 [mm]
					00000	Alarm OFF
					00001	Measurement Alarm
P	Alarm Output Read	ROA	-	3/4	00005	Sensor head A unconnected
0					00006	Connection head unadapted
					00007	Head connection check error
	Strobe Output Read	ROB		3/4	00000	Strobe OFF
	Silobe Output Read	KUB	-		00001	Strobe ON
	Judgment Output HI	RHI	-	3/4	00000	Judgment Output HI OFF
	Read				00001	Judgment Output HI ON
	Judgment Output GO	RGO	-	3/4	00000	Judgment Output GO OFF
	Read				00001	Judgment Output GO ON
	Judgment Output LO	RLO	-	3/4	00000	Judgment Output LO OFF
	Read				00001	Judgment Output LO ON
					00000	10 [μs]
					00001	20 [μs]
					00002	40 [μs]
	Sampling Cycle	RSP	WSP	5	00003	100 [μs]
	Sampling Cycle	1101	WOI	3	00004	200 [μs]
non					00005	400 [μs]
Common					00006	1000 [μs]
ပိ					00007	2000 [μs]
	Terminal Input	RIM	WIM	5	00000	Independent
	Control	AXIIVI	VVIIVI	3	00001	All
	Chattering				00000	OFF
	Prevention for	RIC	WIC	5	00001	ON1
	Terminal Input				00002	ON2

<sup>\*1</sup> Subdata section consists of 5 digits (zero suppress is omitted) indicated by decimal.

	Item	Com	mand	Code	Subdata*1	Setting value
item				-	00000	OFF
					00001	2ms
	Judgment Output	ROF	WOF	5	00002	10ms
	Off Delay				00003	100ms
					00004	Hold
	Interference				00000	OFF
	Prevention	RXT	WXT	5	00001	ON
_	2 Outputs Measurement Value Read	RMA	-	5	1	-999.999999 to +999.999999 [mm]
Common	All Outputs Read	RMB	-	5	-	One Time Read Output 1: Measurement value Strobe Output Judgment HI Output Judgment GO Output Judgment LO Output Reserve Output Alarm Output Output 2: Measurement value Strobe Output Judgment HI Output Judgment GO Output Judgment LO Output Reserve Output Alarm Output Alarm Output
	0 + 4 9 44;				00000	None
	Output Setting Copy	-	WOC	0	00001	Copy Output 1 to Output 2.
	Сору				00002	Copy Output 2 to Output 1.
	Priority Setting of	RYU	WYU	0	00000	Command
	Memory Change	KIU	WYU	U	00001	Terminal
	Memory Change	RMC	WMC	0	00000 to 00015	Memory No.
System	Copy Source No.	-	WSF	0	00000 to 00015	Memory No.
	Copy Destination	1	WDF	0	00000 to 00015	Memory No.
	M G		WOE	0	00000	None
	Memory Copy	-	WCF	0	00001	Execute
					00000	None
	Initialization	-	WIN	0	00001	Initialize Selected Memory
					00002	Initialize All Memory
1.0	wholata agatian agn	.:	. 6 5 1:	-ita (		omitted) indicated by decimal

<sup>\*1</sup> Subdata section consists of 5 digits (zero suppress is omitted) indicated by decimal.

	Item	Com	mand	Code	Subdata*1	Setting value
	C		14/14/5	0	00000	None
	Save	-	WWR	U	00001	Save All Memory
					00000	9600[bps]
	RS-232C	DO 4	\A/O A	0	00001	19200[bps]
	Baud Rate	RSA	WSA	0	00002	38400[bps]
					00003	115200[bps]
	RS-232C	DOD	WOD	0	00000	7-bit
	Data Length	RSB	WSB	0	00001	8-bit
					00000	Even
	RS-232C Parity Check	RSC	WSC	0	00001	Odd
	Parity Check				00002	None
					00000	Handshake
	RS-232C	RSD	WSD	0	00001	Timing
	Output Mode				00002	Continuous
					00000	OUT1&OUT2
	RS-232C	RSE	WSE	0	00001	OUT1 only
	Output Type				00002	OUT2 only
	Display Update	RKS	WKS	0	00000	Fast
	Display Update Cycle of Measurement Value Change Indication				00001	Standard
Ε					00002	Slow
ste					00003	Very Slow
S	Change Indication	RUT	WUT	0	00000	mm Unit
	Unit	RUI	WUI	U	00001	μm Unit
					00000	OUT1 Display
					00001	OUT1 Operation
					00002	OUT2 Display
					00003	OUT2 Operation
					00004	OUT1&2 Display
					00005	Waveform(A)
					00006	Waveform(B)
	Console	DVC	WKG	0	00007	Тор
	Start-up Screen	KNG	WNG	U	80000	Setting
					00009	Head A Menu
					00010	Head B Menu
					00011	OUT1 Menu
					00012	OUT2 Menu
					00013	Common Menu
					00014	System Menu
					00015	Measurement Value Menu
	Console	RPL	WPL	0	00000	OFF
	Panel Lock	KPL	WPL	U	00001	ON

<sup>\*1</sup> Subdata section consists of 5 digits (zero suppress is omitted) indicated by decimal.

	Item	Com	mand	Code	Subdata*1	Setting value
	G 16 4	RSS	MCC	0	00000	OFF
	Self-stop	KSS	WSS	0	00001	ON
					00000	Continuous
	Buffering	DDD	WDD	_	00001	Trigger
	Mode	RBD	WBD	5	00002	Timing
					00003	Sample Trigger
					00000	OUT1 & 2
	Buffering	RTT	WTT	5	00001	OUT1
	Type				00002	OUT2
					00000	1
					00001	1/2
					00002	1/4
					00003	1/8
					00004	1/16
					00005	1/32
					00006	1/64
	Buffering		WBR	5	00007	1/128
	Rate	RBR	WBK	5	00008	1/256
					00009	1/512
_					00010	1/1024
ing					00011	1/2048
Buffering					00012	1/4096
3uf					00013	1/8192
_					00014	1/16384
					00015	1/32768
	Accumulated Amount	RBC	WBC	5	-	1 to Max. Accumulated Amount
					00000	At timing input ON
					00001	At HI
					00002	At LO
	. ·				00003	At HI or LO
	Trigger Conditions	RTR	WTR	3/4	00004	When HI turns to GO
	Conditions				00005	When LO turns to GO
					00006	When HI or LO to GO
					00007	At an alarm occurred
					00008	At an alarm released
	Trigger Delay	RTL	WTL	5	-	+0000000000 to +0100000000
	Trigger Point	RTP	WTP	5	-	1 to Accumulated amount
	Sample Trigger Accumulation Amount	RSR	WSR	5	-	1 to Accumulated amount
	Buffering	RBS	WBS	0	00000	Stop
	Operation	KDO	WDS	0	00001	Start

<sup>\*1</sup> Subdata section consists of 5 digits (zero suppress is omitted) indicated by decimal.

	Item		mand	Code	Subdata <sup>*1</sup>	Setting value
					00000	Non-buffering
	Status	RTS	_	3/4	00001	Wait for Trigger
	Readout	KIS	-	3/4	00002	Accumulating
					00003	Accumulation Completed
	Final data point	RLD	1	3/4	-	Read One Time
Buffering	Data Read (Normal)	RLA	-	3/4	-	5-character head point + 5-characterend point Data point within the range from the head data point to the end data point is specified.
	Data Read (Rapid)	RLB	1	3/4	-	5-character head point + 5-characterend point Data point within the range from the head data point to the end data point is specified.
	Trigger Counter Readout	RLE	-	3/4	-	0 to end data point

<sup>\*1</sup> Subdata section consists of 5 digits (zero suppress is omitted) indicated by decimal.

## 5-2 USB Communication Control

HL-C2 can be controlled through the external host device (personal computer) through USB interface by using the API function. → Refer to "HL-C2 Series USER'S MANUAL USB Communication Control" in "our web site: https://panasonic.net/id/pidsx/global" (PDF data) for the details.

#### USB driver

USB driver should be installed to the external control device (personal computer) in order to control HL-C2 by external control device (personal computer).

You can download the USB driver from our Website.

→ Refer to "1-2 Installation of USB Driver" in "HL-C2 Series USER'S MANUAL USB Communication Control" for the installing method of USB driver.

#### API file

API (Application Program Interface) is provided to easily control HL-C2 by the external control device. API is provided in DLL format.

Please feel free to ask our salesman how to obtain a DLL file.

Please contact the vendor of development environment for the use of DLL.

Refer to "Chapter 2 API Function Specification" in "HL-C2 Series

USER'S MANUAL USB Communication Control" for the use of API.

## ■ Operating Environment

The following operating environments are required to use HL-C2.

Operating environment					
os	Microsoft Windows® 7 Professional 32bit/64bit Microsoft Windows® 8.1 Pro 32bit/64bit Microsoft Windows® 10 Professional 32bit/64bit (Japanese, English, Chinese, Korean)				
CPU	1GHz or more processor*1				
Memory	2GB or more*1				
USB Port	USB 2.0 Full Speed (USB 1.1 compatible) compliant				

<sup>\*1</sup> It depends on the operation environment of OS.

## ■ Change RS-232C Communication Conditions

After changing the settings of communication conditions on baud rate, data length or parity check by API, make sure to save the new setting values and then restart the controller to reflect them.

#### Sample program

Sample program for USB control, which was created using API, is provided. We offer Sample program, which are for Visual Basic and Visual C++.

<sup>\*</sup>Windows is a registered trademark of Microsoft Corporation in the United States and other countries.

## 5-3 Ethernet Communication Control


The HL-C21C makes it possible to read a variety of settings and measured values over Ethernet communication. → Refer to "HL-C2 Series USER'S MANUAL Ethernet Communication Control" in "our web site: https://panasonic.net/id/pidsx/global" (PDF data) for the details.

## ■ Specifications of Ethernet Block


Interface		RJ45		
	Baud rate	10BASE-T / 100BASE-TX		
Transmission specifications	Imathad	Baseband		
	Max. segment length	100m		
Support comm	nand	MEWTOCOL (Master) iQSS-supporting MC protocol communication (Sensor slave node) MC protocol (Master)		
Support tool		Configurator WD (Ver. 1.62 or later)		

<sup>\*</sup>MEWTOCOL: Supports MEWTOCOL-COM communication.

<sup>\*</sup>MC protocol: Used to write data from the HL-C21C to memories of PLCs manufactured by Mitsubishi Electric Corp. This protocol supports QnA-compatible 3E frame commands.



<sup>\*</sup>iQSS supporting: An iQ Sensor solution of Mitsubishi Electric Corp.



# Maintenance and Inspection

3-1	Maintenance ······	6-2
3_2	Inspection	6-2

## 6-1 Maintenance

#### Maintenance Instructions

- · Before cleaning the unit, be sure to turn off the power and stop laser emission.
- · Molded resin is used in some parts of the unit. Do not use organic solvents such as thinner or benzene to wipe dirt on it.
- Do not wipe the glass portion of laser aperture too hard. Scratches on the glass may cause measurement errors.

#### (1) Cleaning of light emitter/receiver on the front surface of sensor head

- · Measurement error may occur if oil, fingerprints, or other substances that refract light exists on the light emitting or receiving surface at the sensor head. Inspect the surfaces regularly and always keep them clean.
- · To remove large particles of dust, blow them away using a camera lens blower.
- To remove small particles of dust or fingerprints, use soft lens cleaning cloth or lens cleaner paper to lightly wipe them out.
- Use cloth moistened with a small amount of alcohol to wipe out tough dirt carefully.

#### (2) Cleaning of other components


• To remove dirt on the controller or compact programmable display, lightly wipe it away with clean, soft cloth.

## 6-2 Inspection

Inspect the sensor unit regularly to ensure performance and to use it under optimum conditions.

### ■ Major Inspection Items

- · Check that I/O terminal connections are not loose or disconnected.
- · Check that the glass surface on the laser aperture is free from dust, dirt or fingerprints.
- Check that the power supply voltage is within the rated range (21.6 to 26.4VDC).
- · Check that the ambient temperature during use is within the specification (sensor head: 0 to +45°C, controller: 0 to +50°C)
- · Check that ambient humidity during use is within the range of 35 to 85%RH.



# Troubleshooting

This chapter explains corrective actions against abnormal state.

Read this chapter if failures are suspected.

7-1 Corrective Actions ······ 7	-2
7-2 Lock ······ 7	-7
7-3 Initialization ······· 7	-7

## 7-1 Corrective Actions

In case an error or trouble occurs during use of the system or a system failure is suspected, read this chapter carefully first and carry out the corresponding corrective actions.

#### Trouble type

(SET) Troubles in the settings of controller

COM Troubles in communication control

MEAS Troubles in measurement method or display of measurement value

[LED] Troubles in LED indication of alarms and errors

TERM Troubles in external terminal I/O

LASER Troubles in laser emission

#### **OCHECK**

- Refer to "4-1 Data Flow", too for the problems related to measurement data processing.
- · Refer to **→** "4-4-1 Alarm Setting and Outputs", too for the problems related to alarms.
- · Refer to "4-4-2 When Output Data become Unfixed", too for the details of conditions where measurement value is unfixed.

Туре	Problem	Cause	Corrective action	Ref. page
	The display on the compact programmable display does not change.	Connecting cable is not connected properly.	Check the <b>connection</b> between controller and cable.	1-2
	The touch key on the compact programmable display does not operate.  ERFF is displayed at the upper right of the compact programmable display screen. Sensor head indicator does not light up. The controller does not operate.	Connecting cable is disconnected.	Check the <b>wiring</b> between controller and cable.	1-14
SET		Power is not supplied to the controller.	Check the <b>connection</b> of controller and <b>external power</b> 24V DC.	1-15
		Controller operation is stopped.	Turn on the power of controller again.	3-6
SET	It takes too long until the controller starts or laser is emitted.	Usually about 25 to 30 seconds are required.	Wait for 40 seconds or more after power-on.	3-6
SET	Update cycle of measurement value is too late.	Update cycle of measurement value is not set correctly.	Set the Display Update Cycle of Measurement Value properly.	4-56

7

Туре	Problem	Cause	Corrective action	Ref. page
		Laser Control setting is saved with OFF.	Save the setting of Laser Control with ON.	4-16 4-65
		Laser control terminal is short-circuited.	Open the laser control terminal (LSRA or LSRB).	2-2
(1055)	Laser beam is not	Remote interlock is open.	Short circuit the remote interlock.	23
LASER	emitted.	IL terminal and LSRA/LSRB terminal is disconnected.	Check the wirings of terminal block.	1-16 2-2
		The export controlled sensor head is connected to the export uncontrolled controller.	Connect the export uncontrolled sensor head to the export uncontrolled controller.	24
		Calibration is not set correctly.	Set Calibration correctly.	4-17
	There is a difference	The measurement object is fluctuating or vibrating.	Stop fluctuation or vibration of measurement object.	1-10
MEAS	between actual distance to the measurement object and measurement value.	The measurement object is tilted.	Place the measurement object as perpendicularly as possible.	1-13
		Received light waveform is saturated or insufficient.	Adjust the received light intensity using <b>Emission Adjustment</b> .	4-10
		The refractive index is not correct.	Adjust the reflectance using Refractive Index Calculation.	4-24
	Measurement	Sensor head is not installed correctly.	Install the head correctly. Note that an installation method is different between specular reflection and diffuse reflection.	1-13
MEAS	range is partially output.	Installation mode is wrong.	Set the correct installation mode (Specular Reflection or Diffuse Reflection).	4-7
		Is the measuring range set appropriately?	Set the measuring range appropriately.	4-16
	Correct measurement value is not displayed.	Measurement object is out of the measurement range.	Check the measurement range of sensor head used.	8-22
MEAS		Operation coefficient or offset is not set correctly.	Set Operation coefficient or offset correctly.	4-36 4-37
		Light emitter/receiver is dirt.	Remove the dirt on the <b>light</b> emitter/receiver.	9 1-7

Туре	Problem	Cause	Corrective action	Ref. page
		Moving Average is small.	Increase the number of Moving Average.	4-34
		Measurement mode is not set correctly.	Set the <b>Measurement Mode</b> according to applications or measurement object. Select the optimum mode.	4-8
MEAS	Measurement values vary.	Light emitter/receiver is dirt.	Remove the dirt on the <b>light emitter/receiver</b> on the sensor head.	9 1-7
		Mounting direction of sensor head is wrong.	Check the mounting direction of sensor head.	1-10
		Sensor head or measurement object is tilted.	Check the installation of sensor head and position of measurement object.	1-10
		RS232C cable is disconnected.	Check the cable connection between RS232C cable and connector.	5-2
	RS-232C communication control can not be done. An error is	RS232 cable type is improper.	Use the <b>proper RS232C cable type</b> , straight type or cross type, depending on the settings of personal computer.	5-3 1-2
СОМ		The setting of baud rate or communication specification is improper.	Check the settings of personal computer currently connected and set the correct RS232C communication specifications.	5-2
	transmitted in RS-232C.	Incorrect data format or command is transmitted.	Refer to the <b>error codes</b> and send the data with correct format and command.	5-6 5-8
		Several commands are sent continuously without waiting receiving responses from the controller.	Send the next command after the controller transmits the response to the previous command.	5-5
		USB cable is disconnected.	Connect the USB cable securely.	1-2
	USB communication control can not be done.	USB cable type is improper.	Use the USB2.0 full speed-compliant cable at USB2.0 interface.	8-3
COM		USB driver is not correctly installed.	Correctly install the USB driver. You can download the USB driver from our Website.	1-3
		The personal computer used does not satisfy the operating environment.	Use the personal computer satisfying the operating environment.	5-25

Туре	Problem	Cause	Corrective action	Ref.
		Head is not connected.	The <b>alarm indicator</b> lights up when the head is not connected.	1-2
		Beam emitting spot is out of the measurement range.	Move the measurement object so beam projection spot come within the measurement range to light up or blink the RANGE indicator on the sensor head.	8-22
	Alarm indicator lights up and measurement can not be done.	The reflected beam from the beam emitting spot is blocked.	Move the position of beam projection spot or change the <b>mounting direction of sensor head</b> so the reflected beam should not be blocked.	1-10
		The beam emitting spot is applied to the R portion (curved surface) of the measurement object.	Apply the beam projection spot to the top of R portion or adjust the beam diameter so it comes larger by moving the measurement object back and forth within the measurement range.	1-10
		The reflected beam has directionality because the surface of object is hairline-finished.	Check the mounting direction of sensor head.	1-10
MEAS) (LED)		Extraneous light such as sunlight or light having the same wavelength as that of the laser is entering.	Take measures to prevent the entry of extraneous light, and turn the power back on.	4-86
	output read by RS-232C or USB communication.	External noise is entering.	Take noise prevention measures, and turn the power back on.	4-86
	communication.	Received light intensity is insufficient because the sampling cycle is too short.	Set longer sampling cycle.	4-50
		Received light intensity is saturated because the sampling cycle is too long at specular reflection.	Set shorter <b>sampling cycle</b> or attach the <b>ND filter</b> .	4-50 1-13
		Diffuse Reflection is selected to measure the mirrored surface or transparent object.	Use the sensor head with Specular Reflection installation.	1-13
		The export controlled sensor head is connected to the export uncontrolled controller.	Connect the export uncontrolled sensor head to the export uncontrolled controller.	24

Туре	Problem	Cause	Corrective action	Ref. page
	Measurement range indicator on the sensor head does not light up/blink.	Sensor head is not installed correctly.	Install the head correctly.  The installation method is different between specular reflection and diffuse reflection.	1-13
SET		Installation mode is wrong.	Set the correct installation mode (Specular Reflection or Diffuse Reflection).	4-7
(LED)		Output selection is incorrect.	Check the setting in Output Selection. The measurement range indicator that is not selected in Output Selection is turned off.	4-20
		Is the measuring range set appropriately?	Set the measuring range appropriately.	4-16

Туре	Problem	Cause	Corrective action	Ref. page
MEAS	Alarm indicator lights up and measurement can not be done.	Sampling period is too long and this causes excessive received light intensity beyond the adjustable range.	Set shorter <b>sampling period</b> and reduce the emitted light intensity (enter a smaller number to <b>"Emission Adjustment"</b> ).	4-50 4-10
LED	Measurement range is limited.	Specular reflection component is received during the measurement at diffuse reflection setting.	Adjust the mounting direction of the sensor head or change the tilt of the object so the beam receiver should not receive specular reflection component.	1-10
	Manage Name and La	Wiring on terminal is disconnected.	Check the <b>connection</b> to Terminals from M0 to M3.	1-16 2-3
TERM	Memory No. can not be changed from the terminal.	"Command" is selected in "Priority Setting of Memory Change".	Change the setting of "Priority Setting of Memory Change" to "Terminal".	4-60
MEAS	Others	Sensor head is connected to HEAD B only.	Connect the sensor head to HEAD A when using only one sensor head.	1-2


## **7-2** Lock

- · "Panel Lock" is used for prohibiting the setting change on the compact programmable display to prevent any setting error occurrence due to unintentional operation on the compact programmable display.
- · Set or release panel lock referring to "Panel Lock" (→ page 4-72).
- When this function is set to "ON", any operations except for screen display change and setting off of "Panel Lock" are prohibited. Save function, however, can be executed and the "Panel Lock" is valid at the next system start-up by saving the setting.

## 7-3 Initialization

- · Initialization deletes all settings and returns them to the factory default.
- Refer to "Initialization" ( page 4-66) to initialize the system.
- After initialization, the default settings are not saved. Save the settings referring to "Save" ( > page 4-68) before turning off the system power in order to keep them valid after the next power-on.

#### МЕМО



# Specifications

This chapter describes the specifications of system components (controller and sensor head).

8-1	Controller Specifications	·· 8–2
8-2	Sensor Head Specifications	8–8
8-3	ND Filter Specifications	8-36
8-4	Outside Dimension	8-37
8-5	Characteristics	8-49

## 8-1 Controller Specifications

#### • RS-232C type

Model No.		0.	HL-C2C(E)	HL-C2C(E)-P	
Supply voltage		oltage	24VDC ±10% Including ripple 0.5V (P-P)		
Current consumption		otion	Approx. 500mA at 2 sensor heads connected Approx. 350mA at 1 sensor head connected (Approx. 100mA is additionally required when the compact programmable display is connected.)		
Sa	mpling	g cycle	10μs, 20μs, 40μs, 100μs,	200μs, 400μs, 1ms, 2ms	
An	alog	Voltage <sup>*1</sup>	Voltage output scale: -5 to +5V/F.S (ir Output range during normal status: -1 Output at abnormal status: -10.8V or Resolution: 2mV, Linearity: ±0.05% F. Max. 2mA, output impedance 50Ω, Re	0.0 to +10.0V +10.8V S.	
ou	tput	Current*2	Current output scale: 4 to 20mA/F.S (initial value) Output range during normal status: 2 to 24mA Output at abnormal status: 1mA or 25mA Resolution: 3mA, Linearity ±0.05% F.S. Load impedance: 250Ωmax., Response delay time: Approx. 10μs		
Alarm output		utput	NPN transistor open collector Maximum in-flow current: 100mA Applied voltage: 3 to 30VDC (ALARM output to Common(-)) Residual voltage: 1V or less (at in-flow current of 100mA) Leak current: 0.05mA or less	PNP transistor open collector Maximum out-flow current: 100mA Applied voltage: 3 to 30VDC (ALARM output to +V) Residual voltage: 1V or less (at out-flow current of 100mA) Leak current: 0.05mA or less	
	Outpu	ıt operation	Open when the output is ON	(Light intensity is insufficient).	
	Short ci	rcuit protection	Incorporated (Auto-reset)		
Judgment output (HI, GO, LO)			NPN transistor open collector Maximum in-flow current: 100mA Applied voltage: 3 to 30VDC (Judgment output to Common(-)) Residual voltage: 1V or less (at in-flow current of 100mA) Leak current: 0.05mA or less	PNP transistor open collector Maximum out-flow current: 100mA Applied voltage: 3 to 30VDC (Judgment output to +V) Residual voltage: 1V or less (at out-flow current of 100mA) Leak current: 0.05mA or less	
	Outpu	it operation	Open when the output is ON (output operates).		
	Short ci	rcuit protection	Incorporated	(Auto-reset)	
Strobe output		utput	NPN transistor open collector Maximum in-flow current: 100mA Applied voltage: 3 to 30VDC (Strobe output to Common(-)) Residual voltage: 1V or less (at in-flow current of 100mA) Leak current: 0.05mA or less	PNP transistor open collector Maximum out-flow current: 100mA Applied voltage: 3 to 30VDC (Strobe output to +V) Residual voltage: 1V or less (at out-flow current of 100mA) Leak current: 0.05mA or less	
	Outpu	ıt operation	Open when the output is	ON (data is determined).	
Short circuit protection		rcuit protection	Incorporated	(Auto-reset)	

		HL-C2C(E)	HL-C2C(E)-P	
Remote interlock input		Laser emission is delayed when connected to Common (-). Laser emission stop at open	Laser emission is delayed when connected to IL (+). Laser emission stop at open	
Las	ser control input	Laser emission is stopped when connected to Common (-). Laser is emitted immediately after opened.	Laser emission is stopped when connected to external power (+). Laser is emitted immediately after opened. Applied voltage: 10.8 to 30VDC (Leak current: 0.1mA or less)	
Zei	o set input	Zero set is ON when connected with Common (-). Zero set turns to OFF after continuously connected to Common (-) for one second.	Zero set is ON when connected with external power (+). Zero set turns to OFF after continuously connected to external power (+) for one second. Applied voltage: 10.8 to 30VDC (Leak current: 0.1mA or less)	
Tin	ning input	ON at/during connection to Common (-) (depending on analysis mode)	ON at/during connection to external power (+) (depending on analysis mode) Applied voltage: 10.8 to 30VDC (Leak current: 0.1mA or less)	
Reset input		Reset is done when connected to Common (-).	Reset is done when connected to external power (+). Applied voltage: 10.8 to 30VDC (Leak current: 0.1mA or less)	
Ме	mory change input	Memory is specified when connected to Common (-).	Memory is specified when connected to external power (+). Applied voltage: 10.8 to 30VDC (Leak current: 0.1mA or less)	
RS	-232C interface	Baud rate: 9600, 19200, 38400, 115200bit/s		
US	B interface	USB 2.0 Full-speed (USB 1.1 compatible) compliant		
Cor	nnecting sensor head	Maximum 2 sensor heads with connection compatibility		
Se	tting/data display	Compact programmable display		
	Power	Green LED: ON at power on.		
٦٢	Sensor head A Laser radiation	Green LED: ON during or immediately before laser emission of sensor head A.		
ndicator	Sensor head B Laser radiation	Green LED: ON during or immediately before laser emission of sensor head B.		
ľ	Alarm 1	Red LED: ON when OUT1 can not be measured due to insufficient amount of light		
İ	Alarm 2	Red LED: ON when OUT2 can not be measured due to insufficient amount of light		
Pro	tective structure	IP30		
Ро	llution Degree	2		
Ins	ulation Resistance	20M ohms or more by 500V dc megger (between live parts and enclosure or F.G.)		
Commercial Frequency  Impulse		AC500V for 1min. (between live parts and enclosure or F.G.)		
Die	Impulse	+/- 1000V 1.2/50 µs (between power supply, input/output, and F.G.)		
Vib	ration resistance	Endurance: 10 to 55Hz (cycle: 1 minute), Resistant amplitude of vibration: 0.75mm, in X, Y, and Z directions for 30 minutes		
Sh	ock resistance	196m/s <sup>2</sup> in X, Y, and 2	Z directions for 3 times	
Am	bient temperature	0 to +50°C (No dew condensation or ic	ing allowed) At storage: –20 to +70°C	

	HL-C2C(E)	HL-C2C(E)-P
Ambient humidity	idity 35 to 85%RH	
Ambient Height	2000m or less	
Material	Case: polycarbonate	
Weight	Approx. 450g	
Applicable standards	Conformed to EMC Directive, Attained Korea's S-mark certification	

Measurement conditions are as follows unless otherwise specified; power voltage: 24VDC, ambient temperature:  $20^{\circ}$ C, sampling cycle:  $40\mu s$ , average number of samples: 256 times, measurement center distance, and measurement object: white ceramic.

- \*1 The linearity is F.S.=20V to digital measurement value. Response delay time is the period after update of measurement value.
- \*2 The linearity is F.S.=16mA to digital measurement value. Response delay time is the period after update of measurement value.

## • Ethernet type

Model No.		HL-C21C(E)	HL-C21C(E)-P	
Supply voltage		24VDC ±10% Including ripple 0.5V (P-P)		
Current consumption		Approx. 500mA at 2 sensor heads connected Approx. 350mA at 1 sensor head connected (Approx. 100mA is additionally required when the compact programmable display is connected.)		
Sampli	ing cycle	10μs, 20μs, 40μs, 100μs,	200μs, 400μs, 1ms, 2ms	
Analog	Voltage <sup>*1</sup>	Voltage output scale: -5 to +5V/F.S (initial value) Output range during normal status: -10.0 to +10.0V Output at abnormal status: -10.8V or +10.8V Resolution: 2mV, Linearity: ±0.05% F.S. Max. 2mA, output impedance 50Ω, Response delay time: Approx. 1.5μs/V		
output	Current*2	Current output scale: 4 to 20mA/F.S (initial value) Output range during normal status: 2 to 24mA Output at abnormal status: 1mA or 25mA Resolution: 3mA, Linearity ±0.05% F.S. Load impedance: 250Ωmax., Response delay time: Approx. 10μs		
Alarm output		NPN transistor open collector Maximum in-flow current: 100mA Applied voltage: 3 to 30VDC (ALARM output to Common(-)) Residual voltage: 1V or less (at in-flow current of 100mA) Leak current: 0.05mA or less	PNP transistor open collector Maximum out-flow current: 100mA Applied voltage: 3 to 30VDC (ALARM output to +V) Residual voltage: 1V or less (at out-flow current of 100mA) Leak current: 0.05mA or less	
Out	put operation	Open when the output is ON (Light intensity is insufficient).		
Short	t circuit protection	Incorporated (Auto-reset)		
Judgm (HI, GC	ent output D, LO)	NPN transistor open collector Maximum in-flow current: 100mA Applied voltage: 3 to 30VDC (Judgment output to Common(-)) Residual voltage: 1V or less (at in-flow current of 100mA) Leak current: 0.05mA or less	PNP transistor open collector Maximum out-flow current: 100mA Applied voltage: 3 to 30VDC (Judgment output to +V) Residual voltage: 1V or less (at out-flow current of 100mA) Leak current: 0.05mA or less	
Out	put operation	Open when the output i	is ON(output operates).	
Short	t circuit protection	Incorporated	(Auto-reset)	
Strobe output		NPN transistor open collector Maximum in-flow current: 100mA Applied voltage: 3 to 30VDC (Strobe output to Common(-)) Residual voltage: 1V or less (at in-flow current of 100mA) Leak current: 0.05mA or less	PNP transistor open collector Maximum out-flow current: 100mA Applied voltage: 3 to 30VDC (Strobe output to +V) Residual voltage: 1V or less (at out-flow current of 100mA) Leak current: 0.05mA or less	
Out	put operation	Open when the output is	ON(data is determined).	
Short	t circuit protection	Incorporated	(Auto-reset)	

		HL-C21C(E)	HL-C21C(E)-P	
Remote interlock input		Laser emission is delayed when connected to Common (-). Laser emission stop at open	Laser emission is delayed when connected to IL (+). Laser emission stop at open	
La	ser control input	Laser emission is stopped when connected to Common (-). Laser is emitted immediately after opened.	Laser emission is stopped when connected to external power (+). Laser is emitted immediately after opened. Applied voltage: 10.8 to 30VDC (Leak current: 0.1mA or less)	
Ze	ro set input	Zero set is ON when connected with Common (-). Zero set turns to OFF after continuously connected to Common (-) for one second.	Zero set is ON when connected with external power (+). Zero set turns to OFF after continuously connected to external power (+) for one second. Applied voltage: 10.8 to 30VDC (Leak current: 0.1mA or less)	
Tir	ning input	ON at/during connection to Common (-) (depending on analysis mode)	ON at/during connection to external power (+) (depending on analysis mode) Applied voltage: 10.8 to 30VDC (Leak current: 0.1mA or less)	
Reset input		Reset is done when connected to Common (-).	Reset is done when connected to external power (+). Applied voltage: 10.8 to 30VDC (Leak current: 0.1mA or less)	
Me	emory change input	Memory is specified when connected to Common (-).	Memory is specified when connected to external power (+). Applied voltage: 10.8 to 30VDC (Leak current: 0.1mA or less)	
Eth	nernet interface	IEEE 802.3u,100BASE-TX/10BASE-T Connector shape: RJ45		
US	B interface	USB 2.0 Full-speed (USB 1.1 compatible) compliant		
Со	nnecting sensor head	Maximum 2 sensor heads with connection compatibility		
Se	tting/data display	Compact programmable display		
	Power	Green LED: ON at power on.		
'n	Sensor head A Laser radiation	Green LED: ON during or immediately before laser emission of sensor head A.		
ndicator	Sensor head B Laser radiation	Green LED: ON during or immediately before laser emission of sensor head B.		
Ľ	Alarm 1	Red LED: ON when OUT1 can not be measured due to insufficient amount of light		
	Alarm 2	Red LED: ON when OUT2 can not be me	easured due to insufficient amount of light	
Pro	otective structure	IP	30	
Ро	llution Degree	2	2	
Insulation Resistance		20M ohms or more by 500V dc megger (between live parts and enclosure or F.G.)		
Commercial Frequency Impulse		AC500V for 1min. (between live parts and enclosure or F.G.)		
Die	Impulse	+/- 1000V 1.2/50 µs (between power supply, input/output, and F.G.)		
Vik	oration resistance	Endurance: 10 to 55Hz (cycle: 1 minute), Resistant amplitude of vibration: 0.75mm, in X, Y, and Z directions for 30 minutes		
Sh	ock resistance	196m/s <sup>2</sup> in X, Y, and Z	directions for 3 times	
An	nbient temperature	0 to +50°C (No dew condensation or icing allowed) At storage: –20 to +70°C		

	HL-C21C(E)	HL-C21C(E)-P
Ambient humidity 35 to 85%RH		5%RH
Ambient Height	2000m or less	
Material	Case: polycarbonate	
Weight	Approx. 450g	
Applicable standards	Conformed to EMC Directive	

Measurement conditions are as follows unless otherwise specified; power voltage: 24VDC, ambient temperature:  $20^{\circ}$ C, sampling cycle:  $40\mu s$ , average number of samples: 256 times, measurement center distance, and measurement object: white ceramic.

- \*1 The linearity is F.S.=20V to digital measurement value. Response delay time is the period after update of measurement value.
- \*2 The linearity is F.S.=16mA to digital measurement value. Response delay time is the period after update of measurement value.

## ■ Sensor Head Model

The model of HL-C2 sensor head is indicated as shown below.

Н	L - C 2				
Measure	ment center distance	$\Box$	T	T	
	8mm type				
01	10mm type				
	15mm type				
03	30mm type				
05	50mm type				
08	85mm type				
11	110mm type				
35	350mm type				

Laser class or FDA

A	Class 1 (JIS/IEC)
В	Class 2 (JIS/IEC)
С	Class 3R (JIS/IEC)
F	FDA-compliant (Class I / II ) *
F5	FDA-compliant (Class IIIa)

\*: FDA is supported by HL-C205  $\Box$  / 208  $\Box$  / 235 CE-W  $\Box$  .

Export control-

None	Pertinent
Е	Non- pertinent (E type)

Spot-

None	Spot type	
-MK	Line spot type	
-SP□	Spot type	
-SP□M	Line spot type	
-W	Wide range spot type	
-WMK	Wide range line spot type	

In "8-2 Sensor Head Specifications", "8-5 Outside Dimension", and "8-6 Characteristics", the type of sensor head is classified by the kind of measurement center distance unless otherwise specified. The model name is therefore partially omitted.

## **■**CHECK in specifications

Measuring conditions are as follows unless otherwise specified; connection with controller, power voltage: 24VDC, ambient temperature: 20°C, sampling cycle: 40µs, average number of samples: 256 times, measurement center distance, measurement object: white ceramic (10mm type is an aluminum vapor deposition surface reflection mirror), and digital measurement value.

# ■List of products which have attained the Korea's S-mark certification

Туре	Model		
10mm type	HL-C201A/HL-C201A-MK HL-C201AE/HL-C201AE-MK		
30mm type	HL-C203B/HL-C203B-MK HL-C203BE/HL-C203BE-MK		
110mm type(Class2)	HL-C211B/HL-C211B-MK HL-C211BE/HL-C211BE-MK		
110mm type(Class3R)	HL-C211C/HL-C211C-MK HL-C211CE/HL-C211CE-MK		
350mm type(Class2)	HL-C235BE/HL-C235BE-MK		
350mm type(Class3R)	HL-C235CE/HL-C235CE-MK		

#### • 10mm type

Model No.		HL-C201A, HL-C201F HL-C201AE, HL-C201FE	HL-C201A-MK, HL-C201F-MK HL-C201AE-MK, HL-C201FE-MK			
Measurement method		Specular reflection				
Measurement center distance		10mm				
Meas	surement range*1	±1mm				
Bear	m source	Red semiconductor laser Class 1 (JIS/IEC/GB/KS) <sup>-2</sup> Max output: 0.1mW, Emission peak wavelength: 658nm				
Bear	m diameter <sup>*3</sup>	Approx. φ20μm	Approx. 20×700μm			
Bean	n receiving element	Linear ima	ge sensor			
Res	olution	0.04μm/average times: 256, 0.01μm/average times: 4096 (E type ' <sup>4</sup> 0.25μm/average times 256)				
Line	arity	±0.02% F.S. (E typ	pe <sup>*4</sup> ±0.025% F.S.)			
	perature acteristics	0.01% F.S./°C (E typ	oe <sup>*4</sup> 0.013% F.S./°C)			
ō	Laser emission	Green LED: ON du	ring laser emission.			
=	Measurement range	Yellow LED: Near measurement center: ON/within measurement range : Blink/Beyond the range: OFF				
Prot	ective structure	IP67 (except connector)				
Pollu	ution Degree	2				
Insul	ation Resistance	20M ohms or more by 500V dc megger (between all the terminals and enclosure.)				
Dielectric Withstand	Commercial Frequency	AC500V for 1min. (between all the terminals and enclosure.)				
Ş Ş Ş	Impulse	+/- 1000V 1.2/50 µs (betw	veen all the terminals and enclosure.)			
Vibra	ation resistance	Endurance: 10 to 55Hz (cycle: 1minute), Resistant amplitude of vibration: 1.5mm in X, Y, and Z directions for 2 hours				
Shoo	ck resistance	196m/ s <sup>2</sup> in X, Y, and Z directions for 3 times				
Amb	ient illuminance	3,000lx or less*5 (illuminance at beam receiving surface using incandescent lamp				
Ambi	ient temperature	0 to +45°C (No dew condensation or icing allowed), At storage: –20 to +70°C				
Amb	ient humidity	35 to 85%RH At storage: 35 to 85%RH				
Amb	ient Height	2000m or less				
Material		Main unit case & cover: aluminum die-cast, Front cover: glass				
Cable length		0.5m				
Cabl	le extension	Extendible to 30m long maximum using the optional extension cable.				
Weight		Approx. 250g including cable weight				
Accessory		Laser warning label: 1 set				
Applicable standards		Conformed to EMC Directive, Attained Korea's S-mark certification <sup>*6</sup>				

For measuring conditions, refer to "8-2 Sensor Head Specifications" - "CHECK in specifications".

- \*1 The measurement range is between +0.1 and +1.0mm (in case the sampling cycle is 20µs), or between +0.8 and +1.0mm (in case the sampling cycle is 10µs).
- \*2 FDA-compliant model is classified into Class I Laser Notice No.50, based on FDA PART1040.
- \*3 The figure shows the value at measurement center distance. It is determined by 1/e² (approximately 13.5%) of center beam intensity. The reflectance around the detecting point may be higher than at the point due to leak light outside the specified area, and this may affect the measurement value.
- \*4 The minimum resolution of 0.25μm, linearity of ±0.025%F.S. and temperature characteristics of 0.013%F.S./°C can be achieved if the sensor head is connected to the controller that is not subject to "Foreign Exchange and Foreign Trade Law".
- \*5 Variance is  $\pm 0.02\%$  F.S. or less depending on the ambient illuminance.
- \*6 For models compliant with standards, refer to "8-2 Sensor Head Specifications" "List of models attained Korea's S-mark certification".

#### • 30mm type

- `	Jonnin type					
Model No.		HL-C203B, HL-203F HL-C203BE, HL-C203FE		HL-C203B-MK, HL-203F-MK HL-C203BE-MK, HL-C203FE-MK		
		Diffuse Reflection	Specular Reflection	Diffuse Reflection	Specular Reflection	
Measurement method <sup>™</sup>		Diffuse reflection/Specular reflection				
	asurement Iter distance	30mm	26.4mm	30mm	26.4mm	
Mea	asurement range <sup>*2</sup>	±5mm	±4.6mm	±5mm	±4.6mm	
Beam source		Red semiconductor laser Class 2 (JIS/IEC/GB/KS) <sup>-3</sup> Max output: 1mW, Emission peak wavelength: 658nm				
Bea	am diameter <sup>*4</sup>	Approx. φ30μm Approx. 30 x 1200μm				
Bea	m receiving element		Linear ima	ige sensor		
Res	solution	0.1μm/ a	average times: 256, 0 (E type <sup>⁵5</sup> 0.25µm/a	0.025µm/average time verage times 256)	es: 4096	
Line	earity		±0.03°	% F.S.		
	nperature iracteristics		0.01%	F.S./°C		
or	Laser emission		Green LED: ON during laser emission.			
Measurement range   Near measurement center: ON/within measurement range : Blink/Beyond t			eyond the range: OFF			
Pro	tective structure	IP67 (except connector)				
Pollution Degree		2				
Insu	ulation Resistance	20M ohms or more by 500V dc megger (between all the terminals and enclosure.)				
Dielectric	Commercial Frequency	AC500V for 1min (between all the terminals and enclosu			nclosure.)	
Commercial Frequency   AC500V for 1min. (between all the terminals and enclosure.)			d enclosure.)			
Vibi	ration resistance	Endurance: 10 to 55Hz (cycle: 1 minute), Resistant amplitude of vibration: 1.5mm, in X, Y, and Z directions for 2 hours				
Sho	ock resistance	196m/ s <sup>2</sup> in X, Y, and Z directions for 3 times				
Am	bient illuminance	3,000lx or less*6 (illuminance at beam receiving surface using incandescent lamp)				
Am	bient temperature	0 to +45°C (No dew condensation or icing allowed), At storage: –20 to +70°C				
Am	bient humidity	35 to 85%RH At storage: 35 to 85%RH				
Ambient Height		2000m or less				
Material		Main unit case & cover: aluminum die-cast, Front cover: glass				
Cable length		0.5m				
Cable extension		Extendible to 30m long maximum using the optional extension cable.				
Weight		Approx. 250g including cable weight				
Accessory		Laser warning label: 1 set				
App	licable standards	Conformed to EMC Directive, Attained Korea's S-mark certification *7				
- ' '			,			

For measuring conditions, refer to "8-2 Sensor Head Specifications" - "CHECK in specifications".

- \*1 Use the external ND filter (optional) in case the amount of reflected beam is too large on Specular Reflection installation.
- \*2 The measurement range is limited between 0 and +5.0mm (in case the sampling cycle is 20µs at diffuse reflection), between 0 and +4.6mm (in case the sampling cycle is 20µs at specular reflection), between +3.8 and +5.0mm (in case the sampling cycle is 10µs at diffuse reflection), or between +3.6 and +4.6mm(in case the sampling cycle is 10µs at specular reflection).
- \*3 FDA-compliant model is classified into Class II, based on FDA PART1040.
- \*4 The figure shows the value at measurement center distance. It is determined by 1/e² (approximately 13.5%) of center beam intensity. The reflectance around the detecting point may be higher than at the point due to leak light outside the specified area, and this may affect the measurement value.
- \*5 The minimum resolution is 0.25µm while the sensor head is connected to the controller that is not subject to "Foreign Exchange and Foreign Trade Law".
- \*6 Variance is  $\pm 0.03\%$  F.S. or less depending on the ambient illuminance.
- \*7 For models compliant with standards, refer to "8-2 Sensor Head Specifications" "List of models attained Korea's S-mark certification".

## • 50mm type (Class2)

	John type (C					
Model No.		HL-C205B,			HL-C205BE-MK	
		Diffuse Reflection	Specular Reflection	Diffuse Reflection	Specular Reflection	
Measurement method*1		Diffuse reflection/Specular reflection				
Measurement center distance		50mm	46mm	50mm	46mm	
Mea	asurement range <sup>*2</sup>		±5r	mm		
Bea	am source	Red semiconductor laser Class 2 (JIS/IEC/GB/KS/FDA) Max output: 1mW, Emission peak wavelength: 658nm				
Bea	am diameter <sup>*3</sup>	Approx. φ70μm Approx. 70 x 1000μm			) x 1000μm	
Bea	ım receiving element		Linear ima	ige sensor		
Res	solution	0.2μm/	average times: 256, (E type*4 0.25µm/a	0.05µm/average time verage times 256)	es: 4096	
Line	earity		±0.03	% F.S.		
	nperature aracteristics		0.01%	F.S./°C		
or	Laser emission	Green LED: ON during laser emission.				
Indicator	Measurement range	Yellow LED: Near measurement center: ON/within measurement range : Blink/Beyond the range: OFF				
Pro	tective structure	IP67 (except connector)				
Pol	lution Degree	2				
Insu	ulation Resistance	20M ohms or more by 500V dc megger (between all the terminals and enclosure.)				
Dielectric	Commercial Frequency Impulse	AC500V	AC500V for 1min. (between all the terminals and enclosure.)			
Die	Impulse	+/- 1000V 1.2/50 $\mu s$ (between all the terminals and enclosure.)				
Vibi	ration resistance	Endurance: 10 to 55Hz (cycle: 1 minute), Resistant amplitude of vibration: 1.5mm, in X, Y, and Z directions for 2 hours				
Sho	ock resistance	196m/ s <sup>2</sup> in X, Y, and Z directions for 3 times				
Am	bient illuminance	3,000lx or less*5 (illuminance at beam receiving surface using incandescent lamp)				
Am	bient temperature	0 to +45°C (No dew condensation or icing allowed), At storage: -20 to +70°C				
Am	bient humidity	35 to 85%RH At storage: 35 to 85%RH				
Am	bient Height	2000m or less				
Material		Main unit case & cover: aluminum die-cast, Front cover: glass				
Cable length		0.5m				
Cable extension		Extendible to 30m long maximum using the optional extension cable.				
Weight		Approx. 300g including cable weight				
Accessory		Laser warning label: 1 set				
Applicable standards		Conformed to EMC Directive				
-						

For measuring conditions, refer to "8-2 Sensor Head Specifications" - "CHECK in specifications".

- \*1 Use the external ND filter (optional) in case the amount of reflected beam is too large on Specular Reflection installation.
- \*2 The measurement range is limited between +0.5 and +5.0mm (in case the sampling cycle is 20μs at diffuse reflection), between +0.5 and +5.0mm (in case the sampling cycle is 20μs at specular reflection), between +4.7 and +5.0mm (in case the sampling cycle is 10μs at diffuse reflection), or between +4.6 and +5.0mm(in case the sampling cycle is 10μs at specular reflection).
- \*3 The figure shows the value at measurement center distance. It is determined by 1/e² (approximately 13.5%) of center beam intensity. The reflectance around the detecting point may be higher than at the point due to leak light outside the specified area, and this may affect the measurement value.
- \*4 The minimum resolution is 0.25µm while the sensor head is connected to the controller that is not subject to "Foreign Exchange and Foreign Trade Law".
- \*5 Variance is  $\pm 0.03\%$  F.S. or less depending on the ambient illuminance.

• 50mm type (Class3R)

• .	• 50mm type (Class3R)						
Model No.		HL-C205C, HL-C205CE		HL-C205C-MK, HL-C205CE-MK			
		Diffuse Reflection	Specular Reflection	Diffuse Reflection	Specular Reflection		
Measurement method*1		Diffuse reflection/Specular reflection					
Measurement center distance		50mm	46mm	50mm	46mm		
Mea	surement range <sup>*2</sup>		±5r	mm			
Beam source		Red semiconductor laser Class 3R (JIS/IEC/GB/KS/FDA) Max output: 5mW, Emission peak wavelength: 658nm					
Bea	ım diameter <sup>*3</sup>	Approx. φ70μm Approx. 70 x 1000μm					
Bear	m receiving element		Linear ima	ige sensor			
Res	solution	0.2μm/	average times: 256, (E type*4 0.25µm/a	0.05µm/average time verage times 256)	es: 4096		
Line	earity		±0.03	% F.S.			
	nperature racteristics		0.01%	F.S./°C			
or	Laser emission	Green LED: ON during laser emission.					
Measurement range		Yellow LED: Near measurement center: ON/within measurement range : Blink/Beyond the range: OFF					
Pro	tective structure	IP67 (except connector)					
Pollution Degree		2					
Insu	lation Resistance	20M ohms or more by 500V dc megger (between all the terminals and enclosure.)					
Commercial Frequency Impulse		AC500V for 1min. (between all the terminals and enclosure.)					
E E	Impulse	+/- 1000V 1.2/50 μs (between all the terminals and enclosure.)					
Vibr	ation resistance	Endurance: 10 to 55Hz (cycle: 1 minute), Resistant amplitude of vibration: 1.5mm, in X, Y, and Z directions for 2 hours					
Sho	ck resistance	196m/ s <sup>2</sup> in X, Y, and Z directions for 3 times					
Aml	pient illuminance	3,000lx or less*5 (illuminance at beam receiving surface using incandescent lamp)					
Amb	pient temperature	0 to +45°C (No dew condensation or icing allowed), At storage: –20 to +70°C					
Aml	bient humidity	35 to 85%RH At storage: 35 to 85%RH					
Aml	bient Height	2000m or less					
Material		Main unit case & cover: aluminum die-cast, Front cover: glass					
Cable length		0.5m					
Cable extension		Extendible to 30m long maximum using the optional extension cable.					
Weight		Approx. 300g including cable weight					
Accessory		Laser warning label: 1 set					
Applicable standards		Conformed to EMC Directive					
- ' '							

For measuring conditions, refer to "8-2 Sensor Head Specifications" - "CHECK in specifications"...

- \*1 Use the external ND filter (optional) in case the amount of reflected beam is too large on Specular Reflection installation.
- \*2 The measurement range is limited between +0.5 and +5.0mm (in case the sampling cycle is 20μs at diffuse reflection), between +0.5 and +5.0mm (in case the sampling cycle is 20μs at specular reflection), between +4.7 and +5.0mm (in case the sampling cycle is 10μs at diffuse reflection), or between +4.6 and +5.0mm(in case the sampling cycle is 10μs at specular reflection).
- \*3 The figure shows the value at measurement center distance. It is determined by 1/e² (approximately 13.5%) of center beam intensity. The reflectance around the detecting point may be higher than at the point due to leak light outside the specified area, and this may affect the measurement value.
- \*4 The minimum resolution is 0.25µm while the sensor head is connected to the controller that is not subject to "Foreign Exchange and Foreign Trade Law".
- \*5 Variance is  $\pm 0.03\%$  F.S. or less depending on the ambient illuminance.

## • 85mm type (Class2)

• obtain type (class2)						
Мо	del No.	HL-C208B, HL-C208BE HL-C208B-MK, HL-C208B				
		Diffuse Reflection	Specular Reflection	Diffuse Reflection	Specular Reflection	
Measurement method*1		Diffuse reflection/Specular reflection				
	asurement ter distance	85mm	81.4mm	85mm	81.4mm	
Mea	asurement range <sup>*2</sup>	±20mm	±6mm	±20mm	±6mm	
Bea	am source	Red se Max o	emiconductor laser Cl output: 1mW, Emissio	ass 2 (JIS/IEC/GB/K n peak wavelength: 6	S/FDA) 358nm	
Bea	am diameter <sup>*3</sup>	Approx.	φ100μm	Approx. 10	0 x 1200µm	
Bea	m receiving element		Linear ima	age sensor		
Res	solution		average times: 256, µm/average times 25			
Line	earity	±0.03% F.S.	±0.1% F.S.	±0.03% F.S.	±0.1% F.S.	
	nperature racteristics		0.01%	F.S./°C		
or	Laser emission		Green LED: ON du	ring laser emission.		
Indicator	Measurement range	Yellow LED: Near measurement center: ON/within measurement range : Blink/Beyond the range: OFF				
Pro	tective structure	IP67 (except connector)				
Pol	lution Degree	2				
Insu	lation Resistance	20M ohms or more by 500V dc megger (between all the terminals and enclosure.)				
Dielectric State S		AC500V for 1min. (between all the terminals and enclosure.)				
Die	Impulse	+/- 1000\	/ 1.2/50 μs (between	n all the terminals and	all the terminals and enclosure.)	
Vibi	ration resistance	Endurance: 10 to 55Hz (cycle: 1 minute), Resistant amplitude of vibration: 1.5mm, in X, Y, and Z directions for 2 hours				
Sho	ock resistance	196m/ s <sup>2</sup> in X, Y, and Z directions for 3 times				
Am	bient illuminance	3,000lx or less*5 (illuminance at beam receiving surface using incandescent lamp)				
Am	oient temperature	0 to +45°C (No dew condensation or icing allowed), At storage: -20 to +70°C				
Am	bient humidity	35 to 85%RH At storage: 35 to 85%RH				
Am	bient Height	2000m or less				
Ma	terial	Main unit case & cover: aluminum die-cast, Front cover: glass				
Cable length		0.5m				
Cal	ole extension	Extendible to 30m long maximum using the optional extension cable.				
We	ight	Approx. 300g including cable weight				
Acc	essory	Laser warning label: 1 set				
App	licable standards	Conformed to EMC Directive				
, ppilotolo otal latil do		<u> </u>				

For measuring conditions, refer to "8-2 Sensor Head Specifications" - "CHECK in specifications".

- \*1 Use the external ND filter (optional) in case the amount of reflected beam is too large on Specular Reflection installation.
- \*2 The measurement range is limited between 0 and +20mm (in case the sampling cycle is 20µs at diffuse reflection), between 0 and +6mm (in case the sampling cycle is 20µs at specular reflection), between +18 and +20mm (in case the sampling cycle is 10µs at diffuse reflection), or unmeasurable (in case the sampling cycle is 10µs at specular reflection).
- \*3 The figure shows the value at measurement center distance. It is determined by 1/e² (approximately 13.5%) of center beam intensity. The reflectance around the detecting point may be higher than at the point due to leak light outside the specified area, and this may affect the measurement value.
- \*4 The minimum resolution is 0.25µm while the sensor head is connected to the controller that is not subject to "Foreign Exchange and Foreign Trade Law".
- \*5 Variance is  $\pm 0.03\%$  F.S. or less depending on the ambient illuminance.

• 85mm type (Class3R)

	• obinin type (Classon)				
Мо	del No.	HL-C208C, HL-C208CE HL-C208C-MK, HL-C			
		Diffuse Reflection	Specular Reflection	Diffuse Reflection	Specular Reflection
Mea	surement method*1	Diffuse reflection/Specular reflection			T
	asurement ter distance	85mm	81.4mm	85mm	81.4mm
Mea	surement range <sup>*2</sup>	±20mm	±6mm	±20mm	±6mm
Bea	m source	Red ser Max o	miconductor laser Cla output: 5mW, Emissio	ass 3R (JIS/IEC/GB/k n peak wavelength: 6	(S/FDA) 658nm
Bea	ım diameter <sup>*3</sup>	Approx.	φ100μm	Approx. 10	0 x 1200µm
Bea	m receiving element		Linear ima	age sensor	
Res	solution		average times: 256, µm/average times 25		
Line	earity	±0.03% F.S.	±0.1% F.S.	±0.03% F.S.	±0.1% F.S.
	nperature racteristics		0.01%	F.S./°C	
ō	Laser emission		Green LED: ON du	ring laser emission.	
Measurement range  Near measurement center: ON/within measurement range : Blink/Beyond		eyond the range: OFF			
Pro	tective structure	IP67 (except connector)			
Pol	ution Degree	2			
Insu	lation Resistance	20M ohms or more by 500V dc megger (between all the terminals and enclosure.)			
Dielectric	Commercial Frequency	AC500V	for 1min. (between al	l the terminals and e	nclosure.)
Die!	Impulse	+/- 1000V 1.2/50 µs (between all the terminals and enclosure.)			d enclosure.)
Vibr	ation resistance	Endurance: 10 to 55Hz (cycle: 1 minute), Resistant amplitude of vibration: 1.5mm, in X, Y, and Z directions for 2 hours			
Sho	ck resistance	196m/ s² in X, Y, and Z directions for 3 times			
Am	oient illuminance	3,000lx or less*5 (illuminance at beam receiving surface using incandescent lamp)			
Aml	pient temperature	0 to +45°C (No dew condensation or icing allowed), At storage: -20 to +70°C			
Am	bient humidity	35 to 85%RH At storage: 35 to 85%RH			
Ambient Height		2000m or less			
Material		Main unit case & cover: aluminum die-cast, Front cover: glass			
Cable length		0.5m			
Cal	le extension	Extendible to 30m long maximum using the optional extension cable.			
We	ght	Approx. 300g including cable weight			
Acc	essory	Laser warning label: 1 set			
App	licable standards	Conformed to EMC Directive			
_					

For measuring conditions, refer to "8-2 Sensor Head Specifications" - "CHECK in specifications"...

- \*1 Use the external ND filter (optional) in case the amount of reflected beam is too large on Specular Reflection installation.
- \*2 The measurement range is limited between 0 and +20mm (in case the sampling cycle is 20µs at diffuse reflection), between 0 and +6mm (in case the sampling cycle is 20µs at specular reflection), between +18 and +20mm (in case the sampling cycle is 10µs at diffuse reflection), or unmeasurable (in case the sampling cycle is 10µs at specular reflection).
- \*3 The figure shows the value at measurement center distance. It is determined by 1/e² (approximately 13.5%) of center beam intensity. The reflectance around the detecting point may be higher than at the point due to leak light outside the specified area, and this may affect the measurement value.
- \*4 The minimum resolution is 0.25μm while the sensor head is connected to the controller that is not subject to "Foreign Exchange and Foreign Trade Law".
- \*5 Variance is  $\pm 0.03\%$  F.S. or less depending on the ambient illuminance.

## • 110mm type (Class2\*3)

	• Homin type (Classz )				
Mod	del No.	HL-C211B HL-C211BE,	3, HL-211F HL-C211FE		K, HL-211F-MK HL-C211FE-MK
		Diffuse Reflection	Specular Reflection	Diffuse Reflection	Specular Reflection
Mea	asurement method*1	Diffuse reflection/Specular reflection			
	asurement ter distance	110mm	106.7mm	110mm	106.7mm
Mea	asurement range <sup>*2</sup>	±15mm	±14.5mm	±15mm	±14.5mm
Bea	am source	Red Max o	semiconductor laser output: 1mW, Emissio	Class 2 (JIS/IEC/GB/ n peak wavelength: 6	KS) <sup>°3</sup> 858nm
Bea	am diameter <sup>*4</sup>	Approx.	φ80μm	Approx. 80	) x 1700µm
Bea	m receiving element		Linear ima	ige sensor	
Res	solution	0.4µm/	<sup>/</sup> average times: 256, (E type <sup>*5</sup> 0.25µm/av	0.1µm/average times verage times 4096)	s: 4096
Line	earity		±0.03°	% F.S.	
	nperature racteristics		0.01%	F.S./°C	
or	Laser emission		Green LED: ON du	ring laser emission.	
Indicator	Measurement range	Yellow LED: Near measurement center: ON/within measurement range : Blink/Beyond the range: C			eyond the range: OFF
Pro	tective structure	IP67 (except connector)			
Pol	lution Degree	2			
Insu	lation Resistance	20M ohms or more	by 500V dc megger (I	between all the termi	nals and enclosure.)
Commercial Frequency   AC500V for 1min. (between all the terminals and 1000   1.2/50 µs (between all the terminals and 1000   1.2/50 µs (between all the terminals   1.2/50 µs		I the terminals and e	nclosure.)		
Diel	Impulse	+/- 1000V 1.2/50 µs (between all the terminals and enclosure.)			
Vibr	ration resistance	Endurance: 10 to 55Hz (cycle: 1 minute), Resistant amplitude of vibration: 1.5mm, in X, Y, and Z directions for 2 hours			
Sho	ock resistance	196m/ s <sup>2</sup> in X, Y, and Z directions for 3 times			
Am	bient illuminance	3,000lx or less*6 (illuminance at beam receiving surface using incandescent lamp)			
Aml	pient temperature	0 to +45°C (No dew condensation or icing allowed), At storage: -20 to +70°C			
Am	bient humidity	35 to 85%RH At storage: 35 to 85%RH			
Ambient Height		2000m or less			
Material		Main unit case & cover: aluminum die-cast, Front cover: glass			
Cable length		0.5m			
Cal	ole extension	Extendible to 30m long maximum using the optional extension cable.			
We	ight	Approx. 300g including cable weight			
Acc	essory		Laser warnin	g label: 1 set	
Арр	licable standards	Conformed to EMC Directive, Attained Korea's S-mark certification 7			
, ppilotolo otti iddi do					

For measuring conditions, refer to "8-2 Sensor Head Specifications" - "CHECK in specifications".

- \*1 Use the external ND filter (optional) in case the amount of reflected beam is too large on Specular Reflection installation.
- \*2 The measurement range is limited between +0.5 and +15.0mm (in case the sampling cycle is 20μs at diffuse reflection), between +0.5 and +14.5mm (in case the sampling cycle is 20μs at specular reflection), between +12.5 and +15.0mm (in case the sampling cycle is 10μs at diffuse reflection), or between +12.5 and +14.5mm(in case the sampling cycle is 10μs at specular reflection).
- \*3 FDA-compliant model is classified into Class II, based on FDA PART1040.
- \*4 The figure shows the value at measurement center distance. It is determined by 1/e² (approximately 13.5%) of center beam intensity. The reflectance around the detecting point may be higher than at the point due to leak light outside the specified area, and this may affect the measurement value.
- \*5 The minimum resolution is 0.25µm while the sensor head is connected to the controller that is not subject to "Foreign Exchange and Foreign Trade Law".
- \*6 Variance is  $\pm 0.03\%$  F.S. or less depending on the ambient illuminance.
- \*7 For models compliant with standards, refer to "8-2 Sensor Head Specifications" "List of models attained Korea's S-mark certification".

## • 110mm type (Class3R\*3)

	Tollilli type (	,			
Mod	del No.	HL-C211C, HL-211F5 HL-C211CE, HL-C211F5E		HL-C211C-MK, HL-211F5-MK HL-C211CE-MK, HL-C211F5E-MK	
		Diffuse Reflection	Specular Reflection	Diffuse Reflection	Specular Reflection
Mea	surement method*1		Diffuse reflection/S	Specular reflection	
	asurement ter distance	110mm	106.7mm	110mm	106.7mm
Mea	asurement range <sup>*2</sup>	±15mm	±14.5mm	±15mm	±14.5mm
Bea	am source	Red s Max o	emiconductor laser Coutput: 5mW, Emissio	Class 3R (JIS/IEC/GB n peak wavelength: 6	/KS) <sup>°³</sup> 858nm
Bea	m diameter*4	Approx.	φ80μm	Approx. 80	) x 1700μm
Bea	m receiving element		Linear ima	ige sensor	
Res	solution	0.4µm/	average times: 256, (E type 5 0.25µm/av	0.1µm/average times /erage times 4096)	s: 4096
Line	earity		±0.03°	% F.S.	
	nperature racteristics		0.01%	F.S./°C	
or	Laser emission	Green LED: ON during laser emission.			
Measurement range Near measurement center: ON/within measurement range : Blink/Beyond		eyond the range: OFF			
Pro	tective structure	IP67 (except connector)			
Poll	ution Degree	2			
Insu	lation Resistance	20M ohms or more by 500V dc megger (between all the terminals and enclosure.)			
Dielectric Withstand	Commercial Frequency	AC500V	for 1min. (between al	I the terminals and e	nclosure.)
AC500V for 1min. (between all the terminals and enclosure Frequency Impulse +/- 1000V 1.2/50 µs (between all the terminals and enclosure Frequency Impulse F		d enclosure.)			
Vibr	ation resistance	Endurance: 10 to 55Hz (cycle: 1 minute), Resistant amplitude of vibration: 1.5mm, in X, Y, and Z directions for 2 hours			
Sho	ock resistance	196m/ s <sup>2</sup> in X, Y, and Z directions for 3 times			
Aml	bient illuminance	3,000lx or less*6 (illuminance at beam receiving surface using incandescent lamp)			
Aml	pient temperature	0 to +45°C (No dew condensation or icing allowed), At storage: -20 to +70°C			
Am	bient humidity	35 to 85%RH At storage: 35 to 85%RH			
Ambient Height		2000m or less			
Mat	erial	Main unit case & cover: aluminum die-cast, Front cover: glass			
Cable length		0.5m			
Cable extension		Extendible to 30m long maximum using the optional extension cable.			
We	ight	Approx. 300g including cable weight			
Acc	essory	Laser warning label: 1 set			
App	licable standards	Conformed to EMC Directive, Attained Korea's S-mark certification <sup>7</sup>			

For measuring conditions, refer to "8-2 Sensor Head Specifications" - "CHECK in specifications"...

- \*1 Use the external ND filter (optional) in case the amount of reflected beam is too large on Specular Reflection installation.
- \*2 The measurement range is limited between +0.5 and +15.0mm (in case the sampling cycle is 20μs at diffuse reflection), between +0.5 and +14.5mm (in case the sampling cycle is 20μs at specular reflection), between +12.5 and +15.0mm (in case the sampling cycle is 10μs at diffuse reflection), or between +12.5 and +14.5mm(in case the sampling cycle is 10μs at specular reflection).
- \*3 FDA-compliant model is classified into Class IIIa, based on FDA PART1040.
- \*4 The figure shows the value at measurement center distance. It is determined by 1/e² (approximately 13.5%) of center beam intensity. The reflectance around the detecting point may be higher than at the point due to leak light outside the specified area, and this may affect the measurement value.
- \*5 The minimum resolution is 0.25µm while the sensor head is connected to the controller that is not subject to "Foreign Exchange and Foreign Trade Law".
- \*6 Variance is  $\pm 0.03\%$  F.S. or less depending on the ambient illuminance.
- \*7 For models compliant with standards, refer to "8-2 Sensor Head Specifications" "List of models attained Korea's S-mark certification".

• 350mm type (Class2)

• 300mm type (Glassz)					EDE MIZ	
Мо	del No.	HL-C235BE  Diffuse Reflection   Specular Reflection		HL-C235BE-MK  Diffuse Reflection   Specular Reflection		
Measurement method*1		Dilluse Reliection			Specular Reflection	
	easurement	Diffuse reflection/Specular reflection				
	nter distance	350mm	348mm	350mm	348mm	
Me	asurement range <sup>*2</sup>	±50mm	±42mm	±50mm	±42mm	
Ве	am source	Red Max	d semiconductor laser output: 1mW, Emissic	Class 2 (JIS/IEC/GE on peak wavelength: (	8/KS) 858nm	
Ве	am diameter <sup>*3</sup>	Approx	. φ250μm	Approx. 25	0 x 3500µm	
Bea	am receiving element		Linear ima	age sensor		
Re	solution	2.0µm	n/ average times: 256,	0.5µm/average time	s: 4096	
Lin	earity		±0.03	% F.S.		
	nperature aracteristics		0.01%	F.S./°C		
or	Laser emission		Green LED: ON du	ıring laser emission.		
Indicator	Measurement range	Near measurement of	Yellov center: ON/within measu	v LED: urement range : Blink/B	eyond the range: OFF	
Pro	otective structure	IP67 (except connector)				
Ро	llution Degree	2				
Insulation Resistance		20M ohms or more by 500V dc megger (between all the terminals and enclosure.)				
Dielectric	Commercial Frequency Impulse	AC500V for 1min (between all the terminals and enclo			nclosure.)	
Diel	Impulse	+/- 1000	V 1.2/50 μs (betwee	n all the terminals an	nd enclosure.)	
Vib	ration resistance	Endurance: 10 to 55Hz (cycle: 1 minute), Resistant amplitude of vibration: 1.5mm, in X, Y, and Z directions for 2 hours				
Sh	ock resistance	196m/ s <sup>2</sup> in X, Y, and Z directions for 3 times				
Am	bient illuminance	3,000lx or less*4 (illuminance at beam receiving surface using incandescent lamp)				
Am	bient temperature	0 to +45°C (No dew condensation or icing allowed), At storage: -20 to +70°C				
Am	bient humidity	35 to 85%RH At storage: 35 to 85%RH				
Am	bient Height	2000m or less				
Ма	terial	Main unit case & cover: aluminum die-cast, Front cover: glass				
Cable length		0.5m				
Ca	ble extension	Extendible to 30m long maximum using the optional extension cable.				
We	eight	Approx. 450g including cable weight				
Su	ited controller *5	Controller ver.2.00 or later				
Ac	cessory	Laser warning label: 1 set				
Ар	plicable standards	Conformed to EMC Directive, Attained Korea's S-mark certification				
	on one of the control					

For measuring conditions, refer to "8-2 Sensor Head Specifications" - "CHECK in specifications".

- \*1 Use the external ND filter (optional) in case the amount of reflected beam is too large on Specular Reflection installation.
- \*2 The measurement range is limited between +0.0 and +50.0mm (in case the sampling cycle is 20μs at diffuse reflection), between +0.0 and +42mm (in case the sampling cycle is 20μs at specular reflection), between +36 and +50mm (in case the sampling cycle is 10μs at diffuse reflection), or between +36 and +42mm (in case the sampling cycle is 10μs at specular reflection).
- \*3 The figure shows the value at measurement center distance. It is determined by 1/e² (approximately 13.5%) of center beam intensity. The reflectance around the detecting point may be higher than at the point due to leak light outside the specified area, and this may affect the measurement value.
- \*4 Variance is  $\pm 0.03\%$  F.S. or less depending on the ambient illuminance.
- \*5 It does not work properly in case connected to the controller ver.1\*\*.

## • 350mm type (Class3R)

HL-C235CE HL-C2			B5CE-MK			
Model No.		Diffuse Reflection   Specular Reflection		Diffuse Reflection	Specular Reflection	
Measurement method*1		Diffuse reflection/Specular reflection			Opecular Reflection	
Measurement center distance		350mm	348mm	350mm	348mm	
Me	asurement range*2	±50mm	±42mm	±50mm	±42mm	
Ве	am source	Red : Max o	semiconductor laser output: 5mW, Emissio	Class 3R (JIS/IEC/GI n peak wavelength: 6	B/KS) 558nm	
Ве	am diameter*3	Approx.	φ250μm	Approx. 25	0 x 3500μm	
Bea	am receiving element		Linear ima	ige sensor		
Re	solution	2.0µm/	average times: 256,	0.5µm/average time	s: 4096	
Lin	earity		±0.03	% F.S.		
	mperature aracteristics		0.01%	F.S./°C		
or	Laser emission		Green LED: ON du	ring laser emission.		
Indicator	Measurement range	Near measurement ce	Yellow enter: ON/within measu	/ LED: rement range : Blink/B	eyond the range: OFF	
Pro	otective structure	IP67 (except connector)				
Ро	llution Degree	2				
Insulation Resistance		20M ohms or more by 500V dc megger (between all the terminals and enclosure.)				
Dielectric	Commercial Frequency	AC500V for 1min. (between all the terminals and enclosure.)				
Diel	₹ Impulse	+/- 1000V 1.2/50 µs (between all the terminals and enclosure.)				
Vib	ration resistance	Endurance: 10 to 55Hz (cycle: 1 minute), Resistant amplitude of vibration: 1.5mm, in X, Y, and Z directions for 2 hours				
Sh	ock resistance	196m/ s <sup>2</sup> in X, Y, and Z directions for 3 times				
Am	bient illuminance	3,000lx or less*4 (illuminance at beam receiving surface using incandescent lamp)				
Am	bient temperature	0 to +45°C (No dew condensation or icing allowed), At storage: -20 to +70°C				
Am	bient humidity	35 to 85%RH At storage: 35 to 85%RH				
Am	bient Height	2000m or less				
Ма	terial	Main unit case & cover: aluminum die-cast, Front cover: glass				
Cable length		0.5m				
Ca	ble extension	Extendible to	30m long maximum	using the optional ex	tension cable.	
We	eight	Approx. 450g including cable weight				
Su	ited controller *5	Controller ver.2.00 or later				
Ac	cessory	Laser warning label: 1 set				
Ар	plicable standards	Conformed to EMC Directive, Attained Korea's S-mark certification				

For measuring conditions, refer to "8-2 Sensor Head Specifications" - "CHECK in specifications".

- \*1 Use the external ND filter (optional) in case the amount of reflected beam is too large on Specular Reflection installation.
- \*2 The measurement range is limited between +0.0 and +50mm (in case the sampling cycle is 20µs at diffuse reflection), between +0.0 and +42mm (in case the sampling cycle is 20µs at specular reflection), between +36 and +50mm (in case the sampling cycle is 10µs at diffuse reflection), or between +36 and +42mm (in case the sampling cycle is 10µs at specular reflection).
- \*3 The figure shows the value at measurement center distance. It is determined by 1/e² (approximately 13.5%) of center beam intensity. The reflectance around the detecting point may be higher than at the point due to leak light outside the specified area, and this may affect the measurement value.
- \*4 Variance is  $\pm 0.03\%$  F.S. or less depending on the ambient illuminance.
- \*5 It does not work properly in case connected to the controller ver.1\*\*.

## • 350mm type (Class3R)

- 00	onini type (	Old 3301 ()		
Model No.		HL-C235CE-W	HL-C235CE-WMK	
Measurement method*1		Diffuse reflection		
Measurement center distance		350mm	350mm	
Measu	rement range <sup>*2</sup>	±200mm	±200mm	
Beam	source	Red semiconductor laser Cla Max output: 5mW, Emission	lss 3R (JIS/IEC/GB/KS/FDA) n peak wavelength: 658nm	
Beam	diameter*3	Approx. φ400μm	Approx. 400 x 6500μm	
Beam re	eceiving element	Linear ima	ge sensor	
Resolu	ution	8µm/ average times: 256,	2μm/average times: 4096	
Linear	rity	$\pm 0.04\% \text{F.S.}$ (-200 to 0mm), ±0.08%	F.S. (0 to +200mm) (F.S. = ±200mm)	
	erature cteristics	0.01%	F.S./°C	
<sub>5</sub> La	aser emission	Green LED: ON du	ring laser emission.	
<del>'=</del>	leasurement ange		Yellow LED: within measurement range : Blink/Beyond the range: OFF	
Protec	ctive structure	IP67 (except connector)		
Polluti	ion Degree	2		
Insulati	ion Resistance	20M ohms or more by 500V dc megger (b	petween all the terminals and enclosure.)	
Dielectric Withstand	Commercial Frequency	AC500V for 1min. (between all the terminals and enclosure.)		
Die Wit	Impulse	+/- 1000V 1.2/50 μs (between all the terminals and enclosure.)		
Vibratio	on resistance	Endurance: 10 to 55Hz (cycle: 1 minute), Resistant amplitude of vibration: 1.5mm, in X, Y, and Z directions for 2 hours		
Shock	resistance	196m/ s <sup>2</sup> in X, Y, and Z directions for 3 times		
Ambie	ent illuminance	3,000lx or less*4 (illuminance at beam red	ceiving surface using incandescent lamp)	
Ambier	nt temperature	0 to +45°C (No dew condensation or icing allowed), At storage: –20 to +70°C		
Ambie	ent humidity	35 to 85%RH At storage: 35 to 85%RH		
Ambient Height		2000m or less		
Material		Main unit case & cover: aluminum die-cast, Front cover: glass		
Cable length		0.5m		
Cable extension		Extendible to 30m long maximum using the optional extension cable.		
Weigh	nt	Approx. 300g including cable weight		
Acces	sory	Laser warnin	g label: 1 set	
Accessory  Applicable standards		Conformed to EMC Directive		

For measuring conditions, refer to "8-2 Sensor Head Specifications" - "CHECK in specifications".

- \*1 Use the external ND filter (optional) in case the amount of reflected beam is too large on Specular Reflection installation.
- \*2 The measurement range is limites between -70 and +200mm (in case the sampling cycle is 20μs), or between +100 and +200mm (in case the sampling cycle is 10μs).
- \*3 The figure shows the value at measurement center distance. It is determined by 1/e² (approximately 13.5%) of center beam intensity. The reflectance around the detecting point may be higher than at the point due to leak light outside the specified area, and this may affect the measurement value.
- \*4 Variance is  $\pm 0.08\%$  F.S. or less depending on the ambient illuminance.

• 8mm type (Class1)

• (	smm type (Cla	ass1)		
Model No.		HL-C201A(E)-SP2	HL-C201A(E)-SP2M	
Measurement method		Specular reflection		
Measurement center distance		8m	nm	
Mea	asurement range <sup>*1</sup>	±0.8	Smm	
Bea	am source	Red semiconductor laser Max output: 0.1mW, Emission	Class 1 (JIS/IEC/GB/KS) on peak wavelength: 658nm	
Bea	am diameter <sup>*2</sup>	Approx. φ20μm	Approx. 20 x 700μm	
Bea	m receiving element	Linear ima	ige sensor	
Res	solution	0.04µm/ average times: 256, [E type <sup>(3)</sup> : 0.25µm/ a	0.01µm/average times: 4096 average times: 256]	
Lin	earity	±0.02% F.S. [E type	e <sup>(*4)</sup> : ±0.032% F.S.]	
	nperature aracteristics	0.02%	F.S./°C	
or	Laser emission	Green LED: ON du	ring laser emission.	
Indicator	Measurement range	Yellow LED: Near measurement center: ON/within measurement range : Blink/Beyond the range: OFF		
Pro	tective structure	IP67 (except connector)		
Pol	lution Degree	2		
Inst	ulation Resistance	20M ohms or more by 500V dc megger (I	between all the terminals and enclosure.)	
Dielectric	Commercial Frequency	AC500V for 1min. (between all the terminals and enclosure.)		
Die	Impulse	+/- 1000V 1.2/50 µs (between	all the terminals and enclosure.)	
Vib	ration resistance	Endurance: 10 to 55Hz (cycle: 1 minute), Resistant amplitude of vibration: 1.5mm in X, Y, and Z directions for 2 hours		
Sho	ock resistance	196m/ s <sup>2</sup> in X, Y, and Z directions for 3 times		
Am	bient illuminance	3,000lx or less(*5) (illuminance at beam receiving surface using incandescent lamp)		
Am	bient temperature	0 to +45°C (No dew condensation or ic	sing allowed), At storage: –20 to +70°C	
Ambient humidity		35 to 85%RH At storage: 35 to 85%RH		
Ambient Height		2000m or less		
Material		Main unit case & cover: alu	ıminum, Front cover: glass	
Cal	ble length	0.08m		
Cal	ble extension	Extendible to 30m long maximum i	using the optional extension cable.	
We	ight	Approx. 300g inclu	uding cable weight	
Acc	cessory	Laser warnin	g label: 1 set	
App	olicable standards	Conformed to EMC Directive		
		-		

For measuring conditions, refer to "8-2 Sensor Head Specifications" - "CHECK in specifications".

- \*1 The measurement range is between +0.1 and +0.8mm (in case the sampling cycle is 20µs), or between +0.7 and +0.8mm (in case the sampling cycle is 10µs).
- \*2 The figure shows the value at measurement center distance. It is determined by 1/e² (approximately 13.5%) of center beam intensity. The reflectance around the detecting point may be higher than at the point due to leak light outside the specified area, and this may affect the measurement value.
- \*3 The minimum resolution of 0.25µm can be achieved if the sensor head is connected to the controller that is not subject to "Foreign Exchange and Foreign Trade Law".
- \*4 The linearity of ±0.032%F.S. can be achieved if the sensor head is connected to the controller that is not subject to "Foreign Exchange and Foreign Trade Law".
- \*5 Variance is  $\pm 0.02\%$  F.S. or less depending on the ambient illuminance.

## • 15mm type (Class1)

	el No.	HL-C201A(E)-SP3	HL-C201A(E)-SP3M	
Measurement method		Specular reflection		
Measurement		15mm		
	er distance			
Meas	surement range*1	±1n		
Bear	m source	Red semiconductor laser Max output: 0.3mW, Emission	Class 1 (JIS/IEC/GB/KS) on peak wavelength: 658nm	
Bear	m diameter*2	Approx. φ30μm	Approx. 30 x 1400μm	
Beam	n receiving element	Linear ima	ge sensor	
Reso	olution	0.04μm/ average times: 256, [E type <sup>(*3)</sup> : 0.25μm/	0.01µm/average times: 4096 average times: 256]	
Linea	arity	±0.02% F.S. [E type	e <sup>(*4)</sup> : ±0.025% F.S.]	
	perature acteristics	0.02% I	F.S./°C	
or	Laser emission	Green LED: ON dur	ring laser emission.	
=	Measurement range	Yellow LED: Near measurement center: ON/within measurement range : Blink/Beyond the range: OFF		
Prote	ective structure	IP67 (except connector)		
Pollu	ution Degree	2		
Insula	ation Resistance	20M ohms or more by 500V dc megger (between all the terminals and enclosure.)		
Dielectric Withstand	Commercial Frequency	AC500V for 1min. (between all the terminals and enclosure.)		
Diele	Impulse	+/- 1000V 1.2/50 μs (between all the terminals and enclosure.)		
Vibra	ation resistance	Endurance: 10 to 55Hz (cycle: 1 minute), Resistant amplitude of vibration: 1.5mm, in X, Y, and Z directions for 2 hours		
Shoo	ck resistance	196m/ s <sup>2</sup> in X, Y, and Z directions for 3 times		
Amb	ient illuminance	3,000lx or less <sup>(*5)</sup> (illuminance at beam receiving surface using incandescent lamp)		
Ambi	ent temperature	0 to +45°C (No dew condensation or ic	ing allowed), At storage: –20 to +70°C	
Amb	ient humidity	35 to 85%RH At storage: 35 to 85%RH		
Ambient Height		2000m or less		
Material		Main unit case & cover: aluminum, Front cover: glass		
Cable length		0.5	5m	
Cabl	e extension	Extendible to 30m long maximum using the optional extension cable.		
Weig	ght	Approx. 400g inclu	iding cable weight	
Acce	essory	Laser warning label: 1 set		
Appli	icable standards	Conformed to EMC Directive		

For measuring conditions, refer to "8-2 Sensor Head Specifications" - "CHECK in specifications".

- \*1 The measurement range is between +0.1 and +1.0mm (in case the sampling cycle is 20µs), or between +0.8 and +1.0mm (in case the sampling cycle is 10µs).
- \*2 The figure shows the value at measurement center distance. It is determined by 1/e² (approximately 13.5%) of center beam intensity. The reflectance around the detecting point may be higher than at the point due to leak light outside the specified area, and this may affect the measurement value.
- \*3 The minimum resolution of 0.25µm can be achieved if the sensor head is connected to the controller that is not subject to "Foreign Exchange and Foreign Trade Law".
- \*4 The linearity of ±0.025%F.S. can be achieved if the sensor head is connected to the controller that is not subject to "Foreign Exchange and Foreign Trade Law".
- \*5 Variance is  $\pm 0.02\%$  F.S. or less depending on the ambient illuminance.

# 8-3 ND Filter Specifications


Model No.	HL-C2F01		
	HL-C203□/HL-C203□-MK		
	HL-C205□/HL-C205□-MK		
Applicable head	HL-C208□/HL-C208□-MK		
	HL-C211□/HL-C211□-MK		
	HL-C235□E/HL-C235□E-MK		
Fading rate	98% *1		
Shock resistance	196m/s <sup>2</sup> or more in X, Y, and Z directions for 3 times		
Ambient temperature	0 to +45°C (No dew condensation or icing allowed), At storage: -20 to +70°C		
A 1: (1 : 10)			
Ambient humidity	35 to 85%RH At Storage: 35 to 85%RH		
Material	Retentive portion: aluminum, ND area: glass		
Weight	Approx. 20g		
Accessory	Mounting screw:2		

<sup>\*1</sup> Mount the ND filter and use it if reflected light intensity from the measurement object is large.


## 8-4 Outside Dimension

## ■ Controller

• RS-232C type [HL-C2C(E)/HL-C2C(E)-P]




## • Ethernet type [HL-C21C(E)/HL-C21C(E)-P]



## ■ Sensor Head


• 10mm type (HL-C20100/HL-C20100-MK)



Unit: mm


#### • 30mm type (HL-C203B□/HL-C203B□-MK)






Unit: mm

#### Specular reflection




#### Diffuse reflection



Unit: mm


#### Specular reflection



## 8


## • 85mm type(HL-C208B□/HL-C208B□-MK/HL-C208C□/HL-C208C□-MK)

#### Diffuse reflection



Unit: mm


#### Specular reflection



Unit: mm


## • 110mm type(HL-C211B<sub>\(\sigma\)</sub>/HL-C211B<sub>\(\sigma\)</sub>/HL-C211C<sub>\(\sigma\)</sub>/HL-C211C<sub>\(\sigma\)</sub>

#### Diffuse reflection



Unit: mm

#### Specular reflection




Unit: mm

R

## 8


## • 350mm type(HL-C235BE/HL-C235BE-MK/HL-C235CE/HL-C235CE-MK)

#### Diffuse reflection



Unit: mm


#### Specular reflection




The reference surface for specular reflection installation

## •350mm type(HL-C235CE-W/HL-C235CE-WMK)

#### Diffuse reflection




#### • 8mm type [HL-C201A(E)-SP2/HL-C201A(E)-SP2M]




Unit: mm

### • 15mm type [HL-C201A(E)-SP3/HL-C201A(E)-SP3M]




• 30mm type (HL-C203F□/HL-C203F□-MK)

#### Diffuse reflection



Unit: mm

#### Specular reflection




Unit: mm

8

## 8


## • 110mm type (HL-C211Fp/HL-C211Fp-MK/HL-C211F5p/HL-C211F5p-MK)

#### Diffuse reflection




Unit: mm

#### Specular reflection




## ■ ND Filter (HL-C2F01)




Unit: mm

Diffuse reflection (ND filter attached) (HL-203 - HL-C203 - HK)



Unit: mm

Specular reflection (ND filter attached) (HL-203 - HL-C203 - HK)




Unit: mm

\* The measurement in installation is also the same in HL-C211 | HL-C211 | MK. \* For FDA-compliant models, please remove the ND filter when mounting with a beam attenuator.


## 8-5 Characteristics

## ■ Beam Diameter


#### • 10mm type




#### • 30mm type



#### • 50mm type




## • 85mm type




Q

#### • 110mm type




Unit: mm


#### • 350mm type (HL-C235 = E/HL-C235 = E-MK)



Unit: mm


## • 350mm type (HL-C235CE-W/HL-C235CE-WMK)





Unit: mm

#### • 15mm type




Unit: mm

8

## ■ Mutual Interference Area


When installing 2 or more sensor heads side by side, mutual interference occurs if the laser spots from other sensor heads fall within the shaded areas in the figure below. Install sensor heads as the laser spots from other sensor heads fall outside the shaded areas.

#### • 30mm type (HL-C203□/HL-C203□-MK)




Unit: mm

### • 50mm type (HL-C205□/HL-C205□-MK)




Unit: mm




Unit: mm

• 110mm type (HL-C211 -/HL-C211 --MK)




Unit: mm

#### • 350mm type (HL-C235 = E/HL-C235 = E-MK)



• 350mm type (HL-C235CE-W/HL-C235CE-WMK)



Unit: mm


## **OCHECK**

If beam from the other sensor head enters into the mutual interference area when two sensor heads are connected, set the "Interference Prevention" function to ON.

\* "4-3-3 Common Setting" – "Interference Prevention"


## Output Characteristics and Measurement Range Indicator

• 10mm type (HL-C201□/HL-C201□-MK)




- \*1 In the figure above, analog output setting is used as the initial setting.
- \*2 The measurement range is limited between +0.1 and +1.0mm (in case the sampling cycle is 20µs) or between +0.8 and +1.0mm (in case the sampling cycle is 10µs).
- \*3 The measurement range indicator at sampling cycle of 20μs or 10μs lights up at the center of limited measurement range.

#### • 30mm type (HL-C203□/HL-C203□-MK)




- \*1 In the figure above, analog output setting is used as the initial setting.
- \*2 The measurement range is limited between 0 and +5.0mm (in case the sampling cycle is 20μs) or between +3.8 and +5.0mm (in case the sampling cycle is 10μs).
- \*3 The measurement range indicator at sampling cycle of  $20\mu s$  or  $10\mu s$  lights up at the center of limited measurement range.




- \*1 In the figure above, analog output setting is used as the initial setting.
- \*2 The measurement range is limited between 0 and +4.6mm (in case the sampling cycle is  $20\mu s$ ) or between +3.6 and +4.6mm (in case the sampling cycle is  $10\mu s$ ).
- \*3 The measurement range indicator at sampling cycle of  $20\mu s$  or  $10\mu s$  lights up at the center of limited measurement range.

#### • 50mm type (HL-C205□/HL-C205□-MK)




- \*1 In the figure above, analog output setting is used as the initial setting.
- \*2 The measurement range is limited between +0.5 and +5.0mm (in case the sampling cycle is 20µs) or between +4.7 and +5.0mm (in case the sampling cycle is 10µs).
- \*3 The measurement range indicator at sampling cycle of  $20\mu s$  or  $10\mu s$  lights up at the center of limited measurement range.




- \*1 In the figure above, analog output setting is used as the initial setting.
- \*2 The measurement range is limited between +0.5 and +5.0mm (in case the sampling cycle is  $20\mu s$ ) or between +4.6 and +5.0mm (in case the sampling cycle is  $10\mu s$ ).
- \*3 The measurement range indicator at sampling cycle of  $20\mu s$  or  $10\mu s$  lights up at the center of limited measurement range.

### • 85mm type (HL-C208□/HL-C208□-MK)




- \*1 In the figure above, analog output setting is used as the initial setting.
- \*2 The measurement range is limited between 0 and +20mm (in case the sampling cycle is 20µs) or between +18 and +20mm (in case the sampling cycle is 10µs).
- \*3 The measurement range indicator at sampling cycle of  $20\mu s$  or  $10\mu s$  lights up at the center of limited measurement range.




- \*1 In the figure above, analog output setting is used as the initial setting.
- \*2 The measurement range is limited between 0 and +6mm (in case the sampling cycle is 20µs) or unmeasurable (in case the sampling cycle is 10µs).
- \*3 The measurement range indicator at sampling cycle of 20μs or 10μs lights up at the center of limited measurement range.

#### • 110mm type (HL-C211 - HL-C211 - HK)




- \*1 In the figure above, analog output setting is used as the initial setting.
- \*2 The measurement range is limited between +0.5 and +15.0mm (in case the sampling cycle is  $20\mu s$ ) or between +12.5 and +15.0mm (in case the sampling cycle is  $10\mu s$ ).
- \*3 The measurement range indicator at sampling cycle of  $20\mu s$  or  $10\mu s$  lights up at the center of limited measurement range.




- \*1 In the figure above, analog output setting is used as the initial setting.
- \*2 The measurement range is limited between +0.5 and +14.5mm (in case the sampling cycle is  $20\mu s$ ) or between +12.5 and +14.5mm (in case the sampling cycle is  $10\mu s$ ).
- \*3 The measurement range indicator at sampling cycle of 20µs or 10µs lights up at the center of limited measurement range.

#### • 350mm type (HL-C235 = E/HL-C235 = E-MK)




- \*1 In the figure above, analog output setting is used as the initial setting.
- \*2 The measurement range is limited between +0.0 and +50mm (in case the sampling cycle is 20µs) or between +36 and +50mm (in case the sampling cycle is 10µs).
- \*3 The measurement range indicator at sampling cycle of  $20\mu s$  or  $10\mu s$  lights up at the center of limited measurement range.




- \*1 In the figure above, analog output setting is used as the initial setting.
- \*2 The measurement range is limited between +0.0 and +42mm (in case the sampling cycle is  $20\mu$ s) or between +36 and +42mm (in case the sampling cycle is  $10\mu$ s).
- \*3 The measurement range indicator at sampling cycle of  $20\mu s$  or  $10\mu s$  lights up at the center of limited measurement range.

#### • 350mm type (HL-C235CE-W/HL-C235CE-WMK)




- \*1 In the figure above, analog output setting is used as the initial setting.
- \*2 The measurement range is limited between -70 and +200mm (in case the sampling cycle is  $20\mu s$ ) or between +100 and +200mm (in case the sampling cycle is  $10\mu s$ ).
- \*3 The measurement range indicator at sampling cycle of  $20\mu s$  or  $10\mu s$  lights up at the center of limited measurement range.

#### • 8mm type [HL-C201A(E)-SP2/HL-C201A(E)-SP2M]



- \*1 In the figure above, analog output setting is used as the initial setting.
- \*2 The measurement range is limited between +0.1 and +0.8mm (in case the sampling cycle is 20µs) or between +0.7 and +0.8mm (in case the sampling cycle is 10µs).
- \*3 The measurement range indicator at sampling cycle of 20μs or 10μs lights up at the center of limited measurement range.

#### • 15mm type [HL-C201A(E)-SP3/HL-C201A(E)-SP3M]



- \*1 In the figure above, analog output setting is used as the initial setting.
- \*2 The measurement range is limited between +0.1 and +1.0mm (in case the sampling cycle is  $20\mu s$ ) or between +0.8 and +1.0mm (in case the sampling cycle is  $10\mu s$ ).
- \*3 The measurement range indicator at sampling cycle of  $20\mu s$  or  $10\mu s$  lights up at the center of limited measurement range.

MEMO



# **Appendix**

1 Index ······2

٩рх

## 1 Index

-A-	
Accessories list·····	1-3
Accumulation amount ······	
Adjust the analog output ·······	· 4 <b>-</b> 45
Alarm delay times ·····	· 4-14
Alarm output delay ·····	
Alarm setting and outputs	· 4-84
Analog output at alarm ······	
Analog output at data unfixed $\cdots$	· 4-49
Analog output circuit ······	
Analog scaling ······	
Analysis mode ·····	· 4-36
-B-	
Basic operation······	3-6
BCC	· 5-13
Beam diameter ·····	
Buffering mode ······	
Buffering operation ·····	
Buffering procedure ······	
Buffering rate ·····	
Buffering setting·····	· 4-75
Buffering type ······	· 4-79
-C-	
Calculation ·····	
Calibration ·····	
Cautions on handling laser light	14
CE	
Change Indication Unit ······	· 4-61
Characteristics ·····	
Chattering prevention of termina	
input·····	
Classification of function ·······	
Command classification······	
Command list ······	
Common setting ·····	
Communication COM port	4-69

Communication specifications ··· 5-2 Compact programmable display ··· 1-8 Conditions when output data become unfixed ··· 4-85 Connection method of power supply · 1-15 Connection method of terminal block ··· 1-15 Connection of Intelligent Monitor AiM (PC) ··· 1-17 Programmable display operation ·· 3-1 Console setting ··· 4-72 Controller ··· 1-6 Controller specifications ··· 8-2 Correct handling ··· 8 Correct the deviation of the measurement value ··· 4-19 Corrective actions ··· 7-2
-D-
Data flow         4-2           Data read         4-83           Data transmission/reception         5-5
Data unfixed status ········· 4-85 Digit number of measurement value 4-52 Digital output at alarm ········ 4-50 Display update cycle of measurement value ······ 4-59 Display waveform of received light intensity ······ 3-14
Digit number of measurement value 4-52 Digital output at alarm · · · · · · · · 4-50 Display update cycle of measurement value · · · · · · · · 4-59 Display waveform of received light

_F_	_M_
FDA	Maintenance
Grounding 12	Measures to noise······10  Memory change·····4-64
-H-         Head setting···································	Memory copy
_I_	-N-
I/O circuit ······· 2-4 I/O terminal block ······· 2-1, 2-2, 2-3	ND filter         8-28           ND filter specifications         8-20
Initialization	-O-
Installation	Offset 4-40 Operation Coefficient 4-39 Operation screens 3-2 OUT setting 4-23 Output characteristics and measurement range 8-34 Output selection 4-23 Output setting copy 4-62 Outside dimension 8-22
JIS/IEC 14	Part names and functions ······1-6
Judgment Output Off Delay ······4-57  —L—  Laser control terminal block ······ 2-2  Lock ······ 7-7	Peak Recognition Sensitivity ···· 4-21 Power supply ···· 11 Priority setting of memory change 4-63 Protective structure ··· 9
LOOK 1-1	-R-

Timing 4-33 Timing chart 2-8 Transparent object 4-25 Trigger conditions 4-80 Trigger counter readout 4-82 Trigger delay 4-81
Trigger point ················4-81 Troubleshooting··············7-1 Type and format of commands ····5-5
-U-
Upper/lower Hysteresis of judgment output
-V-
Voltage Resistance ······10
− <b>W</b> −  Warming up time ······10  Wiring method ·····116
-Z- Zero set ······ 4-31

MEMO

Арх

## Revision history

Released date	Revision No.
October 2007	First release
May 2008	Second release
July 2008	Third release
October 2008	Fourth release
September 2009	Fifth release
June 2010	Sixth release
February 2011	Seventh release
December 2011	Eighth release
June 2013	Ninth release
November 2013	Tenth release
July 2014	Eleventh release
May 2017	Twelfth release
January 2019	Thirteenth release

Apx



Please contact .....

## Panasonic Industrial Devices SUNX Co., Ltd.

■ Overseas Sales Division (Head Office): 2431-1 Ushiyama-cho, Kasugai-shi, Aichi, 486-0901, Japan ■ Telephone: +81-568-33-861 ■ Facsimile: +81-568-33-8591

panasonic.net/id/pidsx/global

For sales network, please visit our website.